

LOOKING UP AT SOFFIT BOARD AT GROUND FLOOR UNIT ENTRIES.



SOFFIT BOARDS SHOULD BE CUT IN STRAIGHT LINES. THERE SHOULD BE A CONSISTENT JOINT (1/4"-3/8"). THE JOINT SHOULD NOT GO FROM 1/16" TO 1/2". REMOVE AND REPLACE.

