


AS DISCUSSED ON SITE ON 04/08/2021, ALL HVAC IN BUILDING F SHOULD ALIGN WITH THE LIGHTS. THEY SHOULD BE AT THE SAME ANGLE AND EVENLY SPACED. SEE RCP ATTACHED BELOW FROM HVAC LAYOUT SUBMITTAL. REMOVE AND REPLACE.



BUILDING F HVAC PENETRATION LAYOUT SUBMITTAL 12/15/2020



BUILDING F HVAC PENETRATION LAYOUT SUBMITTAL 12/15/2020

