

FCP BOARDS SHOULD BE CUT IN STRIAGHT LINES. THEIR SHOULD BE A CONSISTANT JOINT (1/4"-3/8"). THE JOINT SHOULD NOT GO FROM 1/16" TO 1/2". REMOVE AND REPLCE.

PICTURE TAKEN AT RECESSED ENTRY AT GROUND FLOOR BUILDING B

104 625 1/1
Elev = 401-VC-NO1 8 2-11/16" x 1/16"
#P-101-B Insuling