

THIS IS SIMPLY
WAY TO MUCH
SEALANT. THERE
SHOULD BE A 1/2"
SEALANT AND
BACKER ROD MAX.
REMOVE AND
REPLACE.

PHOTO TAKEN IN STAIRWELL BUILDING B.

