

SECTION 087100
DOOR HARDWARE

SECTION 087100 - DOOR HARDWARE

GENERAL

1.1 SUMMARY

A. Section Includes:

1. Mortise hinges.
2. Glass pivot hinges.
3. Mechanical locks and latches.
4. Auxiliary locks.
5. Electric strikes.
6. Electromechanical locks.
7. Glass patch cylindrical locks.
8. Latch and deadbolt monitors.
9. Manual flush bolts.
10. Exit devices and auxiliary items.
11. Lock cylinders.
12. Keying.
13. Key control system and lock boxes.
14. Operating trim.
15. Accessories for pairs of doors.
16. Surface closers.
17. Concealed closers.
18. Automatic door operators.
19. Wall- and floor-mounted stops.
20. Electromagnetic door holders.
21. Door silencers.
22. Door gasketing and sweeps.
23. Automatic door bottom seals.
24. Thresholds.
25. Metal protective trim units.
26. Door access control devices.

B. Related Requirements:

1. Section 081113 "Hollow Metal Doors and Frames"
2. Section 081416 "Flush Wood Doors"
3. Section 084123 "Fire-Rated Glass & Framing System"
4. Section 084229.23 "Sliding Automatic Entrances"
5. Section 084413 "Glazed Aluminum Curtainwall"
6. Section 102219 "Demountable Partitions"
7. Section 102300 "Glazed Interior Wall & Door Assemblies"

1.2 COORDINATION

- A. Floor-Recessed Door Hardware: Coordinate layout and installation with floor construction.

SECTION 087100
DOOR HARDWARE

1. Cast anchoring inserts into concrete.
- B. Installation Templates: Distribute for doors, frames, and other work specified to be factory prepared. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.
- C. Security / Access Control: Coordinate installation of door hardware, keying, and access control with Owner's security vendor.
- D. Electrical System Roughing-In: Coordinate layout and installation of electrified door hardware with connections to power supplies and building safety and security systems.

1.3 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.
 1. Conference participants must include Installer's Architectural Hardware Consultant and Owner's security consultant.
- B. Keying Conference: Conduct conference at Project site.
 1. Conference participants must include Installer's Architectural Hardware Consultant and Owner's security consultant.
 2. Incorporate conference decisions into keying schedule after reviewing door hardware keying system, including, but not limited to, the following:
 - a. Flow of traffic and degree of security required.
 - b. Preliminary key system schematic diagram.
 - c. Requirements for key control system.
 - d. Requirements for access control.
 - e. Address for delivery of keys.

1.4 ACTION SUBMITTALS

- A. Product Data:
 1. Mortise hinges.
 2. Glass pivot hinges.
 3. Mechanical locks and latches.
 4. Auxiliary locks.
 5. Electric strikes.
 6. Electromechanical locks.
 7. Glass patch cylindrical locks.
 8. Latch and deadbolt monitors.
 9. Manual flush bolts.
 10. Exit devices and auxiliary items.
 11. Lock cylinders.
 12. Keying.
 13. Key control system and lock boxes.

SECTION 087100
DOOR HARDWARE

14. Operating trim.
 15. Accessories for pairs of doors.
 16. Surface closers.
 17. Concealed closers.
 18. Automatic door operators.
 19. Wall- and floor-mounted stops.
 20. Electromagnetic door holders.
 21. Door silencers.
 22. Door gasketing and sweeps.
 23. Automatic door bottom seals.
 24. Thresholds.
 25. Metal protective trim units.
 26. Door access control devices.
- B. Product Data Submittals: For each product.
- C. Shop Drawings: For electrified door hardware.
1. Include diagrams for power, signal, and control wiring.
 2. Include details of interface of electrified door hardware and building safety and security systems.
- D. Door Hardware Schedule: Prepared by or under the supervision of Installer's Architectural Hardware Consultant. Coordinate door hardware schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
1. Submittal Sequence: Submit door hardware schedule concurrent with submissions of product data, Samples, and Shop Drawings. Coordinate submission of door hardware schedule with scheduling requirements of other work to facilitate the fabrication of other work that is critical in Project construction schedule.
 2. Format: Use same scheduling sequence and format and use same door AND hardware set numbers as in door hardware schedule in the Contract Documents.
 3. Content: Include the following information:
 - a. Identification number, location, hand, fire rating, size, and material of each door and frame.
 - b. Locations of each door hardware set, cross-referenced to Drawings on floor plans and to door and frame schedule.
 - c. Complete designations, including name and manufacturer, type, style, function, size, quantity, function, and finish of each door hardware product.
 - d. Description of electrified door hardware sequences of operation and interfaces with other building control systems.
 - e. Fastenings and other installation information.
 - f. Explanation of abbreviations, symbols, and designations contained in door hardware schedule.
 - g. Mounting locations for door hardware.
 - h. List of related door devices specified in other Sections for each door and frame.
- E. Keying Schedule: Prepared by or under the supervision of Installer's Architectural Hardware Consultant, detailing Owner's final keying instructions for locks. Include schematic keying

SECTION 087100
DOOR HARDWARE

diagram and index each key set to unique door designations that are coordinated with the Contract Documents.

1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer and Architectural Hardware Consultant.
- B. Product Certificates: For each type of electrified door hardware.
 - 1. Certify that door hardware for use on each type and size of labeled fire-rated doors complies with listed fire-rated door assemblies.
- C. Product Test Reports: For compliance with accessibility requirements, for tests performed by manufacturer and witnessed by a qualified testing agency, for door hardware on doors located in accessible routes.
- D. Field quality-control reports.
- E. Sample Warranty: For special warranty.

1.6 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For each type of door hardware to include in maintenance manuals.
- B. Schedules: Final door hardware and keying schedule.

1.7 QUALITY ASSURANCE

- A. Installer Qualifications: Supplier of products and an employer of workers trained and approved by product manufacturers and of an Architectural Hardware Consultant who is available during the course of the Work to consult Contractor, Architect, and Owner about door hardware and keying.
 - 1. Warehousing Facilities: In Project's vicinity.
 - 2. Scheduling Responsibility: Preparation of door hardware and keying schedule.
 - 3. Engineering Responsibility: Preparation of data for electrified door hardware, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lockup for door hardware delivered to Project site.
- B. Tag each item or package separately with identification coordinated with the final door hardware schedule, and include installation instructions, templates, and necessary fasteners with each item or package.

SECTION 087100
DOOR HARDWARE

- C. Deliver keys to manufacturer of key control system for subsequent delivery to Owner.
 - 1. Deliver high-security keys and permanent cores to Owner by registered mail or overnight package service.

1.9 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Structural failures, including excessive deflection, cracking, or breakage.
 - b. Faulty operation of doors and door hardware.
 - c. Deterioration of metals, metal finishes, and other materials beyond normal weathering and use.
 - 2. Warranty Period: Three years from date of Substantial Completion unless otherwise indicated below:
 - a. Exit Devices: Two years from date of Substantial Completion.
 - b. Manual Closers: 10 years from date of Substantial Completion.
 - c. Concealed Floor Closers: Five years from date of Substantial Completion.

PRODUCTS

1.10 PERFORMANCE REQUIREMENTS

- A. Fire-Rated Door Assemblies: Where fire-rated doors are indicated, provide door hardware complying with NFPA 80 that is listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at positive pressure in accordance with NFPA 252 or UL 10C.
- B. Smoke- and Draft-Control Door Assemblies: Where smoke- and draft-control door assemblies are required, provide door hardware that complies with requirements of assemblies tested in accordance with UL 1784 and installed in compliance with NFPA 105.
 - 1. Air-Leakage Rate: Maximum air leakage of **0.3 cfm per sq. ft. (3 cu. m per minute/sq. m)** at the tested pressure differential of **0.3 inch wg (75 Pa)** of water.
- C. Electrified Door Hardware: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- D. Means of Egress Doors: Latches do not require more than **15 lbf (67 N)** to release the latch. Locks do not require use of a key, tool, or special knowledge for operation.
- E. Accessibility Requirements: For door hardware on doors in an accessible route, comply with ICC A117.1 and State of Illinois Accessibility Code.

SECTION 087100
DOOR HARDWARE

1. Provide operating devices that do not require tight grasping, pinching, or twisting of the wrist and that operate with a force of not more than **5 lbf (22.2 N)**.
2. Comply with the following maximum opening-force requirements:
 - a. Interior, Non-Fire-Rated Hinged Doors: **5 lbf (22.2 N)** applied perpendicular to door.
 - b. Sliding or Folding Doors: **5 lbf (22.2 N)** applied parallel to door at latch.
 - c. Fire Doors: Minimum opening force allowable by authorities having jurisdiction.
3. Bevel raised thresholds with a slope of not more than 1:2. Provide thresholds not more than **1/2 inch (13 mm)** high.
4. Adjust door closer sweep periods so that, from an open position of 90 degrees, the door will take at least 5 seconds to move to a position of 12 degrees from the latch.
5. Adjust spring hinges so that, from an open position of 70 degrees, the door will take at least 1.5 seconds to move to the closed position.

1.11 SCHEDULED DOOR HARDWARE

- A. Provide products for each door that comply with requirements indicated in Part 2 AND door hardware schedule below.
 1. Door Hardware Sets are indicated on Drawings (Door Schedule).

1.12 MORTISE HINGES

- A. Mortise Hinges: ANSI/BHMA A156.1. Provide template-produced hinges for hinges installed on hollow-metal doors and hollow-metal frames.
 1. IVES - 5BB1 4.5" x 4.5"
 2. IVES - 5BB1HW 4.5" x 4.5"

1.13 GLASS PIVOT HINGES

- A. Glass Pivot Hinges: ANSI/BHMA A156.4.
 1. CRL - Clear View Pivot Hinge
 2. Alur – Duo - 3/4" Offset Pivot Hinge

1.14 MECHANICAL LOCKS AND LATCHES

- A. Lock Functions: As indicated in door hardware schedule.
- B. Lock Throw: Comply with testing requirements for length of bolts required for labeled fire doors, and as follows:
 1. Bored Locks: Minimum **1/2-inch (13-mm)** latchbolt throw.
 2. Mortise Locks: Minimum **3/4-inch (19-mm)** latchbolt throw.
 3. Deadbolts: Coordinate throw requirements w/ deadbolt monitor.
- C. Lock Backset: **2-3/4 inches (70 mm)** unless otherwise indicated.

SECTION 087100
DOOR HARDWARE

D. Lock Trim:

1. Description: As indicated in door hardware schedule.
2. Levers: As indicated in door hardware schedule.
3. Escutcheons (Roses): As indicated in door hardware schedule.
4. Dummy Trim: Match lever lock trim and escutcheons.

E. Strikes: Provide manufacturer's standard strike for each lock bolt or latchbolt complying with requirements indicated for applicable lock or latch and with strike box and curved lip extended to protect frame; finished to match lock or latch.

1. Flat-Lip Strikes: For locks with three-piece antifriction latchbolts, as recommended by manufacturer.
2. Extra-Long-Lip Strikes: For locks used on frames with applied wood casing trim.
3. Aluminum-Frame Strike Box: Manufacturer's special strike box fabricated for aluminum framing.
4. Rabbet Front and Strike: Provide on locksets for rabbeted meeting stiles.

F. Mortise Locks: ANSI/BHMA A156.13, Operational Grade 1; stamped steel case with steel or brass parts; Series 1000.

1. Schlage – L Series

1.15 AUXILIARY LOCKS

A. Bored Auxiliary Locks: ANSI/BHMA A156.36, Grade 1; with strike that suits frame.

1. Schlage

B. Mortise Auxiliary Locks: ANSI/BHMA A156.36, Grade 1; with strike that suits frame.

1. Schlage – L Series

1.16 ELECTRIC STRIKES

A. Electric Strikes: ANSI/BHMA A156.31, Grade 1; with faceplate to suit lock and frame.

1. Von Duprin - 6200 Series

1.17 ELECTROMECHANICAL LOCKS

A. Electromechanical Locks: ANSI/BHMA A156.25, Grade 1; motor or solenoid driven; with strike that suits frame.

1. Schlage – L Series

2. Type: Mortise

1.18 GLASS PATCH LOCKS

A. Glass Patch Locks: ANSI/BHMA A156.13, Operational Grade 1; stamped steel case with steel or brass parts; Series 1000.

SECTION 087100
DOOR HARDWARE

1. Alur – Duo – ND Series (Schlage)
2. Type: Glass Patch Cylindrical

1.19 LATCH AND DEADBOLT MONITORS

- A. Latch and Deadbolt Monitors: See hardware schedule below and coordinate with other devices.
 1. Allegion

1.20 MANUAL FLUSH BOLTS

- A. Manual Flush Bolts: ANSI/BHMA A156.16; minimum 3/4-inch (19-mm) throw; designed for mortising into door edge.
 1. Ives - FB45X

1.21 EXIT DEVICES AND AUXILIARY ITEMS

- A. Exit Devices and Auxiliary Items: ANSI/BHMA A156.3.
 1. Von Duprin – 35A Series

1.22 LOCK CYLINDERS

- A. Lock Cylinders: Tumbler type, constructed from brass or bronze, stainless steel, or nickel silver.
 1. Schlage – L Series (FSIC – Primus)
- B. Standard Lock Cylinders: ANSI/BHMA A156.5, Grade 1 permanent cores; face finished to match lockset.
 1. Core Type: Interchangeable
- C. Construction Master Keys: Provide cylinders with feature that permits voiding of construction keys without cylinder removal. Provide 10 construction master keys.
- D. Construction Cores: Provide construction cores that are replaceable by permanent cores. Provide 10 construction master keys.

1.23 KEYING

- A. Keying System: Factory registered, complying with guidelines in ANSI/BHMA A156.28, appendix. Provide one extra key blank for each lock. Incorporate decisions made in keying conference.
 1. Great-Grand Master Key System: Change keys, a master key, a grand master key, and a great-grand master key operate cylinders.
 - a. Schlage – Primus (FSIC)

SECTION 087100
DOOR HARDWARE

- b. Provide three cylinder change keys and five each of master, grand master, and great-grand master keys.
 - B. Keys: Nickel silver.
 - 1. Stamping: Permanently inscribe each key with a visual key control number and include the following notation:
 - a. Notation: "DO NOT DUPLICATE."
- 1.24 KEY CONTROL SYSTEM
 - A. Key Lock Boxes: Designed for storage of two keys.
 - 1. Knox
- 1.25 OPERATING TRIM
 - A. Operating Trim: ANSI/BHMA A156.6; See hardware schedule below for types / finishes.
- 1.26 ACCESSORIES FOR PAIRS OF DOORS
 - A. Coordinators: ANSI/BHMA A156.3; consisting of active-leaf, hold-open lever, and inactive-leaf release trigger; fabricated from steel with nylon-coated strike plates; with built-in, adjustable safety release; and with internal override.
 - B. Astragals: ANSI/BHMA A156.22.
- 1.27 SURFACE CLOSERS
 - A. Surface Closers: ANSI/BHMA A156.4; rack-and-pinion hydraulic type with adjustable sweep and latch speeds controlled by key-operated valves and forged-steel main arm. Comply with manufacturer's written instructions for size of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Provide factory-sized closers, adjustable to meet field conditions and requirements for opening force.
 - 1. LCN - 4040XP
- 1.28 CONCEALED CLOSERS
 - A. Concealed Closers: ANSI/BHMA A156.4; rack-and-pinion hydraulic type with adjustable sweep and latch speeds controlled by key-operated valves. Comply with manufacturer's written instructions for size of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Provide factory-sized closers, adjustable to meet field conditions and requirements for opening force.
 - 1. CRL – Clear View
 - 2. Alur – Duo - Concealed Overhead Closer – 90-degree Hold Open

SECTION 087100
DOOR HARDWARE

1.29 AUTOMATIC DOOR OPERATORS

- A. Automatic Door Operators: See hardware schedule below and coordinate with other devices.
 - 1. Assa Abloy – SW100 Series
 - 2. Assa Abloy – SW200i-IG Series

1.30 ELECTROMAGNETIC DOOR HOLDERS

- A. Electromagnetic Door Holders: ANSI/BHMA A156.15, Grade 1; wall-mounted electromagnetic single unit with strike plate attached to swinging door; coordinated with fire detectors and interfaced with fire-alarm system for labeled fire-rated door assemblies.
 - 1. Sentronic - SEM 7800 Series

1.31 DOOR SILENCERS

- A. Door Silencers: See hardware schedule below.
 - 1. Ives - Silencer SI6X

1.32 DOOR GASKETING AND SWEEPS

- A. Door Gasketing and Sweeps: ANSI/BHMA A156.22; with resilient or flexible seal strips that are easily replaceable and readily available from stocks maintained by manufacturer.
 - 1. Pemko / NGP / Zero
- B. Maximum Air Leakage: When tested in accordance with ASTM E283/E283M with tested pressure differential of 0.3 inch wg (75 Pa), as follows:
 - 1. Smoke-Rated Gasketing: 0.3 cfm/sq. ft. (3 cu. m per minute/sq. m) of door opening.
 - 2. Gasketing on Single Doors: 0.3 cfm/sq. ft. (3 cu. m per minute/sq. m) of door opening.
 - 3. Gasketing on Double Doors: 0.50 cfm per ft. (0.000774 cu. m/s per m) of door opening.

1.33 AUTOMATIC DOOR BOTTOM SEALS

- A. Automatic Door Bottom Seals: See hardware schedule below.
 - 1. NGP - 225S

1.34 THRESHOLDS

- A. Thresholds: ANSI/BHMA A156.21; fabricated to full width of opening indicated.
 - 1. Pemko / NGP / Zero
 - 2. Tubelite

SECTION 087100
DOOR HARDWARE

1.35 METAL PROTECTIVE TRIM UNITS

- A. Metal Protective Trim Units: ANSI/BHMA A156.6; fabricated from 0.050-inch- (1.3-mm-) thick brass; with manufacturer's standard machine or self-tapping screw fasteners.
 - 1. Ives – 8400 Series

1.36 DOOR ACCESS CONTROL DEVICES

- A. Coordinate with Owner's Security Vendor.

1.37 FABRICATION

- A. Manufacturer's Nameplate: Do not provide products that have manufacturer's name or trade name displayed in a visible location except in conjunction with required fire-rating labels and as otherwise approved by Architect.
 - 1. Manufacturer's identification is permitted on rim of lock cylinders only.
- B. Base Metals: Produce door hardware units of base metal indicated, fabricated by forming method indicated, using manufacturer's standard metal alloy, composition, temper, and hardness. Furnish metals of a quality equal to or greater than that of specified door hardware units and ANSI/BHMA A156.18.
- C. Fasteners: Provide door hardware manufactured to comply with published templates prepared for machine, wood, and sheet metal screws. Provide screws that comply with commercially recognized industry standards for application intended; however, aluminum fasteners are not permitted. Provide Phillips flat-head screws with finished heads to match surface of door hardware unless otherwise indicated.
 - 1. Concealed Fasteners: For door hardware units that are exposed when door is closed, except for units already specified with concealed fasteners. Do not use through bolts for installation where bolt head or nut on opposite face is exposed unless it is the only means of securely attaching the door hardware. Where through bolts are used on hollow door and frame construction, provide sleeves for each through bolt.
 - 2. Fire-Rated Applications:
 - a. Wood or Machine Screws; provide door blocking as req'd.
 - 1) Hinges mortised to doors or frames; use threaded-to-the-head wood screws for wood doors and frames.
 - 2) Strike plates to frames.
 - 3) Closers to doors and frames.
 - 4) Surface hinges to doors.
 - 5) Closers to doors and frames.
 - 6) Surface-mounted exit devices.
 - 3. Spacers or Sex Bolts: For through bolting of hollow-metal doors.

SECTION 087100
DOOR HARDWARE

4. Gasketing Fasteners: Provide noncorrosive fasteners for exterior applications and elsewhere as indicated.

1.38 FINISHES

- A. Provide finishes complying with ANSI/BHMA A156.18 as indicated in door hardware schedule.
- B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- C. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

EXECUTION

1.39 EXAMINATION

- A. Examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire-rated door assembly construction, wall and floor construction, and other conditions affecting performance of the Work.
- B. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

1.40 PREPARATION

- A. Steel Doors and Frames: For surface-applied door hardware, drill and tap doors and frames in accordance with ANSI/SDI A250.6.
- B. Wood Doors: Comply with door and hardware manufacturers' written instructions.

1.41 INSTALLATION

- A. Mounting Heights: Mount door hardware units at heights to comply with the following unless otherwise indicated or required to comply with governing regulations.
 1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
 2. Wood Doors: DHI's "Recommended Locations for Architectural Hardware for Wood Flush Doors."

SECTION 087100
DOOR HARDWARE

- B. Install each door hardware item to comply with manufacturer's written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing work. Do not install surface-mounted items until finishes have been completed on substrates involved.
 - 1. Set units level, plumb, and true to line and location. Adjust and reinforce attachment substrates as necessary for proper installation and operation.
 - 2. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors in accordance with industry standards.
- C. Hinges: Install types and in quantities indicated in door hardware schedule, but not fewer than the number recommended by manufacturer for application indicated or one hinge for every **30 inches (760 mm)** of door height, whichever is more stringent, unless other equivalent means of support for door, such as spring hinges or pivots, are provided.
- D. Intermediate Offset Pivots: Where offset pivots are indicated, provide intermediate offset pivots in quantities indicated in door hardware schedule, but not fewer than one intermediate offset pivot per door and one additional intermediate offset pivot for every **30 inches (760 mm)** of door height greater than **90 inches (2286 mm)**.
- E. Lock Cylinders: Install construction cores to secure building and areas during construction period.
 - 1. Replace construction cores with permanent cores as indicated in keying schedule.
- F. Key Control System:
 - 1. Key Lock Boxes: Install where indicated or approved by Architect to provide controlled access for fire and medical emergency personnel.
- G. Boxed Power Supplies: Locate power supplies as indicated or, if not indicated, above accessible ceilings AND/OR in equipment room. Verify location with Architect.
- H. Thresholds: Set thresholds for exterior doors and other doors indicated in full bed of sealant complying with requirements specified in Section 079200 "Joint Sealants."
- I. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they will impede traffic.
- J. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.
 - 1. Do not notch perimeter gasketing to install other surface-applied hardware.
- K. Meeting Stile Gasketing: Fasten to meeting stiles, forming seal when doors are closed.
- L. Door Bottoms: Apply to bottom of door, forming seal with threshold when door is closed.

SECTION 087100
DOOR HARDWARE

1.42 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.
 - 1. Door Closers: Adjust sweep period to comply with accessibility requirements and requirements of authorities having jurisdiction.
 - 2. Spring Hinges: Adjust to achieve positive latching when door is allowed to close freely from an open position of 70 degrees and so that closing time complies with accessibility requirements of authorities having jurisdiction.
 - 3. Electric Strikes: Adjust horizontal and vertical alignment of keeper to properly engage lock bolt.

1.43 CLEANING AND PROTECTION

- A. Clean adjacent surfaces soiled by door hardware installation.
- B. Clean operating items as necessary to restore proper function and finish.
- C. Provide final protection and maintain conditions that ensure that door hardware is without damage or deterioration at time of Substantial Completion.

1.44 MAINTENANCE SERVICE

- A. Maintenance Tools and Instructions: Furnish a complete set of specialized tools and maintenance instructions for Owner's continued adjustment, maintenance, and removal and replacement of door hardware.

1.45 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain door hardware.

1.46 DOOR HARDWARE SCHEDULE

ATTACHED IN FOLLOWING PAGES

SECTION 087100 DOOR HARDWARE

ROSELLE PUBLIC LIBRARY DISTRICT - DOOR HARDWARE SCHEDULE					
SET	HARDWARE TYPE	MANUFACTURER - PRODUCT	QTY.	FINISH	NOTES
1.1	CYLINDER / CORE	SCHLAGE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	
SLIDING AUTO EXTR ENTR					COORDINATE W/ SLIDING AUTO ENTRANCE MFR.
1.2	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
CURTAINWALL	MORTISE LOCKSET	SCHLAGE - L9077, 18 LEVEL, L ESCUTCHEON - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	CLASSROOM SECURITY W/ HOLDBACK FUNCTION
EXTR ENTR	ELECTRIC STRIKE	VON DUPRIN - 6200 SERIES	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
SINGLE DOOR	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	GASKETING / SWEEP	PEMCO / NGP / ZERO - WEATHER GASKETING & SWEEP	--	BLACK	THRESHOLD PROVIDED BY CURTAINWALL ENTRANCE MFR.
CARD READER	DOOR ACCESS	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
	CONTROL DEVICES				COORDINATE W/ CURTAINWALL ENTRANCE MFR.
1.3	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
CURTAINWALL	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	
EXTR EGRESS	PANIC HARDWARE	VON DUPRIN - 35A MORTISE DEVICE, CONCEALED VERTICAL RODS, 18 LEVER, L ESCUTCHEON, HARDWIRED ALARM KIT W/ POWER SUPPLY - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	PANIC / CLASSROOM FUNCTION
SINGLE DOOR					
	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	GASKETING / SWEEP	PEMCO / NGP / ZERO - WEATHER GASKETING & SWEEP	--	BLACK	THRESHOLD PROVIDED BY CURTAINWALL ENTRANCE MFR.
					COORDINATE W/ CURTAINWALL ENTRANCE MFR.
1.4	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
FIRE-RATED GL	PANIC HARDWARE	VON DUPRIN - 35A MORTISE DEVICE, CONCEALED VERTICAL RODS, 18 LEVER, L ESCUTCHEON	1	613 (OIL RUBBED BRONZE)	PANIC / PASSAGE FUNCTION
INTR EGRESS					
SINGLE DOOR	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	MAG. DOOR HOLDER	SENTRONIC - SEM 7800 SERIES	1	691 (LIGHT BRONZE)	COORDINATE W/ FIRE ALARM SYSTEM
	SILENCERS	IVES - SILENCER SI6X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
					COORDINATE W/ FIRE-RATED GLASS ENTRANCE MFR.
1.5	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
CURTAINWALL	MORTISE LOCKSET	SCHLAGE - L9077, 18 LEVEL, L ESCUTCHEON - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	CLASSROOM SECURITY W/ HOLDBACK FUNCTION
BALCONY	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
EXTR ENTR	GASKETING / SWEEP	PEMCO / NGP / ZERO - WEATHER GASKETING & SWEEP	--	BLACK	THRESHOLD PROVIDED BY CURTAINWALL ENTRANCE MFR.
SINGLE DOOR					COORDINATE W/ CURTAINWALL ENTRANCE MFR.
2.1	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
HM DOOR/FRM	MORTISE LOCKSET	SCHLAGE - L9070, 18 LEVEL, L ESCUTCHEON - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	CLASSROOM FUNCTION
EXTR ENTR	ELECTRIC STRIKE	VON DUPRIN - 6200 SERIES	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
SINGLE DOOR	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	GASKETING / SWEEP	PEMCO / NGP / ZERO - WEATHER GASKETING & SWEEP	--	BLACK	
	THRESHOLD	PEMCO / NGP / ZERO - EXTR. THRESHOLD	--		
CARD READER	DOOR ACCESS	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
	CONTROL DEVICES				
2.2	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	5	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
HM DOOR/FRM	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
EXTR ENTR	MORTISE LOCKSET	SCHLAGE - L9070, 18 LEVEL, L ESCUTCHEON - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	CLASSROOM FUNCTION
DBL DOORS	ELECTRIC STRIKE	VON DUPRIN - 6200 SERIES	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	FLUSH BOLT	IVES - FB45X	2	613 (OIL RUBBED BRONZE)	TOP & BOTTOM
	GASKETING / SWEEP	PEMCO / NGP / ZERO - WEATHER GASKETING & SWEEP	--	BLACK	THRESHOLD PROVIDED BY CURTAINWALL ENTRANCE MFR.
	THRESHOLD	PEMCO / NGP / ZERO - EXTR. THRESHOLD	--		
CARD READER	DOOR ACCESS	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
	CONTROL DEVICES				
2.3	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
HM DOOR/FRM	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
EXTR EGRESS	PANIC HARDWARE	VON DUPRIN - 35A MORTISE DEVICE, CONCEALED VERTICAL RODS, 18 LEVER, L ESCUTCHEON, HARDWIRED ALARM KIT W/ POWER SUPPLY - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	PANIC / CLASSROOM FUNCTION
SINGLE DOOR					
	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	GASKETING / SWEEP	PEMCO / NGP / ZERO - WEATHER GASKETING & SWEEP	--	BLACK	THRESHOLD PROVIDED BY CURTAINWALL ENTRANCE MFR.
	THRESHOLD	PEMCO / NGP / ZERO - EXTR. THRESHOLD	--		
2.4	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
HM DOOR/FRM	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
INTR EGRESS	PANIC HARDWARE	VON DUPRIN - 35A MORTISE DEVICE, CONCEALED VERTICAL RODS, QUIET ELECTRIC LATCH RETRACTION, 18 LEVER, L ESCUTCHEON, HARDWIRED ALARM KIT W/ POWER SUPPLY - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	PANIC / CLASSROOM FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
SINGLE DOOR					
	SURFACE CLOSER	LCN - 4040XP - EDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM, METAL COVER
	SILENCERS	IVES - SILENCER SI6X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
CARD READER	DOOR ACCESS	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
	CONTROL DEVICES				
3.1	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
OFFICE	MORTISE LOCKSET	SCHLAGE - L9056, 18 LEVER, A ROSE, 10-072 STRIKE, ADA THUMBTURN - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	OFFICE FUNCTION W/ AUTO UNLOCKING
SINGLE DOOR					
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	MORTISE AUTO.	NGP - 225S	1	MILL ALUM / BLACK	
	DOOR BOTTOM				
	SILENCERS	IVES - SILENCER SI6X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
3.2	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
CONFERENCE	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
SINGLE DOOR	MORTISE LOCKSET	SCHLAGE - L9092EU, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	MORTISE AUTO.	NGP - 225S	1	MILL ALUM / BLACK	
	DOOR BOTTOM				
	SILENCERS	IVES - SILENCER SI6X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
CARD READER	DOOR ACCESS	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
	CONTROL DEVICES				

SECTION 087100 DOOR HARDWARE

ROSELLE PUBLIC LIBRARY DISTRICT - DOOR HARDWARE SCHEDULE					
SET	HARDWARE TYPE	MANUFACTURER - PRODUCT	QTY.	FINISH	NOTES
3.3 WORKROOM SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
3.4 WORKROOM W/ AUTO-OP SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	AUTO OPERATOR	ASSA ABLOY - SW100	1	691 (LIGHT BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
3.5 RECEIVING W/ AUTO-OP DBL DOORS	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	5	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	AUTO OPERATOR	ASSA ABLOY - SW100	1	691 (LIGHT BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	FLUSH BOLT	IVES - FB45X	2	613 (OIL RUBBED BRONZE)	TOP & BOTTOM
	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	PROTECTION PLATE	IVES - 8400 KICK PLATE	4	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
4.1 STORAGE SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	MORTISE LOCKSET	SCHLAGE - L9081, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	STOREROOM FUNCTION
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
4.2 JANITOR SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	MORTISE LOCKSET	SCHLAGE - L9081, 818 LEVER (MILLED TACTILE WARNING), A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	STOREROOM FUNCTION
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	PROTECTION PLATE	IVES - 8400 MOP PLATE	1	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
4.3 UTILITIES SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	MORTISE LOCKSET	SCHLAGE - L9081, 818 LEVER (MILLED TACTILE WARNING), A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	STOREROOM FUNCTION
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	PROTECTION PLATE	IVES - 8400 KICK & MOP PLATE	2	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
4.4 SINGLE DOOR SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 818 LEVER (MILLED TACTILE WARNING), A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
4.5 SINGLE DOOR DBL DOORS	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	5	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	FLUSH BOLT	IVES - FB45X	2	613 (OIL RUBBED BRONZE)	TOP & BOTTOM
	FLOOR STOP	ROCKWOOD - 446	2	613 (OIL RUBBED BRONZE)	
	PROTECTION PLATE	IVES - 8400 KICK PLATE	4	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
4.6 SINGLE DOOR DBL DOORS	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	5	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	HW MORTISE HINGE	IVES - 5BB1HW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 818 LEVER (MILLED TACTILE WARNING), A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	FLUSH BOLT	IVES - FB45X	2	613 (OIL RUBBED BRONZE)	TOP & BOTTOM
	FLOOR STOP	ROCKWOOD - 446	2	613 (OIL RUBBED BRONZE)	
	PROTECTION PLATE	IVES - 8400 KICK PLATE	4	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
4.7 STORAGE DBL DOORS	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	6	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	MORTISE LOCKSET	SCHLAGE - L9081, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	STOREROOM FUNCTION
	SURFACE CLOSER	LCN - 4040XP - HEDA ARM - METAL COVER	1	691 (LIGHT BRONZE)	EXTRA DUTY ARM W/ HOLD OPEN, METAL COVER
	FLUSH BOLT	IVES - FB45X	2	613 (OIL RUBBED BRONZE)	TOP & BOTTOM
	FLOOR STOP	ROCKWOOD - 446	2	613 (OIL RUBBED BRONZE)	
	PROTECTION PLATE	IVES - 8400 KICK PLATE	4	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES

SECTION 087100 DOOR HARDWARE

ROSELLE PUBLIC LIBRARY DISTRICT - DOOR HARDWARE SCHEDULE					
SET	HARDWARE TYPE	MANUFACTURER - PRODUCT	QTY.	FINISH	NOTES
5.1 STUDY ROOM SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	2	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	BW MORTISE HINGE	IVES - 5BBIHW 4.5" x 4.5"	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	MORTISE LOCKSET ELEC. UNLOCKING	SCHLAGE - L9092EU, 18 LEVER, A ROSE, 10-072 STRIKE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	ELECTRIC UNLOCKING FUNCTION; COORDINATE W/ OWNER'S SECURITY VENDOR
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
CARD READER	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
					PROVIDE FLOOR STOP @ DOOR 223
6.1 STUDY ROOM DEMOUNTABLE GL ENTRANCE SINGLE DOOR	PIVOT HINGE	ALUR - 3/4" OFFSET PIVOT HINGES	2	613 (OIL RUBBED BRONZE)	PROVIDED BY ALUR
	GLASS PATCH MORTISE LOCKSET	ALUR - ND70 GLASS PATCH CYLINDRICAL LOCKSET, 19L LEVER (COORDINATE CORE W/ OTHER TRADES)	1	613 (OIL RUBBED BRONZE)	CLASSROOM FUNCTION; PROVIDED BY ALUR (COORDINATE KEYING/CORE W/ OTHER TRADES)
	CYLINDER / CORE	SCHLAGE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ ALUR
	ELECTRIC STRIKE	TRINE 3000 SERIES	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ ALUR & OWNER'S SECURITY VENDOR
	OH CLOSER	ALUR - CONCEALED OVERHEAD CLOSER W/ 90DEG. H.O.	1	613 (OIL RUBBED BRONZE)	PROVIDED BY ALUR
CARD READER	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
	DOOR ACCESS CTRL	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
6.2 TEEN DEMOUNTABLE GL ENTRANCE SINGLE DOOR	PIVOT HINGE	ALUR - 3/4" OFFSET PIVOT HINGES	2	613 (OIL RUBBED BRONZE)	PROVIDED BY ALUR
	GLASS PATCH MORTISE LOCKSET	ALUR - ND70 GLASS PATCH CYLINDRICAL LOCKSET, 19L LEVER (COORDINATE CORE W/ OTHER TRADES)	1	613 (OIL RUBBED BRONZE)	PROVIDED BY ALUR
	CYLINDER / CORE	SCHLAGE - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ ALUR
	OH CLOSER	ALUR - CONCEALED OVERHEAD CLOSER W/ 90DEG. H.O.	1	613 (OIL RUBBED BRONZE)	PROVIDED BY ALUR
	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
7.1 MAKERSPACE ALL-GLASS ENTRANCE SINGLE DOOR	PIVOT HINGE	CRL - CLEAR VIEW PIVOT HINGE	2	613 (OIL RUBBED BRONZE)	
	HANDLE SET	BLUMCRAFT - GLASS-MOUNT HANDLES DB100 W/ KEYED CYLINDER - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	FULL HEIGHT 'F' STYLE
	OH CLOSER	CRL - CONCEALED OVERHEAD CLOSER	1	613 (OIL RUBBED BRONZE)	
	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
					COORDINATE W/ ALL-GLASS ENTRANCE MFR.
7.2 PROGRAM RM ALL-GLASS ENTRANCE DBL DOORS	PIVOT HINGE	CRL - CLEAR VIEW PIVOT HINGE	4	613 (OIL RUBBED BRONZE)	
	HANDLE SET	BLUMCRAFT - GLASS-MOUNT HANDLES DB100 W/ KEYED CYLINDER - FSIC PRIMUS	2	613 (OIL RUBBED BRONZE)	FULL HEIGHT 'F' STYLE
	OH CLOSER	CRL - CONCEALED OVERHEAD CLOSER	2	613 (OIL RUBBED BRONZE)	
	FLOOR STOP	ROCKWOOD - 446	2	613 (OIL RUBBED BRONZE)	
					COORDINATE W/ ALL-GLASS ENTRANCE MFR.
7.3 STUDY ROOM ALL-GLASS ENTRANCE SINGLE DOOR	PIVOT HINGE	CRL - CLEAR VIEW PIVOT HINGE	2	613 (OIL RUBBED BRONZE)	
	HANDLE SET	BLUMCRAFT - GLASS-MOUNT HANDLES DB100 W/ KEYED CYLINDER - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	FULL HEIGHT 'F' STYLE
	OH CLOSER	CRL - CONCEALED OVERHEAD CLOSER	1	613 (OIL RUBBED BRONZE)	
	ELECTRIC STRIKE	VON DUPRIN - 6200 SERIES	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ OWNER'S SECURITY VENDOR
	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
CARD READER	DOOR ACCESS CONTROL DEVICES	CARD READER / DPS / POWER SUPPLY / ETC (BY OTHERS)	--		PREP/ROUGH-IN DOORS & FRAMES FOR DEVICES TO BE PROVIDED & INSTALLED BY OWNER'S SECURITY VENDOR
					COORDINATE W/ ALL-GLASS ENTRANCE MFR.
7.4 YOUTH ENTR ALL-GLASS ENTRANCE DBL DOORS	PIVOT HINGE	CRL - CLEAR VIEW PIVOT HINGE	4	613 (OIL RUBBED BRONZE)	
	HANDLE SET	CRL - GLASS-MOUNT FULL-HEIGHT LADDER PULLS	2	613 (OIL RUBBED BRONZE)	FULL HEIGHT 'F' STYLE
	FLOOR OPERATOR IN-GROUND	ASSA ABLOY - SW200-IG IN-GROUND SWING DOOR OPERATOR W/ WAVE TO OPEN ACUATORS	2	691 (LIGHT BRONZE)	
	FLOOR STOP	ROCKWOOD - 446	2	613 (OIL RUBBED BRONZE)	
					COORDINATE W/ ALL-GLASS ENTRANCE MFR.
7.5 MTG / EGRESS ALL-GLASS ENTRANCE SINGLE DOOR	PIVOT HINGE	CRL - CLEAR VIEW PIVOT HINGE	2	613 (OIL RUBBED BRONZE)	
	PANIC HARDWARE	BLUMCRAFT - GLASS-MOUNT PANIC DEVICE PA100 W/ KEYED CYLINDER - FSIC PRIMUS	1	613 (OIL RUBBED BRONZE)	FULL HEIGHT 'F' STYLE
	OH CLOSER	CRL - CONCEALED OVERHEAD CLOSER	1	613 (OIL RUBBED BRONZE)	
	FLOOR STOP	ROCKWOOD - 446	1	613 (OIL RUBBED BRONZE)	
					COORDINATE W/ ALL-GLASS ENTRANCE MFR.
7.6 MTG / EGRESS ALL-GLASS ENTRANCE DBL DOORS	PIVOT HINGE	CRL - CLEAR VIEW PIVOT HINGE	4	613 (OIL RUBBED BRONZE)	
	PANIC HARDWARE	BLUMCRAFT - GLASS-MOUNT PANIC DEVICE PA100 W/ KEYED CYLINDER - FSIC PRIMUS	2	613 (OIL RUBBED BRONZE)	FULL HEIGHT 'F' STYLE
	OH CLOSER	CRL - CONCEALED OVERHEAD CLOSER	2	613 (OIL RUBBED BRONZE)	
	FLOOR STOP	ROCKWOOD - 446	2	613 (OIL RUBBED BRONZE)	
					COORDINATE W/ ALL-GLASS ENTRANCE MFR.
8.1 SINGLE-USER RESTROOM SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	MORTISE LOCKSET	SCHLAGE - L9444, 18 LEVER, L ESCUTCHEON, 10-072 STRIKE	1	613 (OIL RUBBED BRONZE)	PRIVACY FUNCTION ("OCCUPIED") W/ DEADBOLT & COIN TURN
	DEADBOLT MONITOR	SCHLAGE - DEADBOLT MONITOR	1		COORDINATE W/ LOCKSET, ELECTRIC STRIKE & AUTO OPERATOR
	AUTO OPERATOR	ASSA ABLOY - SW100 W/ WAVE TO OPEN ACUATORS	1	691 (LIGHT BRONZE)	COORDINATE W/ DEADBOLT MONITOR & ELECTRIC STRIKE
	ELECTRIC STRIKE	VON DUPRIN - 6200 SERIES	1	613 (OIL RUBBED BRONZE)	COORDINATE W/ DEADBOLT MONITOR & AUTO OPERATOR
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	PROTECTION PLATE	IVES - 8400 KICK & MOP PLATE	2	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
8.2 MULTI-USER RESTROOM SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	OFFSET PULL	IVES - 9264-72-56-FLAT TIP	2	613 (OIL RUBBED BRONZE)	72" LENGTH
	AUTO OPERATOR	ASSA ABLOY - SW100 W/ WAVE TO OPEN ACUATORS	1	691 (LIGHT BRONZE)	
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	PROTECTION PLATE	IVES - 8400 KICK & MOP PLATE	2	613 (OIL RUBBED BRONZE)	
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES
8.3 WELLNESS SINGLE DOOR	MORTISE HINGE	IVES - 5BB1 4.5" x 4.5"	3	613 (OIL RUBBED BRONZE)	FULL MORTISE, FIVE KNUCKLE BB HINGE
	MORTISE LOCKSET	SCHLAGE - L9444, 18 LEVER, L ESCUTCHEON, 10-072 STRIKE	1	613 (OIL RUBBED BRONZE)	PRIVACY FUNCTION ("OCCUPIED") W/ DEADBOLT & COIN TURN
	WALL STOP	IVES - WS401/402CCV	1	613 (OIL RUBBED BRONZE)	SEE PLANS FOR WALL CONSTRUCTION
	SILENCERS	IVES - SILENCER S16X	--	BLACK	CONTRACTOR TO CONFIRM QUANTITIES

END OF SECTION 087100