

- D. Push Plates and Door Pulls: When through-bolt fasteners are in the same location as a push plate, countersink the fasteners flush with the door face allowing the push plate to sit flat against the door.
- E. Thresholds: Set thresholds for exterior and acoustical doors in full bed of sealant complying with requirements specified in Division 7 Section "Joint Sealants."
- F. Storage: Provide a secure lock up for hardware delivered to the project but not yet installed. Control the handling and installation of hardware items so that the completion of the work will not be delayed by hardware losses before and after installation.

3.4 FIELD QUALITY CONTROL

- A. Field Inspection (Punch Report): Reference Division 01 Sections "Closeout Procedures". Produce project punch report for each installed door opening indicating compliance with approved submittals and verification hardware is properly installed, operating and adjusted. Include list of items to be completed and corrected, indicating the reasons or deficiencies causing the Work to be incomplete or rejected.
 - 1. Organization of List: Include separate Door Opening and Deficiencies and Corrective Action Lists organized by Mark, Opening Remarks and Comments, and related Opening Images and Video Recordings.

3.5 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.

3.6 CLEANING AND PROTECTION

- A. Protect all hardware stored on construction site in a covered and dry place. Protect exposed hardware installed on doors during the construction phase. Install any and all hardware at the latest possible time frame.
- B. Clean adjacent surfaces soiled by door hardware installation.
- C. Clean operating items as necessary to restore proper finish. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of owner occupancy.

3.7 DEMONSTRATION

- A. Instruct Owner's maintenance personnel to adjust, operate, and maintain mechanical and electromechanical door hardware.

3.8 DOOR HARDWARE SETS

- A. The hardware sets represent the design intent and direction of the owner and architect. They are a guideline only and should not be considered a detailed hardware schedule. Discrepancies, conflicting hardware and missing items should be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application and functionality.
1. Quantities listed are for each pair of doors, or for each single door.
 2. The supplier is responsible for handing and sizing all products.
 3. Where multiple options for a piece of hardware are given in a single line item, the supplier shall provide the appropriate application for the opening.

B. Manufacturer's Abbreviations:

- | | | |
|----|------|----------------------------------|
| 1. | AD | Adams Rite |
| 2. | BE | BEST (Construction cores & keys) |
| 3. | HS | HES |
| 4. | MC | McKinney |
| 5. | MED1 | Medeco |
| 6. | PE | Pemko |
| 7. | RO | Rockwood |
| 8. | SA | Sargent |
| 9. | VA01 | Various MFG (Key cabinet) |

C. Hardware Options/Codes:

Code	Description
1 3/4" DOORS	1-3/4" Thick Doors
13-0512	ADAMS RITE CAM (AR1850) STD CYLS
2 3/4" BS	2 3/4" BACKSET
2" Doors	2" Thick Doors
2004M	Electrolynx Adaptor
31	FOR DOORS UP TO 2 1/4"
70	Small Format Construction Plastic Core
7P	7 Pin
CTC	CENTER TO CENTER MOUNTING MEASUREMENT
Door Height	Door Height in Inches (Specify)
LC	LESS CYLINDER-SINGLE (RIM/MORTISE)
MSES25SS	SS/MS&ES25 (for 36")
MSES25SS	SS/MS&ES25 (for 48")
MSES25SS	SS/MS&ES25 (for 72")
OVERALL LENGTH	OVERALL MEASUREMENT
SRI	RUST INHIBITOR PAINT-ARMS & BODY
Straight Bolt	Straight Bolt
TB	MS and Mortise Nuts for Closers
TYPE 12XHD FASTENING	DECORATIVE HD TB MOUNTING (3/8-16)
V21	Ind Both Sds Lckd/Unlckd x Vcnt/Occ, G/R

D. Hardware Finish List

Code	Description
10BE	Dark Oxidized Satin Bronze – Equivalent
313	Dark Bronze Duranodic
613E	Dark Oxidized Satin Bronze – Equivalent
630	Satin Stainless Steel (placeholder for 5000 electric strike)
BLK	Black
EB	Sprayed Finish, To Match 10B

All exposed hardware, fasteners, etc. shall be 10BE as the BOD finish color. If 10BE is not an option, submit an alternative finish for the design team to review and approve.

E. Hardware Sets:

Set #101

- 1 Pair Doors **#101** Vesitbule 103 to/from Exteri- 105° RHRA
or

Opening Description: 2 - 3' 0" x 8' 0" Type AL-NA-D8 Type AL-NA x N/A

2	Continuous Hinge	K10BEFM95HD1		PE
1	Deadlock	MS1850S Door Height Straight Bolt	313	AD
	Properties: Door Height=96			
1	Thumbturn Cylinder	4066-01	313	AD
1	Mortise Cylinder	70 7P 43 13-0512	10BE	SA
	Note: - SFIC Cylinder housing with disposable core			
1	Construction Core	7190224		BE
	Note: - SFIC Construction core			
2	Pull	RM3301 35" 2" Doors CTC OVERALL LENGTH	10BE	RO
	Note: - Push bar dimensions shall be coordinated with Aluminum Door provider & approved by the deisgn team during submittal phase			
	Properties: CTC = =33, Overall Length=35			
2	Pull	RM3310 30" 2" Doors CTC OVERALL LENGTH	10BE	RO
	Note: - Verify door thickness			
1	Closer	SRI 268 OB	RH 10BE	SA
1	Closer	SRI 268 OB	LH 10BE	SA
1	SFIC	33700006 N 26 DAKM		MED1
	Note: - Product shall be US10B (or 10BE if available) finish per catalog selections			
	- End user needs to confirm master key system & keyway prior procurement			
1	Threshold	2008-10BE-PK 72" MSES25SS		PE
	Note: 1. Integrated Seals (door bottoms, astragals, etc) by Aluminum Door/Frames Provider			
	2. Closer drop plates and spacers are not specified in the hardware sets. Aluminum provider shall coordinate if they are required to complete their division.			
	3. Aluminum Opening Hardware finish color shall be determined by the Architect at a later time			

Set #103

1 Pair Doors #103

Vestibule 103 to/from Bank- 105° RHRA
ing Personal 106

Opening Description: 2 - 3' 0" x 8' 0" Type AL-NA-D8 Type AL-NA x N/A

2	Continuous Hinge	K10BEFM95HD1		PE
1	Deadlock	MS1850S Door Height Straight Bolt	313	AD
	Properties: Door Height=96			
1	Thumbturn Cylinder	4066-01	313	AD
1	Mortise Cylinder	70 7P 43 13-0512	10BE	SA
	Note: - SFIC Cylinder housing with disposable core			
1	Construction Core	7190224		BE
	Note: - SFIC Construction core			
2	Pull	RM3301 35" 2" Doors CTC OVERALL LENGTH	10BE	RO
	Note: - Push bar dimensions shall be coordinated with Aluminum Door provider & approved by the design team during submittal phase			
	Properties: CTC = 33, Overall Length=35			
2	Pull	RM3310 30" 2" Doors CTC OVERALL LENGTH	10BE	RO
	Note: - Verify door thickness			
1	Closer	SRI 268 OB	RH 10BE	SA
1	Closer	SRI 268 OB	LH 10BE	SA
2	Dome Stop	441	10BE	RO
1	SFIC	33700006 N 26 DAKM		MED1
	Note: - Product shall be US10B (or 10BE if available) finish per catalog selections			
	- End user needs to confirm master key system & keyway prior procurement			
	Note: 1. Integrated Seals (door bottoms, astragals, etc) by Aluminum Door/Frames Provider			
	2.			
	3.			
	4. Closer drop plates and spacers are not specified in the hardware sets. Aluminum provider shall coordinate if they are required to complete their division.			

Set #104

1 Single Door #104

Banking Personal 106 to/from 105° RH
Office 104

Opening Description: 3' 0" x 8' 0" x 1 3/4" x WD Type WD-NA-D3 x HMF Type HM-NA-F1 x
N/A

4 Hinges	MPB79 4 1/2 x 4 1/2 NRP	10BE	MC
1 Lockset	70 10XG05 LL 2 3/4" BS	10BE	SA
1 Construction Core	7190224		BE
Note: - SFIC Construction core			
1 Wall Stop	409	10BE	RO
1 SFIC	33700006 N 26 DAKM		MED1
Note: - Product shall be US10B (or 10BE if available) finish per catalog selections			
- End user needs to confirm master key system & keyway prior procurement			
3 Door Silencer	608-RKW	BLK	RO