

Sustained Interruption
Events, January 2025 -
August 2026

Sedgewater Energy Holdings

Effective date	2026-09-09
Purpose	Provide event-level sustained interruptions with 25.52 fields for 2025 and 2026 to date.
Coverage	See each dataset dictionary and summary. Missing numeric values are excluded, not zero.
Summary interpretation	Descriptive statistics of selected records only. Totals of percentages and adjustment values are not operating KPIs.
Introduction	Workbook of sustained interruption events from January 2025 to August 2026, extracted from the outage management system on September 9, 2026 by Reliability Engineering. Each row is one sustained interruption at transformer-fuse level or above.
Sheets	Data 1 - 2025 events (January to December).
Sheets	Data 2 - 2026 events (January to August).
Sheets	Summary - formula totals of each numeric column; totals include every class, including major events.
Classification	Every event is classified as forced, planned, outside cause or major event. Planned interruptions have at least 24 hours' notice; outside-cause interruptions start on the transmission grid or at a customer facility; momentary interruptions of five minutes or less are not in the extract. Headline indices under the Reliability Metric Definitions and Calculation Standard use forced events only and the average of monthly delivery points.
Classification	Records carry type, cause, date and start hour, duration, customers interrupted and feeder identifiers, as the interruption record rule requires.
Headline results	2025, excluding major events: SAIDI 118.0 minutes, SAIFI 1.210, CAIDI 97.5 minutes from 4,560 forced interruptions. January to August 2026: SAIDI 84.0 minutes and SAIFI 0.830, against 83.3 minutes and 0.850 for January to August 2025.
Major events	June 11-13, 2025: 355 interruptions, 104,000 customers, 126.4 million customer minutes. May 19-22, 2026: 463 interruptions, 132,152 customers, 116.6 million customer minutes. Both met the major-event test and are flagged in the major event column.
Causes	In 2025, vegetation caused 26% of forced customer minutes, overhead equipment 22%, underground equipment 16%, lightning 10%, animals 10%, wind 9%, vehicles or public 4% and unknown 3%.
Data notes	Cause is coded Unknown for about 4% of events; crews are asked to update it when the repair is closed. Customer minutes equal customers interrupted multiplied by duration for every row.

Dataset	Measure	Unit	Total	Mean	Records	Period start	Period end
Sustained interruption events, customer_minutes 2025 (Jan-Dec)		customer-minutes				2025-01-01	2025-12-31
			211,922,230.00	40,220.58	5269	2025-01-01	2025-12-31
Sustained interruption events, customers_interrupted 2025 (Jan-Dec)		customers					
			994,701.00	188.78	5269	2025-01-01	2025-12-31
Sustained interruption events, duration_minutes 2025 (Jan-Dec)		minutes					
			1,045,435.00	198.41	5269	2026-01-01	2026-08-31
Sustained interruption events, customer_minutes 2026 (Jan-Aug)		customer-minutes					
			177,538,997.00	46,488.35	3819	2026-01-01	2026-08-31
Sustained interruption events, customers_interrupted 2026 (Jan-Aug)		customers					
			743,270.00	194.62	3819	2026-01-01	2026-08-31
Sustained interruption events, duration_minutes 2026 (Jan-Aug)		minutes					
			820,040.00	214.73	3819		

Dataset	Field	Definition	Unit	Type	Reference
Sustained interruption events, 2025 (Jan-Dec)	event_id	OE-25-000001		id	
Sustained interruption events, 2025 (Jan-Dec)	customer_minutes	Customer minutes interrupted (derived)	customer-minutes	number	
Sustained interruption events, 2025 (Jan-Dec)	customers_interrupted	Customers interrupted	customers	integer	
Sustained interruption events, 2025 (Jan-Dec)	duration_minutes	Duration to restoration	minutes	integer	
Sustained interruption events, 2025 (Jan-Dec)	feeder_code	Feeder (FK)		category	
Sustained interruption events, 2025 (Jan-Dec)	district	District (copied)		category	
Sustained interruption events, 2025 (Jan-Dec)	start_date	Start date		date	
Sustained interruption events, 2025 (Jan-Dec)	start_hour	Start hour (local)	hour	category	
Sustained interruption events, 2025 (Jan-Dec)	cause	Cause code		category	
Sustained interruption events, 2025 (Jan-Dec)	device	Interrupting device		category	
Sustained interruption events, 2025 (Jan-Dec)	classification	25.52 classification		category	
Sustained interruption events, 2025 (Jan-Dec)	major_event	Major event label		category	
Sustained interruption events, 2026 (Jan-Aug)	event_id	OE-26-000001		id	
Sustained interruption events, 2026 (Jan-Aug)	customer_minutes	Customer minutes interrupted (derived)	customer-minutes	number	
Sustained interruption events, 2026 (Jan-Aug)	customers_interrupted	Customers interrupted	customers	integer	
Sustained interruption events, 2026 (Jan-Aug)	duration_minutes	Duration to restoration	minutes	integer	
Sustained interruption events, 2026 (Jan-Aug)	feeder_code	Feeder (FK)		category	
Sustained interruption events, 2026 (Jan-Aug)	district	District (copied)		category	
Sustained interruption events, 2026 (Jan-Aug)	start_date	Start date		date	
Sustained interruption events, 2026 (Jan-Aug)	start_hour	Start hour (local)	hour	category	
Sustained interruption events, 2026 (Jan-Aug)	cause	Cause code		category	

Sustained interruption events, device 2026 (Jan-Aug)	Interrupting device	category
Sustained interruption events, classification 2026 (Jan-Aug)	25.52 classification	category
Sustained interruption events, major_event 2026 (Jan-Aug)	Major event label	category

event_id	customer_minutes	customers_interrupted	duration_minutes	feeder_code	district	start_date	start_hour	cause	device	classification	major_event
OE-25-000001		4750	50	95 CR-S27-02	Crossroads	2025-01-01		5 Vegetation	Lateral fuse	Forced	None
OE-25-000002		2070	23	90 BY-S11-02	Bayou	2025-01-01		6 Equipment - overhead	Lateral fuse	Forced	None
OE-25-000003		1305	9	145 BY-S03-01	Bayou	2025-01-01		8 Animal	Transformer fuse	Forced	None
OE-25-000004		4104	36	114 CR-S23-01	Crossroads	2025-01-01		8 Weather - wind	Lateral fuse	Forced	None
OE-25-000005		690	3	230 BY-S05-01	Bayou	2025-01-01		13 Equipment - underground	Transformer fuse	Forced	None
OE-25-000006		2464	14	176 BY-S16-05	Bayou	2025-01-02		8 Equipment - underground	Transformer fuse	Forced	None
OE-25-000007		4071	59	69 BY-S21-04	Bayou	2025-01-02		8 Equipment - underground	Lateral fuse	Forced	None
OE-25-000008		19516	82	238 BY-S13-02	Bayou	2025-01-02		9 Weather - wind	Lateral fuse	Forced	None
OE-25-000009		5712	56	102 CR-S18-06	Crossroads	2025-01-02		9 Equipment - overhead	Lateral fuse	Forced	None
OE-25-000010		1530	17	90 CR-S31-02	Crossroads	2025-01-02		13 Equipment - underground	Lateral fuse	Forced	None
OE-25-000011		1815	11	165 BY-S27-06	Bayou	2025-01-02		14 Equipment - overhead	Transformer fuse	Forced	None
OE-25-000012		30393	99	307 CR-S07-03	Crossroads	2025-01-02		14 Equipment - underground	Lateral fuse	Forced	None
OE-25-000013		2044	14	146 PR-S16-05	Prairie	2025-01-02		14 Equipment - overhead	Transformer fuse	Forced	None
OE-25-000014		9125	125	73 BY-S03-03	Bayou	2025-01-02		15 Unknown	Lateral fuse	Forced	None
OE-25-000015		5590	130	43 BY-S29-03	Bayou	2025-01-02		18 Unknown	Lateral fuse	Forced	None
OE-25-000016		530	5	106 HB-S15-03	Harbor	2025-01-02		20 Vegetation	Transformer fuse	Forced	None
OE-25-000017		696	12	58 HB-S02-01	Harbor	2025-01-02		23 Unknown	Lateral fuse	Forced	None
OE-25-000018		1232	7	176 PR-S05-03	Prairie	2025-01-03		7 Equipment - overhead	Transformer fuse	Forced	None
OE-25-000019		11050	50	221 CR-S15-03	Crossroads	2025-01-03		10 Scheduled	Lateral fuse	Scheduled	None
OE-25-000020		10836	63	172 PR-S13-03	Prairie	2025-01-03		10 Scheduled	Lateral fuse	Scheduled	None
OE-25-000021		32800	164	200 BY-S05-02	Bayou	2025-01-03		11 Equipment - underground	Lateral fuse	Forced	None
OE-25-000022		17152	128	134 CR-S07-05	Crossroads	2025-01-03		15 Equipment - overhead	Lateral fuse	Forced	None
OE-25-000023		1495	13	115 CR-S19-03	Crossroads	2025-01-03		15 Equipment - overhead	Transformer fuse	Forced	None
OE-25-000024		13536	72	188 PR-S14-01	Prairie	2025-01-03		15 Vegetation	Lateral fuse	Forced	None
OE-25-000025		1690	10	169 HB-S14-03	Harbor	2025-01-03		18 Animal	Transformer fuse	Forced	None
OE-25-000026		510	10	51 BY-S25-05	Bayou	2025-01-03		21 Weather - wind	Transformer fuse	Forced	None
OE-25-000027		15876	126	126 BY-S07-06	Bayou	2025-01-04		0 Equipment - overhead	Lateral fuse	Forced	None
OE-25-000028		15129	123	123 CR-S13-05	Crossroads	2025-01-04		4 Equipment - underground	Lateral fuse	Forced	None
OE-25-000029		34018	73	466 PR-S20-01	Prairie	2025-01-04		5 Animal	Lateral fuse	Forced	None
OE-25-000030		2947	7	421 PR-S13-06	Prairie	2025-01-04		6 Equipment - overhead	Transformer fuse	Forced	None

event_id	customer_minutes	customers_interrupted	duration_minutes	feeder_code	district	start_date	start_hour	cause	device	classification	major_event
OE-26-000001	66334	1951	34	BY-S16-01	Bayou	2026-01-01		1 Vegetation	Feeder recloser	Forced	None
OE-26-000002	10500	125	84	CR-S04-03	Crossroads	2026-01-01		6 Equipment - overhead	Lateral fuse	Forced	None
OE-26-000003	5775	11	525	PR-S20-03	Prairie	2026-01-01		7 Equipment - overhead	Transformer fuse	Forced	None
OE-26-000004	25300	100	253	CR-S12-02	Crossroads	2026-01-01		9 Equipment - underground	Lateral fuse	Forced	None
OE-26-000005	5472	36	152	BY-S16-05	Bayou	2026-01-01		11 Scheduled	Lateral fuse	Scheduled	None
OE-26-000006	15694	118	133	CR-S29-03	Crossroads	2026-01-01		12 Scheduled	Lateral fuse	Scheduled	None
OE-26-000007	158523	997	159	PR-S17-01	Prairie	2026-01-01		12 Vegetation	Feeder recloser	Forced	None
OE-26-000008	26600	475	56	CR-S29-01	Crossroads	2026-01-01		13 Equipment - overhead	Feeder recloser	Forced	None
OE-26-000009	6960	40	174	PR-S10-03	Prairie	2026-01-01		13 Scheduled	Lateral fuse	Scheduled	None
OE-26-000010	4169	11	379	CR-S06-01	Crossroads	2026-01-01		14 Equipment - overhead	Transformer fuse	Forced	None
OE-26-000011	1845	9	205	BY-S18-04	Bayou	2026-01-01		15 Vegetation	Transformer fuse	Forced	None
OE-26-000012	1057	7	151	CR-S10-02	Crossroads	2026-01-01		15 Vegetation	Transformer fuse	Forced	None
OE-26-000013	3600	12	300	HB-S18-02	Harbor	2026-01-02		5 Equipment - underground	Transformer fuse	Forced	None
OE-26-000014	16910	178	95	CR-S19-03	Crossroads	2026-01-02		6 Equipment - underground	Lateral fuse	Forced	None
OE-26-000015	89586	1422	63	HB-S09-03	Harbor	2026-01-02		9 Weather - wind	Substation breaker	Forced	None
OE-26-000016	4296	24	179	BY-S15-03	Bayou	2026-01-02		10 Scheduled	Lateral fuse	Scheduled	None
OE-26-000017	15582	106	147	BY-S10-03	Bayou	2026-01-02		13 Equipment - overhead	Lateral fuse	Forced	None
OE-26-000018	876	4	219	BY-S25-05	Bayou	2026-01-02		16 Vegetation	Transformer fuse	Forced	None
OE-26-000019	15051	87	173	PR-S12-02	Prairie	2026-01-02		16 Vegetation	Lateral fuse	Forced	None
OE-26-000020	21120	88	240	CR-S06-02	Crossroads	2026-01-02		17 Weather - wind	Lateral fuse	Forced	None
OE-26-000021	4379	29	151	CR-S24-01	Crossroads	2026-01-02		22 Equipment - underground	Lateral fuse	Forced	None
OE-26-000022	7497	63	119	CR-S26-05	Crossroads	2026-01-03		11 Animal	Lateral fuse	Forced	None
OE-26-000023	2940	28	105	CR-S07-01	Crossroads	2026-01-03		14 Equipment - underground	Lateral fuse	Forced	None
OE-26-000024	25047	363	69	CR-S16-05	Crossroads	2026-01-03		14 Vegetation	Feeder recloser	Forced	None
OE-26-000025	127872	432	296	HB-S12-03	Harbor	2026-01-03		16 Equipment - underground	Feeder recloser	Forced	None
OE-26-000026	95358	1382	69	BY-S20-02	Bayou	2026-01-03		17 Vegetation	Substation breaker	Forced	None
OE-26-000027	5500	11	500	PR-S02-02	Prairie	2026-01-03		17 Weather - lightning	Transformer fuse	Forced	None
OE-26-000028	2940	70	42	CR-S03-02	Crossroads	2026-01-03		18 Vegetation	Lateral fuse	Forced	None
OE-26-000029	139794	3039	46	CR-S19-03	Crossroads	2026-01-03		18 Equipment - underground	Substation breaker	Forced	None
OE-26-000030	9180	102	90	HB-S17-03	Harbor	2026-01-03		21 Equipment - overhead	Lateral fuse	Forced	None