

Preventive Maintenance Checklist

Model Summit Drive-9 | Revision 1.0

Overview

The Summit Drive-9 records fan runtime and thermal margin for planned maintenance.

Complete the checklist without bypassing interlocks or removing protective earth.

WARNING: condition=guards are removed; consequence=moving-part injury; avoidance=stop the drive

Quarterly maintenance task

- 1. Review the event history.
- 2. Inspect airflow paths.
- 3. Confirm enclosure seals.

Check	Acceptance	Record
Fan runtime	Below 20,000 h	Hours
Heat sink	No obstruction	Pass/fail