

Service report

Atlas Coworking · Kemang · Third floor

INVOICE REFERENCE	REVISION	TECHNICIAN ACCOUNT	APPROVED BY
INV-2026-041	1	alex.morgan.demo	owner · Oct 7, 2026, 6:53:39 AM

Shared workspace · AC-01

✓ Cleaned ✓ Drain checked ✓ Cooling checked

Coil and filter cleaned. Drain flow clear; outlet air 17 °C. Cooling is stable with no follow-up required.



BEFORE SERVICE



AFTER SERVICE

Job c7df821d-ef75-464a-a337-2c4a60433536 · Revision 1
This record documents submitted service evidence. Photos are not tamper-proof; account identities are not independently verified. This is an invoice attachment, not an invoice.