



Michael Wetter
LBNL


October 13, 2020





Lawrence Berkeley
National Laboratory




Spawn architecture




Model development



Building model from
EnergyPlus





Simple HVAC system from
Modelica Buildings Library



Control sequence in
Control Description Language

EnergyPlus — Modelica run-time coupling



- EnergyPlus based HVAC and control system calculations are avoided.
- EnergyPlus and Modelica communicate on time-step basis.
- No need for user to setup co-simulation.

Access, information, and current developments

Development access: <https://github.com/lbl-srg/soep>

Tested with Dymola, Optimica, and JModelica (OpenModelica upcoming).

