



OFFICE OF THE SUPERINTENDING ENGINEER

Electrical Circle, Nagpur

Tender No. SE/EC-NGP/2026-27/0219 · Issued 12 September 2026

NOTICE INVITING TENDER

Supply of LT power cable, earthing material and structural steel
for 33/11 kV substation augmentation

1. SCOPE OF WORK

Supply, delivery and unloading of 1.1 kV grade PVC insulated armoured aluminium conductor power cable (4 core x 50 sq mm, 2,000 metres), galvanized earthing strip, and structural steel sections for equipment supports, at the divisional stores.

2. APPLICABLE STANDARDS

The cable shall conform in all respects to IS 1554 (Part 1). Conductors shall comply with IS 1753. Armouring shall conform to IS 3975. Galvanizing of the earthing strip shall be as per IS 4759:1984. Structural steel sections shall conform to IS 1570. Cable drums shall be as per IS 10418.

3. QUANTITIES AND DELIVERY

Delivery within 60 days of the purchase order, free of cost at the divisional stores. Part supply shall not be accepted without written approval.

Sl.	Item	Governing standard	Quantity
1	LT power cable, 4C x 50 sq mm	IS 1554 (Part 1)	2,000 m
2	Aluminium conductor	IS 1753	as required
3	Galvanized earthing strip	IS 4759	400 m
4	Structural steel sections	IS 1570	6 MT

4. TERMS

Rates shall be inclusive of all taxes and duties.

Superintending Engineer
Electrical Circle, Nagpur