$EpicLog_Scenario_2_19_Oct_2018_14_56_describe.pdf_describe$

	count	mean	std	min	25%	50%	75%	max
SmartHome.SIED2.Measurement.Apparent	192.0	8617.899032592773	4076.1725837244917	0.0	5703.8759765625	11071.55029296875	11089.116943359375	11126.494140625
SmartHome.SIED2.Measurement.Frequency	192.0	42.44993122418722	17.952234457830716	0.0	49.97200012207031	50.00749969482422	50.02899932861328	50.08300018310547
SmartHome.SIED2.Measurement.L1_Current	192.0	11.816405311226845	5.591696314355649	0.0	7.799999237060547	15.19999885559082	15.19999885559082	15.249998092651367
SmartHome.SIED2.Measurement.L2_Current	192.0	11.780728116631508	5.579791382083504	0.0	7.749999046325684	15.149998664855955	15.149998664855955	15.19999885559082
SmartHome.SIED2.Measurement.L3_Current	192.0	11.884634365638098	5.615466207531991	0.0	7.899999618530273	15.249998092651367	15.299999237060549	15.349998474121094
SmartHome.SIED2.Measurement.Power_Factor	192.0	0.8489442684998115	0.35901972818790273	0.0	0.9998999834060668	1.0	1.0	1.0
SmartHome.SIED2.Measurement.Reactive	192.0	-24.473184349636238	38.8196226781564	-73.5953598022461	-45.236517906188965	-27.115352630615234	-7.774838447570801	367.976806640625
SmartHome.SIED2.Measurement.Real	192.0	8617.797256469727	4076.130782849894	0.0	5703.7071533203125	11070.4033203125	11089.037353515625	11126.494140625
SmartHome.SIED2.Measurement.V1	192.0	205.88804531097412	87.073054586174	0.0	242.2165985107422	242.52030181884766	242.7900390625	243.4502868652344
SmartHome.SIED2.Measurement.V2	192.0	206.6641678015391	87.401058282002	0.0	243.2201385498047	243.45782470703125	243.61438369750977	244.15576171875
SmartHome.SIED2.Measurement.V3	192.0	205.79117528597513	87.03220622406839	0.0	242.14396286010742	242.4014587402344	242.631591796875	243.22390747070312
SmartHome.SIED2.Measurement.VL1_L2	192.0	357.44124778111774	151.1669633090432	0.0	420.5090560913086	421.0343780517578	421.4663772583008	422.813232421875
SmartHome.SIED2.Measurement.VL2_L3	192.0	357.9086920420329	151.36462965505652	0.0	421.2702026367188	421.6059875488281	421.92760467529297	422.8019409179688
SmartHome.SIED2.Measurement.VL3_VL1	192.0	355.65323066711426	150.4110436580272	0.0	418.42181396484375	418.9461975097656	419.37345123291016	420.247802734375