



	3x150 TPH BOILER PACKAGE ALONG WITH STEAM TURBO-BLOWER BUILDING (EXCLUDING ENABLING WORKS), PKG NO:- 011-01A				
	SIZING CALCULATION FOR CONDENSATE WATER TRANSFER PUMPS				
SIZING CALCULATION FOR CONDENSATE WATER TRANSFER PUMPS					
REVISION HISTORY					
Rev.	Revision Date	Prepared By	Checked By	Approved By	Description
0	23/06/2012	K.PASUPATHI	K.A.GANESH	RKS	Issued For Approval
1	9/9/2012	K.PASUPATHI	K.A.GANESH	RKS	Issued For Approval
	Owner :				
	BHILAI STEEL PLANT, BHILAI, CHATTISGARH				
	7.0 MTPA EXPANSION				
	Owner's Consultant:				
	MECON LIMITED, RANCHI				
	Contractor: Consortium of				
	FUJIAN LONGKING CO., LTD.				
	No. 81, LINGYUAN ROAD, LONGYAN CITY,				
	FUJIAN PROVIANCE, CHINA				
	ALLIED ENERY SYSTEMS PVT. LTD.				
	PLOT NO. 293, KEHAR SINGH ESTATE,				
	WESTEND MARG, SAIDULAJAB, NEW DELHI-110030				
PACKAGE DESCRIPTION	3x150 TPH BOILERS ALONG WITH STEAM TURBO-BLOWER BUILDING (EXCLUDING ENABLING WORK), PKG NO. 011-01A				
Rev. No.	Date	Document No:-		Format	Sheet
1	9/9/2012	BSP-FSCL-05-011-01A-06-001-01-BE-00053		A4	2

Project	3X150TPH Boiler, Auxiliaries & Turbo Blower System.		
Client	M/S. Bhilai Steel Plant		
EPC Contractor	M/s Fujian Longking Co. Ltd., / M/s Allied Energy Systems Pvt. Ltd.,		
Document Title	Sizing Calculation for Condensate Transfer Pumps		
Document Number	BSP-FSCL-05-011-01A-06-001-01-BE-00053		
Description	Units	Parameter	Remarks
Flow Calculations:			
Maximum flow required from condensate tank to deaerator when all the three boilers are working	tph	411	From Deaerator Sizing Calculation
Maximum temperature of condensate	°C	45.05	From condensate tank sizing Calculation
Margin on flow	%	20%	As per contract
Density of water	Kg/m ³	990.099	
Design discharge flow	tph	493.2	
Selected capacity of pump	tph	495	
Head calculations:			
Deaerator safety valve set pressure	Kg/cm ² a	6	
Deaerator nozzle pressure drop	Kg/cm ²	0.25	
Pressure drop in control valve	Kg/cm ²	2	
Static head	Kg/cm ²	2.65	
Pressure drop in flow measuring orifice	Kg/cm ²	0.2	
Pressure drop in line	Kg/cm ²	0.5	
Total pressure drop	Kg/cm ²	5.60	
Margin on pressure drop	%	10%	
Discharge pressure required	Kg/cm ² a	12.16	
Selected Discharge Pressure	Kg/cm ² a	13	
Suction pressure	Kg/cm ² a	1.3	

Project	3X150TPH Boiler, Auxiliaries & Turbo Blower System.		
Client	M/S. Bhilai Steel Plant		
EPC Contractor	M/s Fujian Longking Co. Ltd., / M/s Allied Energy Systems Pvt. Ltd.,		
Document Title	Sizing Calculation for Condensate Transfer Pumps		
Document Number	BSP-FSCL-05-011-01A-06-001-01-BE-00053		
Description	Units	Parameter	Remarks
Differential pressure	Kg/cm ²	11.7	
Design conditions for the pump:			
Rated flow in terms of TPH	tph	495	
Rated flow in terms of m ³ /hr	m ³ /hr	500	
Temperature of medium	°C	50	
Differential pressure at rated flow	MLC	131.3	Suction pressure neglected
Suction pressure	MLC	flooded	