JCESITE
AI-ASSISTED SITE PLANNING

SITE ASSESSMENT AND PLANNING CONSTRAINTS

Site Assessment and Planning Constraints Report

Lot 2 DP 227508, GUNNEDAH



Figure 1. Lot 2 DP 227508: site context. Lot boundary from the cadastre (indicative, not a survey). Aerial: Imagery: NSW Spatial Services © Department of Customer Service 2020 (includes third-party imagery: AAM, Jacobs Group Ausimage, LANDSAT). Imagery date: 18/10/2011.

PROJECT **Test run: 2//DP227508**	LOT / PLAN **Lot 2 DP 227508**	COUNCIL (LGA) **GUNNEDAH**
ZONE **R2 Low Density Residential**	SITE AREA **956 m²**	SCOPE **Site only**
REPORT DATE **14/10/2026**	STATUS **AI generated draft, indicative**	PRODUCED BY **JCESITE (AI-assisted site planning)**

AI GENERATED DRAFT. NOT CHECKED OR CERTIFIED. MUST BE CHECKED AND VERIFIED BY A QUALIFIED PERSON BEFORE ANY USE.

Indicative only. Mapping data is unverified. This is not a section 10.7 planning certificate or a council property report. Read How to read this report before relying on any result.

01 / SECTION

How to read this report

What the report is, what it is not, and what each result means in plain words.

WHAT THIS REPORT IS

- An indicative, AI assisted draft that screens one lot against a fixed list of mapped planning and hazard layers.
- A written companion to the JCESITE plan set, explaining what each mapped layer is, why it may matter and what to do next.
- A prompt for questions to put to council, authorities and qualified people.

WHAT THIS REPORT IS NOT

- Not certified, not checked by a qualified person and not for approval, sale, finance or construction decisions.
- Not a survey. Lot boundaries come from the cadastre and are indicative.
- Not legal advice or planning advice, and not a section 10.7 planning certificate or council property report.
- Not a complete list of constraints. Only the layers listed in the constraint summary were screened.
- Site only. No building, footprint or floor level has been assessed in this report.

AI GENERATED DRAFT. NOT CHECKED OR CERTIFIED. MUST BE CHECKED AND VERIFIED BY A QUALIFIED PERSON BEFORE ANY USE.

WHAT EACH RESULT MEANS

INTERSECTS	**INTERSECTS** A mapped feature in the dataset overlaps the lot boundary. The overlap area and the share of the lot are shown. This is the strongest screening result. It still needs confirming with the authority.
WITHIN BUFFER	**WITHIN BUFFER (distance)** No mapped feature overlaps the lot, but one lies inside the screening distance measured out from the lot boundary. The distance shown is from the lot boundary to the nearest mapped feature. See Buffers explained.
NOT INTERSECTED	**NOT INTERSECTED BY THE DATA LOADED** No mapped feature in the data loaded for this run overlaps the lot or lies inside the screening distance. This describes the data only. It does not mean the site is free of the issue, because the data may be out of date, incomplete or cover only part of the topic.
NOT CHECKED	**NOT CHECKED** The layer could not be queried in this run (for example no data service is connected, or the service did not respond). NOT CHECKED IS NOT CLEAR. The site may be affected and the layer must be checked directly with the authority.
UNRESOLVED	**UNRESOLVED** A requirement or value was not found in the cited sources. Nothing has been assumed in its place. It must be confirmed with the authority.
ASSUMED	**ASSUMED / PLATFORM DEFAULT** A value that the platform or the user supplied without a cited source (for example a screening distance, a placeholder accuracy or a user entered figure). It is labelled wherever it is used and is not a statutory requirement.

HOW A CONSTRAINT PAGE IS LAID OUT

- A figure with the lot outline, the mapped feature, the screening buffer ring and, where a feature is inside the ring, a distance line marked d.
- A caption stating the screening distance used and whether it is a screening setting, a cited rule or UNRESOLVED.
- RESULT FOR THIS LOT, then WHAT THIS IS, WHY IT MATTERS and WHAT TO DO NEXT.
- Layers with no map page are explained in the Layer guide, with the same four parts.

02 / SECTION

Buffers explained

Why a feature that does not touch the lot can still be reported, and what the distance number means.

WHAT A BUFFER IS

A buffer is a zone drawn at a set distance around something. In this report there are two kinds, and they are labelled differently.

Screening buffer. The platform draws a ring at a fixed distance outward from the lot boundary and asks whether any mapped feature lies inside it. This is how a feature that does not touch the lot can still be reported.

Mapped buffer. Some datasets publish their own buffer polygon (for example a vegetation buffer in bush fire prone land mapping). That polygon is part of the source data and is reported as a mapped feature like any other.




Diagram. Schematic only, not to scale and not based on any value. The same ring is drawn on each constraint page, at the screening distance for that layer.

WHY A LAYER IS SCREENED WITH A DISTANCE

Many hazards and protections extend beyond the edge of the mapped feature. Heat and embers travel beyond vegetation, water moves across land beside a watercourse, and noise and vibration spread from a road. Checking only for a direct overlap could miss features that sit just outside the lot.

A screening distance lets the report flag nearby features for follow up. It is a prompt to ask a question, not a finding that a rule applies.

INTERSECTS COMPARED WITH WITHIN BUFFER

INTERSECTS	The mapped feature overlaps the lot. The overlap area is measured and shown.
WITHIN BUFFER (distance)	The mapped feature does not touch the lot but lies inside the screening distance. The distance number is the shortest straight line from the lot boundary to the feature.
NOT INTERSECTED BY THE DATA LOADED	No feature overlaps the lot or lies inside the screening distance in the data that was loaded.

WHAT THE DISTANCE NUMBER IS

- The distance number on a layer page is measured in metres from the lot boundary to the nearest edge of the mapped feature, in map grid coordinates.
- Data is loaded for the lot plus a margin of 150 m. Features beyond that margin are not seen by the check.

WHERE THE SCREENING DISTANCE COMES FROM

Each distance is a PLATFORM SCREENING SETTING taken from the platform screening settings. It is a screening setting and is not a statutory requirement. It changes only if a cited requirement supplies a different figure for that layer. Each constraint page states which of the following applies.

SCREENING SETTING	A distance set in the platform screening settings. It is not a statutory requirement. Treat it as a screening prompt only.
CITED RULE	A distance supplied by a cited requirement (document, page and quote shown). It is used in place of the screening setting only where the citation names that figure for that layer.
UNRESOLVED	No screening setting and no cited rule is available for the distance. No figure is assumed.

SCREENING DISTANCES USED IN THIS RUN

LAYER	SCREENING DISTANCE	STATUS
Bush fire prone land	**100 m**	SCREENING SETTING
Coastal wetlands	**100 m**	SCREENING SETTING
Road and rail corridors	**60 m**	SCREENING SETTING
Riparian land and watercourses	**40 m**	SCREENING SETTING
Flood planning area	**None (overlap only)**	SCREENING SETTING
Heritage conservation area	**None (overlap only)**	SCREENING SETTING
Heritage item	**None (overlap only)**	SCREENING SETTING
Acid sulfate soils	**None (overlap only)**	SCREENING SETTING
Contaminated land	**None (overlap only)**	SCREENING SETTING
Land reservation acquisition	**None (overlap only)**	SCREENING SETTING
Airport noise and obstacles	**None (overlap only)**	SCREENING SETTING
Biodiversity values	**None (overlap only)**	SCREENING SETTING
Mine subsidence district	**None (overlap only)**	SCREENING SETTING
Floor space ratio	**None (overlap only)**	SCREENING SETTING
Maximum building height	**None (overlap only)**	SCREENING SETTING
Minimum lot size	**None (overlap only)**	SCREENING SETTING
State policy land application	**None (overlap only)**	SCREENING SETTING
Urban release area	**None (overlap only)**	SCREENING SETTING

Data is loaded for the lot plus a margin of 150 m (a platform setting). A layer with no screening distance reports only features that intersect the lot; a nearest distance may still be shown for information.

03 / SECTION

What matters for this site

0	0	0	18	0
INTERSECTS	WITHIN BUFFER	NOT INTERSECTED	NOT CHECKED	UNRESOLVED ITEMS

18 planning and hazard layers were listed for screening for Lot 2 DP 227508 (GUNNEDAH); 0 could be checked and 18 could not be checked. The result of each layer is one of INTERSECTS, WITHIN BUFFER, NOT INTERSECTED BY THE DATA LOADED or NOT CHECKED.

TOP FINDINGS, RANKED

01 **Zoning and planning controls** — CONTROLS
The lot is zoned R2 Low Density Residential.

02 **18 layers not checked** — NOT CHECKED
These could not be queried and must be checked manually: flood planning area; bush fire prone land; heritage item; heritage conservation area; acid sulfate soils; biodiversity values; coastal wetlands; riparian land and watercourses; land reservation acquisition; airport noise and obstacles; mine subsidence district; contaminated land; road and rail corridors; state policy land application; urban release area; minimum lot size; maximum building height; floor space ratio. Not checked is not clear.

APPROVAL PATHWAY

NOT ASSESSED in this report. The approval pathway (exempt development, complying development or a development application) depends on the proposal and is outside this site only report. Ask council or an accredited certifier.

NEXT ACTIONS

- ☐ Obtain the s10.7 planning certificate for Lot 2 DP 227508 from council and confirm every layer in this report against it.
- ☐ Check the layers marked NOT CHECKED directly with council: flood planning area; bush fire prone land; heritage item; heritage conservation area; acid sulfate soils; biodiversity values; coastal wetlands; riparian land and watercourses; land reservation acquisition; airport noise and obstacles; mine subsidence district; contaminated land; road and rail corridors; state policy land application; urban release area; minimum lot size; maximum building height; floor space ratio.
- ☐ Confirm the flagged council requirements (low confidence or UNRESOLVED) with council planning staff.
- ☐ Engage a registered surveyor for an identification and detail survey before any design is finalised.

Not checked is not clear. A layer marked NOT CHECKED could not be queried, so the site may well be affected. It must be checked with the council before design or purchase decisions are made.

04 / SECTION

Site and zoning

LOT / PLAN	Lot 2 DP 227508 (2//DP227508)
COUNCIL (LGA)	GUNNEDAH
ZONE	R2 Low Density Residential (from the NSW LEP zoning layer)
SITE AREA	956 m² calculated from the boundary; registered area not available
FRONTAGE	20.2 m to Little Bloomfield Street
MINIMUM LOT SIZE	Not checked
FLOOR SPACE RATIO	Not checked
MAXIMUM HEIGHT	Not checked
ZONE OBJECTIVES	Not available in this report: the zone objectives and land use table from the LEP were not loaded. Read them in the LEP.



Figure 2. Lot detail with adjoining lots. Figure extent about 121 m wide by 120 m high.




Figure 3. Neighbourhood. Figure extent about 276 m wide by 273 m high.

Aerial: Imagery: NSW Spatial Services © Department of Customer Service 2020 (includes third-party imagery: AAM, Jacobs Group Ausimage, LANDSAT). Imagery date: 18/10/2011. Lot boundaries are from the NSW cadastre and are indicative, not a survey.

ADJOINING PARCELS

LOT 1 DP227508, LOT 3 DP227508, LOT 5 DP548460.

05 / SECTION

Constraint summary

Every layer screened for this lot, with what was found, how far away it is and where the data came from.

STATUS	LAYER AND RESULT	DISTANCE / OVERLAP	SOURCE AND DATA CURRENCY
NOT CHECKED	**Flood planning area** The data service could not be reached from this run (network error). The layer was not queried. To do: Ask council for flood information for the lot (flood planning level and any flood study data).	-	Planning/Hazard / Flood Planning Not queried
NOT CHECKED	**Bush fire prone land** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the s10.7 planning certificate or the RFS Check and Plan map for bush fire prone land status.	-	Fire/BFPL / NSW Bush Fire Prone Lands Not queried
NOT CHECKED	**Heritage conservation area** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the LEP heritage conservation area map with council.	-	Planning/EPI_Primary_Planning_Layers / Heritage Not queried
NOT CHECKED	**Heritage item** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the LEP heritage schedule and the NSW State Heritage Inventory for the lot and its neighbours.	-	Planning/EPI_Primary_Planning_Layers / Heritage Not queried
NOT CHECKED	**Acid sulfate soils** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the LEP acid sulfate soils map and any local ASS clause with council.	-	Planning/Protection / Acid Sulfate Soils Not queried
NOT CHECKED	**Contaminated land** No public data service for this layer is connected to the platform yet. To do: Check the NSW EPA contaminated land record and the council's s10.7 certificate.	-	Source not recorded Not queried
NOT CHECKED	**Land reservation acquisition** The data service could not be reached from this run (network error). The layer was not queried. To do: Ask council which authority holds the reservation and whether it affects the proposal.	-	Planning/EPI_Primary_Planning_Layers / Land Reservation Acquisition Not queried
NOT CHECKED	**Airport noise and obstacles** The data service could not be reached from this run (network error). The layer was not queried. To do: Check height and noise controls with council or the airport operator.	-	Planning/Protection / Airport Noise Not queried
NOT CHECKED	**Biodiversity values** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the Biodiversity Values Map and whether native vegetation clearing is proposed.	-	ePlanning/BiodiversityValuesMap / Biodiversity Values Not queried
NOT CHECKED	**Coastal wetlands** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the Resilience and Hazards SEPP coastal maps with council.	-	Planning/SEPP_Resilience_and_Hazards_2021 / Coastal Wetlands Not queried
NOT CHECKED	**Mine subsidence district** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the Subsidence Advisory NSW district map.	-	ePlanning/Planning_Portal_Subsidence_Advisory / Mine Subsidence District Not queried
NOT CHECKED	**Riparian land and watercourses** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the watercourse and any controlled-activity requirements with council.	-	Planning/Protection / Riparian Lands and Watercourses Not queried

STATUS	LAYER AND RESULT	DISTANCE / OVERLAP	SOURCE AND DATA CURRENCY
NOT CHECKED	**Road and rail corridors** No public data service for this layer is connected to the platform yet. To do: Check classified road and rail corridor controls with council and Transport for NSW.	-	Source not recorded Not queried
NOT CHECKED	**Floor space ratio** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the LEP floor space ratio clause.	-	Planning/EPI_Primary_Planning_Layers / Floor Space Ratio Not queried
NOT CHECKED	**Maximum building height** The data service could not be reached from this run (network error). The layer was not queried. To do: Check the LEP height clause and DCP height controls.	-	Planning/EPI_Primary_Planning_Layers / Height of Building Not queried
NOT CHECKED	**Minimum lot size** The data service could not be reached from this run (network error). The layer was not queried. To do: Check LEP clause 4.1 and the lot size map.	-	Planning/EPI_Primary_Planning_Layers / Lot Size Not queried
NOT CHECKED	**State policy land application** The data service could not be reached from this run (network error). The layer was not queried. To do: Check with council.	-	Planning/SEPP_Resilience_and_Hazards_2021 / Land Application Map Not queried
NOT CHECKED	**Urban release area** The data service could not be reached from this run (network error). The layer was not queried. To do: Ask council whether satisfactory-arrangements provisions apply.	-	Planning/Development_Control / Urban Release Area Not queried

Not checked is not clear. A layer marked NOT CHECKED could not be queried, so the site may well be affected. It must be checked with the council before design or purchase decisions are made.

06 / SECTION

Layer guide

Every layer screened in this run, explained in the same four parts: result, what it is, why it matters and what to do next.

NOT CHECKED

Flood planning area

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land that a planning instrument or flood mapping identifies as subject to flood related controls. The data loaded covers the flood mapping in the service named in the source line. Separate council flood studies and overland flow mapping may exist that are not in this data.
WHY IT MATTERS	Land shown as flood affected may be subject to controls on filling, drainage, access and works on the site. It may trigger a flood assessment, a referral or an approval. Whether it does depends on the authority and the proposal.
WHAT TO DO NEXT	Ask council for flood information for the lot, including whether a flood study applies. Obtain a section 10.7 planning certificate. A qualified flood engineer may be needed to interpret the information.
SOURCE	Source: Service Planning/Hazard, layer Flood Planning (layer id 1). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Bush fire prone land

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land mapped as bush fire prone. It typically shows vegetation classed by hazard and may include a buffer zone around that vegetation. Who publishes the data is stated in the source line, from the layer's own metadata.
WHY IT MATTERS	Land mapped as bush fire prone may be subject to bushfire assessment and protection measures such as a Bushfire Attack Level assessment, an asset protection zone or a referral. These may apply to the site and to anything built on it.
WHAT TO DO NEXT	Confirm bush fire prone status on the section 10.7 planning certificate. Engage a qualified bushfire assessor if the lot is mapped or close to mapped vegetation. Ask council or the relevant fire authority what applies to the proposal.
SOURCE	Source: Service Fire/BFPL, layer NSW Bush Fire Prone Lands (layer id 0). host mapprod3.environment.nsw.gov.au. Publisher or copyright statement (shortened): The NSW BFPL Map is collated and merged together from individual NSW local council maps which are submitted by the local council for certification....

NOT CHECKED

Heritage conservation area

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing areas identified in a planning instrument as having heritage significance as a whole.
WHY IT MATTERS	Works within a heritage conservation area may need approval and may need to respond to the character of the area. This depends on the instrument and the proposal.
WHAT TO DO NEXT	Confirm with council whether the lot is in a conservation area and what controls apply. Engage a qualified heritage consultant if it is.
SOURCE	Source: Service Planning/EPI_Primary_Planning_Layers, layer Heritage (layer id 0). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Heritage item

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing places listed as heritage items in a planning instrument. The data loaded covers listed items only and does not cover unlisted or Aboriginal cultural heritage.
WHY IT MATTERS	Works on or near a heritage item may need approval and a heritage assessment. The lot may also be affected by an item on a neighbouring lot. This depends on the instrument and the proposal.
WHAT TO DO NEXT	Confirm with council whether any item affects the lot or its neighbours. Check the heritage schedule. Engage a qualified heritage consultant if an item is identified.
SOURCE	Source: Service Planning/EPI_Primary_Planning_Layers, layer Heritage (layer id 0). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Acid sulfate soils

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer classing land by the likelihood of acid sulfate soils being present at different depths. These soils can release acid and metals when disturbed or exposed to air.
WHY IT MATTERS	Excavation, drainage or lowering of groundwater on mapped land may trigger a management plan or an approval. The class and the depth of works usually decide this.
WHAT TO DO NEXT	Confirm the class and any local requirement with council. Obtain a geotechnical or soil assessment from a qualified person before excavation on mapped land.
SOURCE	Source: Service Planning/Protection, layer Acid Sulfate Soils (layer id 1). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Contaminated land

RESULT	NOT CHECKED. No public data service for this layer is connected to the platform yet. Not checked is not clear.
WHAT THIS IS	A map layer showing land recorded as contaminated or potentially contaminated.
WHY IT MATTERS	A change of use, earthworks or excavation on affected land may trigger a site investigation and, if contamination is found, remediation.
WHAT TO DO NEXT	Check the records held by the environmental regulator and the section 10.7 planning certificate. Engage a qualified contaminated land consultant if needed.
SOURCE	Source: No data service is recorded for this layer in the platform. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Land reservation acquisition

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land reserved in a planning instrument for a future public purpose, such as a road or open space.
WHY IT MATTERS	Land reserved for acquisition may restrict what can be built on it. The acquiring authority may have a right to take it.
WHAT TO DO NEXT	Ask council which authority holds the reservation and what it means for the lot.
SOURCE	Source: Service Planning/EPI_Primary_Planning_Layers, layer Land Reservation Acquisition (layer id 3). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Airport noise and obstacles

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land inside an airport noise forecast contour or under surfaces that limit the height of structures near an airport. Only the parts present in the data loaded are shown.
WHY IT MATTERS	Land in these areas may be subject to height limits, noise measures or a referral to the airport operator.
WHAT TO DO NEXT	Ask council or the airport operator what applies. Engage a qualified acoustic consultant if noise measures are raised.
SOURCE	Source: Service Planning/Protection, layer Airport Noise (layer id 2). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Biodiversity values

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land flagged as having biodiversity value, such as native vegetation or habitat.
WHY IT MATTERS	Clearing or works on mapped land may trigger an ecological assessment, a referral or a biodiversity offset. Clearing outside the mapped land can still need approval under other rules.
WHAT TO DO NEXT	Confirm with council whether the mapping applies and whether any clearing is proposed. Engage a qualified ecologist or accredited assessor if it does.
SOURCE	Source: Service ePlanning/BiodiversityValuesMap, layer Biodiversity Values (layer id 1). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Coastal wetlands

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land mapped as part of the coastal zone, such as coastal wetlands or areas near them. Other coastal areas may exist that are not in the data loaded.
WHY IT MATTERS	Works on or near mapped coastal land may trigger an assessment, a referral or an approval, and may be tightly controlled.
WHAT TO DO NEXT	Confirm with council whether any coastal mapping applies to the lot. Obtain a section 10.7 planning certificate.
SOURCE	Source: Service Planning/SEPP_Resilience_and_Hazards_2021, layer Coastal Wetlands (layer id 3). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Mine subsidence district

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing declared districts where mining related ground movement may occur.
WHY IT MATTERS	Works in a declared district may need approval from the relevant authority as well as council.
WHAT TO DO NEXT	Confirm district status on the section 10.7 planning certificate and with the district authority.
SOURCE	Source: Service ePlanning/Planning_Portal_Subsidence_Advisory, layer Mine Subsidence District (layer id 248). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Riparian land and watercourses

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing watercourses and the land beside them (riparian land). Unmapped creeks and drainage lines may not appear.
WHY IT MATTERS	Works on or near a watercourse may need a setback from the bank, an approval from the water regulator or an assessment of stormwater and bank stability. The screening ring helps flag watercourses close to the lot.
WHAT TO DO NEXT	Confirm with council and the water regulator whether a watercourse affects the lot. A qualified engineer or hydrologist may be needed to set out the bank and any setback.
SOURCE	Source: Service Planning/Protection, layer Riparian Lands and Watercourses (layer id 7). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Road and rail corridors

RESULT	NOT CHECKED. No public data service for this layer is connected to the platform yet. Not checked is not clear.
WHAT THIS IS	A map layer showing road or rail corridors, or land next to them.
WHY IT MATTERS	Land next to a major road or railway may be subject to noise and vibration controls, access limits or a referral to the transport authority.
WHAT TO DO NEXT	Ask council and the transport authority what applies. Engage a qualified acoustic consultant if noise measures are raised.
SOURCE	Source: No data service is recorded for this layer in the platform. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Floor space ratio

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing a floor space ratio control from the planning instrument. It is a building control and is shown for information only.
WHY IT MATTERS	It may limit the floor area that can be built relative to the lot area. No building has been assessed in this report.
WHAT TO DO NEXT	Check the planning instrument with council when a building design is prepared.
SOURCE	Source: Service Planning/EPI_Primary_Planning_Layers, layer Floor Space Ratio (layer id 1). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Maximum building height

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing a building height control from the planning instrument. It is a building control and is shown for information only.
WHY IT MATTERS	It may limit building height. No building has been assessed in this report.
WHAT TO DO NEXT	Check the planning instrument with council when a building design is prepared.
SOURCE	Source: Service Planning/EPI_Primary_Planning_Layers, layer Height of Building (layer id 5). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Minimum lot size

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing the smallest lot size that the planning instrument allows to be created by subdivision.
WHY IT MATTERS	It guides subdivision potential. It does not by itself stop use of an existing lot. This report does not assess subdivision.
WHAT TO DO NEXT	Check the planning instrument and the map with council if subdivision is being considered.
SOURCE	Source: Service Planning/EPI_Primary_Planning_Layers, layer Lot Size (layer id 4). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

State policy land application

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing where a state level planning policy applies by its own land application map. Other state policies apply by their own rules and are not mapped here.
WHY IT MATTERS	A policy that applies to the lot may add assessment requirements or change which approval path is available.
WHAT TO DO NEXT	Confirm with council which state policies apply to the lot. Obtain a section 10.7 planning certificate.
SOURCE	Source: Service Planning/SEPP_Resilience_and_Hazards_2021, layer Land Application Map (layer id 1). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

NOT CHECKED

Urban release area

RESULT	NOT CHECKED. The data service could not be reached from this run (network error). The layer was not queried. Not checked is not clear.
WHAT THIS IS	A map layer showing land identified for new urban development, where servicing arrangements may need to be in place first.
WHY IT MATTERS	Land in an urban release area may need arrangements for infrastructure before subdivision or development proceeds.
WHAT TO DO NEXT	Ask council whether arrangements apply to the lot.
SOURCE	Source: Service Planning/Development_Control, layer Urban Release Area (layer id 7). host mapprod3.environment.nsw.gov.au. Publisher: SOURCE NOT RECORDED.

07 / SECTION

Council requirements for the site

Site level requirements loaded for R2, each cited to the council document. Building requirements (setbacks, floor levels, outbuildings) are outside this site only report.

> These values were extracted automatically from council documents and may be wrong, incomplete or superseded. Items flagged 'Low confidence' or 'Not found' need confirming with council before they are relied on.

REQUIREMENT	VALUE	SOURCE (DOCUMENT, PAGE, QUOTE)	FLAG
ACCESS AND DRIVEWAY			
Standard for access from the road to the property boundary	**Council standard access drawings + AS2890 series**	GSC Development Control Plan 2025, p.39, C.1.4 Internal driveway, access and parking “Access from the public road to the property boundary to comply with Council's standard access drawings (relevant to the type of development) and the...”	
Surface of internal access and manoeuvring areas	**concrete, bitumen, interlocking pavers or asphalt**	GSC Development Control Plan 2025, p.39, C.1.4 Internal driveway, access and parking “All internal vehicle access, and manoeuvring areas to the designated parking area (including the designated parking area), are to be concrete...”	
Multiple access points	**not permitted unless lot has two road frontages**	GSC Development Control Plan 2025, p.39, C.1.4 Internal driveway, access and parking “Multiple vehicle access points and laybacks are not permitted, will generally only be considered in circumstances where the lot has two road...”	
Crossings per street frontage, maximum	**2**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.44, 2.8.7 Vehicular crossings and accesses, Table 2-H “Maximum number of crossings per street frontage 2”	
Driveway access width, maximum	**4.5 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.44, 2.8.7 Vehicular crossings and accesses, Table 2-H “Width of access (excluding layback splays) 3.0 - 4.5m”	
Kerb separation between crossings, minimum	**2 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.44, 2.8.7 Vehicular crossings and accesses, Table 2-H “Minimum kerb separation distance between crossings 2m”	
Rural driveway culvert diameter, minimum	**450 mm**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.45, 2.8.7 Vehicular crossings and accesses “The minimum size for piped culverts is to be 450mm diameter in rural areas and 375mm diameter in rural residential areas.”	
Driveway culvert width, minimum	**4.5 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.45, 2.8.7 Vehicular crossings and accesses “The minimum width of culverts shall be 4.5 metres.”	
Crossing to common boundary, minimum distance	**0.5 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.44, 2.8.7 Vehicular crossings and accesses, Table 2-H “between crossings and common property boundary 0.5m”	
Crossing to corner allotment boundary, minimum distance	**6 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.44, 2.8.7 Vehicular crossings and accesses, Table 2-H “Minimum distance from crossing to corner allotment boundary 6m”	
Driveway access width, minimum	**3 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.44, 2.8.7 Vehicular crossings and accesses, Table 2-H “Width of access (excluding layback splays) 3.0 - 4.5m”	

REQUIREMENT	VALUE	SOURCE (DOCUMENT, PAGE, QUOTE)	FLAG
Rural gate set back from the road	**Yes / required**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.45, 2.8.7 Vehicular crossings and accesses “Gated accesses in rural areas or areas where the posted speed limit for the road is greater than 80km/h shall have the gate recessed into the...”	
FLOOD			
On-site sewage not to discharge to floodwater	**Yes / required**	GSC Development Control Plan 2025, p.23, B.5.1 General, control d “On-site sewage management systems located within a flood planning area shall be designed to ensure that effluent cannot be discharged into flood...”	
Flood planning level, annual exceedance probability	**1%**	GSC Development Control Plan 2025, p.22, B.5 Flooding (introduction) “Council has adopted the 1% Annual Exceedance Probability (AEP) plus 0.5m freeboard, as its Flood Planning Level (FPL).”	
BUSHFIRE			
Exempt clearing of trees, distance from buildings	**10 m**	NSW Planning: Bushfires (10/50 vegetation clearing), p.1, Bushfires: 10/50 vegetation clearing entitlement “trees and vegetation within 10 m of specified bushfire-prone buildings”	
Exempt clearing of undergrowth, distance from buildings	**50 m**	NSW Planning: Bushfires (10/50 vegetation clearing), p.1, Bushfires: 10/50 vegetation clearing entitlement “undergrowth within 50 m of specified bushfire-prone buildings.”	
WATER, SEWER, STORMWATER AND RAINWATER TANKS			
Sewer property connection cover, minimum	**0.3 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.130, 5.5.10 Design criteria (sewer) “minimum 300 millimetres of cover laid at a minimum grade of 1 in 60.”	
Sewer property connection grade, minimum (1 in N)	**60 (1 in N)**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.130, 5.5.10 Design criteria (sewer) “minimum 300 millimetres of cover laid at a minimum grade of 1 in 60.”	
Sewer junction diameter, minimum	**150 mm**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.130, 5.5.10 Design criteria (sewer) “A 150 millimetre diameter sewer junction is to be provided within each lot.”	
Stormwater design standard	**GSC Engineering Design Minimum Standards**	GSC Development Control Plan 2025, p.43, C.5 Stormwater, control a “All stormwater systems shall be designed and constructed in accordance with Council's Engineering Design Minimum Standards.”	
Roof water plumbing design event, annual exceedance probability	**5%**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.96, 3.10.4.2-3.10.4.3 On-site detention systems in small developments “All roof water plumbing including tank connections shall cater for the 5% AEP year, to AS 3500.”	
Building over or near a council sewer main	**Council Building over Sewer Policy (policy document not obtained)**	GSC Development Control Plan 2025, p.26, B.7 Utilities and services, control c “Where a structure is proposed in proximity to a Council sewer main or other infrastructure, all design and construction shall be in accordance with...”	
Servicing strategy with the application	**Yes / required**	GSC Development Control Plan 2025, p.26, B.7 Utilities and services, control a “A servicing strategy is required with all development applications to demonstrate that availability and feasibility of providing water, sewer and...”	

REQUIREMENT	VALUE	SOURCE (DOCUMENT, PAGE, QUOTE)	FLAG
Water main cover, minimum	**0.5 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.119, 4.7.7.4 Service connections - locations (water) “The services are to have a minimum cover of 500mm under carriageways and 300mm in footway reserves.”	
Water main cover in the footway, minimum	**0.3 m**	GSC Engineering Design Minimum Standards for Subdivisions and Developments, p.119, 4.7.7.4 Service connections - locations (water) “The services are to have a minimum cover of 500mm under carriageways and 300mm in footway reserves.”	
Potable water connection where available	**Yes / required**	GSC Development Control Plan 2025, p.26, B.7 Utilities and services, control d “If available, connection to potable water supply is required.”	
Water storage where no mains water, minimum	**60000 L**	GSC Development Control Plan 2025, p.26, B.7 Utilities and services, control d “Where no potable water supply is available, minimum tank storage of 60,000 litres is required, excluding any water required for firefighting purposes.”	
SITE			
Slope above which a geotechnical investigation is required	**15%**	GSC Development Control Plan 2025, p.21, B.3 Slope and land stability “Development on slopes greater than 15% require a detailed geotechnical investigation”	

NOT FOUND IN THE CITED SOURCES (UNRESOLVED)

ITEM	STATUS
Land use permissibility and zone objectives	UNRESOLVED. Not found in the cited sources. Confirm with council.
Minimum lot size	UNRESOLVED. Not found in the cited sources. Confirm with council.
Driveway maximum grade and grade change	UNRESOLVED. Not found in the cited sources. Confirm with council.
Minimum grade of sewer mains	UNRESOLVED. Not found in the cited sources. Confirm with council.
Sewer and water connection availability	UNRESOLVED. Not found in the cited sources. Confirm with council.
Bushfire requirements (attack level, asset protection zone, access and water supply)	UNRESOLVED. Not found in the cited sources. Confirm with council.
Lot specific flood planning level	UNRESOLVED. Not found in the cited sources. Confirm with council.

AI GENERATED DRAFT. NOT CHECKED OR CERTIFIED. MUST BE CHECKED AND VERIFIED BY A QUALIFIED PERSON BEFORE ANY USE.
NOT A S10.7 PLANNING CERTIFICATE OR COUNCIL PROPERTY REPORT. INDICATIVE ONLY. NOT CHECKED IS NOT CLEAR.

08 / SECTION

Civil summary

Indicative ground levels, driveway and services notes for the site. Everything on this page is unverified.

UNVERIFIED Based on public data and defaults. Not survey, engineering design or certification.

Terrain

SOURCE	NSW_5M_Elevation ImageServer exportImage
POINTS SAMPLED	144
GROUND RANGE	RL 264.1 to 265.9 m AHD (1.8 m relief across the lot)
VERTICAL ACCURACY	ASSUMED / PLATFORM DEFAULT: 5 m (unknown (placeholder))

> The 5 m DEM is derived from stereo imagery and is too coarse for detailed cut and fill on a residential lot. Commission a detail survey before relying on levels or earthworks quantities.

Earthworks

Not calculated: no earthworks design was supplied and the terrain model is a coarse 5 m DEM.

Driveway and crossover

DESIGN WIDTH	3.0 m
DESIGN VEHICLE	B85
MAXIMUM GRADE	Not computed (no survey levels along the route)
STANDARD	default (AS/NZS 2890.1) used
COUNCIL WIDTH RANGE	3 to 4.5 m (Gunnedah Engineering Design Minimum Standards for Subdivisions and Developments, p.44): design width is within the range

The driveway check is preliminary screening, not certified compliance with AS/NZS 2890.1.

Services and rainwater tank

EXISTING SERVICES	0 service assets entered; no BYDA plans were supplied, so existing underground services are unknown
PROPOSED CONNECTIONS	0
RAINWATER TANK	Not sized in this run

Service positions and depths are indicative. Obtain current BYDA plans and physically locate services (potholing) before any excavation.

09 / SECTION

Glossary

Terms used in this report and in the JCESITE plan set. Definitions are general and carry no local values.

TERM	DEFINITION
AEP	Annual exceedance probability. A 1% AEP flood has a 1 in 100 chance of being equalled or exceeded in any year.
AHD	Australian Height Datum. The national reference surface for heights, close to mean sea level. Ground and flood levels are stated in metres AHD.
Asset protection zone	An area around a building managed to reduce bushfire fuel. Its width, if any, is set by the relevant authority for the site.
Assumed / platform default	A value the platform or the user supplied without a cited source. It is labelled wherever it is used and is not a statutory requirement.
BAL (Bushfire Attack Level)	A rating of how severely a site could be exposed to embers, radiant heat and flame contact in a bushfire. It is determined by a qualified assessor under the applicable standard.
Batter	The sloping face of a cut or fill embankment.
Buffer	A zone drawn at a set distance around a feature or a lot. See Buffers explained.
Bushfire prone land	Land mapped as having bushfire hazard, usually the vegetation and a buffer zone around it. Bushfire provisions may apply to development on or near it.
Cadastre	The official record and map of land parcel boundaries.
Crossover	The driveway connection across the road verge between the road pavement and the property boundary.
Cut and fill	Excavating ground (cut) and placing material (fill) to change ground levels.
DBYD	Before You Dig Australia (BYDA), formerly Dial Before You Dig. A referral service for finding out about underground assets before excavating. Asset owners hold the data and answer each enquiry.
DCDB	Digital Cadastral Database. The state digital map of property boundaries. It is indicative and is not a survey.
DCP	Development control plan. A council document setting detailed development requirements.
DEM	Digital elevation model. A grid of ground heights. A coarse grid, such as 5 m, cannot show small level changes on a small lot.
DP	Deposited plan. A registered plan lodged with the land registry that defines lots and easements.
Easement	A legal right for someone to use part of a lot for a set purpose, such as drainage or services. It may limit what can be built or planted on that part.
ESCP	Erosion and sediment control plan. It shows how soil loss and sediment leaving the site will be limited during works.
Flood planning area	Land that a planning instrument maps as subject to flood related development controls.
GDA2020	Geocentric Datum of Australia 2020. The national coordinate system used for positions in this report.
Indicative	Approximate and for guidance only. It has not been surveyed, checked or certified.
Intersects	A mapped feature overlaps the lot boundary.
Kerb and gutter	The raised edge of a road pavement (kerb) and the channel beside it (gutter) that carries stormwater runoff.
Layback	The lowered section of kerb and gutter at a driveway so that a vehicle can cross it.
Layover	The driveway slab across the road verge, between the lowered kerb (layback) and the property boundary.
LEP	Local environmental plan. The main statutory planning instrument for a council area, with zones and maps.
LGA	Local government area. The area of a council.
Lot	A parcel of land created by a registered plan.
MGA zone	Map Grid of Australia zone. Positions are in metres on a flat grid based on GDA2020, divided into zones 6 degrees of longitude wide. The zone suits the location of the lot.
Not checked	The layer could not be queried in this run. Not checked is not clear.

AI GENERATED DRAFT. NOT CHECKED OR CERTIFIED. MUST BE CHECKED AND VERIFIED BY A QUALIFIED PERSON BEFORE ANY USE.
NOT A S10.7 PLANNING CERTIFICATE OR COUNCIL PROPERTY REPORT. INDICATIVE ONLY. NOT CHECKED IS NOT CLEAR.

TERM	DEFINITION
Not intersected by the data loaded	No feature in the data loaded overlaps the lot or lies inside the screening distance. It does not prove the site is free of the issue.
Qualified person	A person with the training, registration and insurance suited to the matter, such as a registered surveyor, a chartered engineer, an accredited certifier or an accredited assessor.
Riparian	Relating to land beside a river, creek or other watercourse.
RL	Reduced level. A height above a stated datum, such as AHD.
Screening distance	The distance from the lot boundary within which a mapped feature is reported as within buffer. In this report it is a platform screening setting, not a statutory requirement.
Section 10.7 planning certificate	A certificate issued by a NSW council listing planning controls and certain constraints that affect a lot. It is a primary source to confirm many of the layers in this report. It does not cover every matter (for example some watercourse, overland flow and transport noise issues).
Swale	A shallow, broad, usually grassed channel that carries and slows stormwater runoff.
UNRESOLVED	A requirement or value was not found in the cited sources. Nothing has been assumed in its place.
Within buffer	No mapped feature overlaps the lot, but one lies inside the screening distance from the lot boundary.
Zone	A land use category given to land by the local environmental plan. It decides which uses are permitted and with what consent.

10 / SECTION

Data sources and limitations

What data this run used, what it did not use, and who must check the result.

A. DATA SOURCES USED IN THIS RUN

DATA NOT AVAILABLE: no constraint layer could be queried in this run, so no constraint data source was used.

OTHER SOURCES	ATTRIBUTION	DATE	LICENCE NOTE
Aerial imagery	Imagery: NSW Spatial Services © Department of Customer Service 2020 (includes third-party imagery: AAM, Jacobs Group Ausimage, LANDSAT)	18/10/2011	Licence terms not stated in service metadata: verify terms before commercial use.
Lot boundary (cadastre)	Boundary geometry supplied to this run. OFFLINE FIXTURE, not live data. Publisher and date: SOURCE NOT RECORDED. Indicative, not a survey.	-	
Ground levels (DEM)	NSW_5M_Elevation ImageServer exportImage. DFSI 2019 (as stated by service copyrightText; no licence text published in service metadata)	-	
Council requirements	Cited line by line in the Council requirements section. Documents: Gunnedah Shire Council Development Control Plan 2025; Gunnedah Shire Council Engineering Design Minimum Standards for Subdivisions and Developments; NSW Planning Portal: BASIX; NSW Planning Portal: BASIX Water section. Extracted automatically.	-	

Report date: 14/10/2026. Run flags: OFFLINE FIXTURE. Development type is recorded only as a run setting used to select requirement sets; no building has been assessed.

B. METHOD

- The lot boundary is intersected with each mapped layer in metric map grid coordinates. INTERSECTS means a mapped feature overlaps the lot.
- WITHIN BUFFER means no overlap, but a mapped feature lies inside the screening distance measured from the lot boundary. See Buffers explained.
- NOT INTERSECTED BY THE DATA LOADED means no feature was found on or within the screening distance of the lot, in that layer only. NOT CHECKED means the layer could not be queried.
- Requirement values appear only when cited to a document. Otherwise the item is shown as UNRESOLVED. Platform defaults and user entered values are labelled ASSUMED / PLATFORM DEFAULT where they are shown.
- Figures show the lot over aerial imagery where available, with mapped features clipped to the figure window.

C. RESOLUTION AND CURRENCY CAVEATS

- Ground levels come from a 5 m DEM where one was loaded. A 5 m grid is coarse for a small lot and cannot show small level changes. Commission a detail survey before relying on any level.
- The aerial date is shown on each figure. Where the date is not published it is not assumed, and the image may be years old.
- Cadastral boundaries are indicative. Mapped features have their own positional accuracy, which is not stated in the data loaded.

D. WHAT WAS NOT CHECKED

- Layers not queried in this run: flood planning area; bush fire prone land; heritage item; heritage conservation area; acid sulfate soils; biodiversity values; coastal wetlands; riparian land and watercourses; land reservation acquisition; airport noise and obstacles; mine subsidence district; contaminated land; road and rail corridors; state policy land application; urban release area; minimum lot size; maximum building height; floor space ratio. Not checked is not clear.
- Not covered at all: easements, covenants, underground services, council flood studies, local council overlays and DCP maps, unless stated in a result above.
- Not assessed: any building, footprint, floor level, setback or approval pathway.

> Not checked is not clear. A layer marked NOT CHECKED could not be queried, so the site may well be affected. It must be checked with the council before design or purchase decisions are made.

E. SIGN OFF AND QUALIFIED PERSON

- This report was produced by software using public map data and the inputs listed above. No person has checked or certified it.
- A qualified person must check and verify every result, source and figure before any use. Matters that need professional sign off include boundaries (registered surveyor), flood and drainage (qualified engineer), bushfire (qualified assessor), soils and ground (qualified geotechnical engineer) and approvals (council or an accredited certifier).
- Where a requirement is shown as UNRESOLVED, or a layer as NOT CHECKED, the matter remains open and must be confirmed with the authority.

AI GENERATED DRAFT. NOT CHECKED OR CERTIFIED. MUST BE CHECKED AND VERIFIED BY A QUALIFIED PERSON BEFORE ANY USE.

F. ACKNOWLEDGEMENTS

Acknowledgements given by the user (Terms and Conditions, Schedule A) before this report was produced.

REF	ACKNOWLEDGEMENT
A1	I acknowledge that the underground service information shown is indicative only and that, before any excavation, I must obtain current BYDA plans from the asset owners and have all services physically located (for example by potholing or other non-destructive methods), with all work health and safety responsibility remaining with me.
A2	I acknowledge that the setbacks and planning controls shown were extracted automatically from council documents, may be wrong or out of date, and that I must verify them against the current LEP, DCP or planning scheme (including overlays and performance-based provisions) and with the relevant council before relying on them.
A3	I acknowledge that cut and fill volumes are indicative estimates based on third-party terrain data and assumptions, and are not to be used for pricing, ordering or earthworks without independent verification by a qualified surveyor or engineer.
A4	I acknowledge that retaining wall outputs are indicative only, are not structural or geotechnical design, rely on assumed soil and loading conditions, and that any wall over 1.0 m (and any other wall as required) must be designed by a suitably qualified engineer.
A5	I acknowledge that the driveway crossover check is a preliminary screening only, is not certified compliance with AS/NZS 2890.1, and that council engineering standards and approval requirements govern.
A6	I acknowledge that the cadastral boundaries shown are indicative and are not a survey, and that I must obtain an identification survey from a registered surveyor before relying on boundary positions.
A7	I acknowledge that the alignment of my uploaded plans is only as accurate as the plans I provided, may be affected by scale, print-to-fit or mirroring errors, is not a survey set-out, and that the architect or designer remains responsible for the plans and their current revision.
A8	I warrant that I have all rights, licences and consents (including client and confidentiality consents) to upload this material and to allow the Operator and its service providers, including AI providers that may be located overseas, to process it.
A9	I acknowledge that the rainwater tank and hydrology outputs are indicative only, are not engineering design or certification, and that BASIX or Queensland Development Code compliance certificates and any stormwater approvals remain my responsibility.

G. LEGAL STATEMENT

> This report is informational and indicative only. It is not a planning certificate under section 10.7 of the NSW Environmental Planning and Assessment Act 1979, and it is not a council property or planning report. Mapping data may be out of date, incomplete or inaccurate, and cadastral boundaries are not a survey. Verify every matter with the relevant council and authority, and use a registered surveyor, a qualified engineer and an accredited certifier where their sign-off is needed.