

INSPECTION REPORT - Q3

Facility: Plant Alpha

Date: 2026-08-30

Inspector: John Doe

Findings: The primary pressure vessel shows minor surface corrosion, well within acceptable limits. All safety valves passed calibration testing. Pump-A flow rate is slightly degraded (10% below nominal) and should be scheduled for routine maintenance in the next shutdown cycle. No critical hazards detected.