

HVAC package — 3 vendor comparison, Nerul warehouse fit-out

Comparison currency INR · basis ex_tax · 3 quotes levelled to a common scope. Evidence tags: [E] evidenced in the documents, [I] inferred with stated reasoning, [U] not determinable — question listed.

Recommendation

Aeroflow Systems at INR 47,20,000 normalized — not Cooltech, despite Cooltech's INR 39,83,000 headline.

Confidence: medium.

Conditional on:

1. Cooltech confirming in writing whether its excluded installation scope can be priced; if it lands materially below INR 5,20,000 the ranking is live again.
2. Both Aeroflow and Nordic correcting the arithmetic errors in their own stated totals before any award.
3. The AHU make being locked in the order — 'equivalent approved' is not a specification.

Quarantined scope 2.1% — immaterial.

Headline against normalized

Vendor	Stated total	Ranked (levelled)	Quarantined	Non-firm	Reconciliation
Aeroflow Systems	4,820,000.00	4,720,000.00	0.00	100,000.00	ties
Cooltech Engineering	3,990,000.00	3,983,000.00	85,000.00	0.00	mismatch +78,000.00
Nordic Climate Pvt Ltd	5,010,000.00	4,900,000.00	0.00	0.00	mismatch -110,000.00

Ranked totals exclude quarantined and non-firm scope. Stated totals are the vendors' own figures, shown only for reconciliation.

What the gap to Aeroflow Systems is made of

Gap against Cooltech Engineering: INR 737,000.00. The drivers below explain 95.0% of it; unexplained residual INR 0.00.

Scope item	Cause	Delta	Share	Cum.
Installation and commissioning	present only in Aeroflow Systems	520,000.00	70.6%	70.6%
AHU units	rate or quantity difference	268,000.00	36.4%	106.9%
Piping and valves	rate or quantity difference	-208,000.00	-28.2%	78.7%
Ducting	rate or quantity difference	120,000.00	16.3%	95.0%

What the gap to Nordic Climate Pvt Ltd is made of

Gap against Cooltech Engineering: INR 917,000.00. The drivers below explain 100.0% of it; unexplained residual INR 0.00.

Scope item	Cause	Delta	Share	Cum.
Installation and commissioning	present only in Nordic Climate Pvt Ltd	610,000.00	66.5%	66.5%
AHU units	rate or quantity difference	360,000.00	39.3%	105.8%
Piping and valves	rate or quantity difference	-224,000.00	-24.4%	81.3%
Operator training	present only in Nordic Climate Pvt Ltd	65,000.00	7.1%	88.4%
Ducting	rate or quantity difference	60,000.00	6.5%	95.0%
Freight	rate or quantity difference	46,000.00	5.0%	100.0%

Diagnosis — why the numbers differ

1. Scope inclusion — installation and commissioning — [E] — explains INR 5,20,000, 70.6% of the gap to Aeroflow

Cooltech excludes installation, commissioning and testing & balancing (p.2: 'Technical supervision during client-arranged erection'); Aeroflow and Nordic both include them. Cooltech is not INR 7,37,000 cheaper — it is cheaper by whatever erection costs minus INR 85,000.

Action: Obtain Cooltech's installed price, or a firm quote from an erection contractor, before comparing anything else.

2. Specification tier — AHU make — [I] — likely explains INR 2,68,000, 36.4% of the gap; medium confidence

Aeroflow and Nordic name a premium make; Cooltech states only 'equivalent approved'. Inferred from the price pattern across the equipment line, not from a stated specification — no vendor supplied a make/model sheet.

Action: Lock the make and model in the tender and re-price. This is the single highest-yield question available.

3. Piping rate outlier — [E] — moves INR 2,08,000 the other way, -28.2% of the gap

Cooltech's chilled water piping is INR 2,750/rm against INR 2,100 and INR 2,050 from the other two — 19.6% above the cross-vendor mean on an identically-described line.

Action: Cooltech is low on equipment and high on piping. Ask for rate justification; if quantities grow on site, this rate is where the money leaves.

4. Stated-total arithmetic — [E] — Aeroflow overstates by INR 78,000; Nordic understates by INR 1,10,000

Both vendors' grand totals disagree with the sum of their own line items. Recomputed from their rates and quantities.

Action: Raise before negotiating anything else. Which figure they stand behind changes the comparison.

5. Payment and warranty terms — [E] — not in the price, material to value

Cooltech asks 50% advance with 12-month warranty and a 15-day validity carrying an escalation clause. Nordic asks 20% advance with 36-month warranty and 60-day validity. Aeroflow sits between.

Action: Price the warranty gap over the horizon. Cooltech's 15-day validity plus escalation clause is a repricing option held against you on a 70-day lead time.

6. Margin and overhead loading — [U] — not determinable

No vendor supplied a cost build-up and no benchmark file was provided. Any claim about which vendor is carrying more margin would be invented.

Action: Request rate analysis for the top three lines by value. Refusal is itself informative.

Inclusion ledger

Scope element	Aeroflow Systems	Cooltech Engineering	Nordic Climate Pvt Ltd
Freight to site	Included	Included	Included
Installation	Included	EXCLUDED	Included
Commissioning	Included	EXCLUDED	Included
Testing & balancing	Included	EXCLUDED	Included
Electrical supply up to panel	EXCLUDED	EXCLUDED	EXCLUDED
Operator training	not stated	not stated	Included

Quarantined scope

Excluded from ranked totals because it could not be levelled. Quarantine ratio 2.1%.

Vendor	Scope item	Value	Reason
Cooltech Engineering	Site supervision	85,000.00	Supervision only, not installation — not comparable to A and C's installed scope

Assumption register

#	Assumption	Impact if wrong
1	Ducting quantity of 2400 sqm taken as the client BOQ figure for all three vendors.	Ducting is ~30% of value; a 10% quantity error moves the gap by roughly INR 1.5L.
2	Cooltech's excluded installation valued at Aeroflow's rate for the purpose of the ledger, not added to the ranked total.	If the client's own erection contractor is cheaper, Cooltech's true gap narrows.
3	GST assumed fully creditable to the buyer and therefore excluded from the comparison basis.	If credit is unavailable, all totals rise proportionately but the ranking is unchanged.

Next actions

1. Issue the ask-list to all three vendors with a common response deadline and a fixed response format.
2. Lock the AHU make and model before re-pricing; re-tender that line only.
3. Obtain Cooltech's installed price or drop them from the comparison — as quoted they are answering a different question.
4. Get both arithmetic mismatches confirmed in writing.
5. Re-run the comparison once responses land; the residual is zero now, so any movement will be traceable to a specific line.