

Mini-Torus Controls

Power Supply Controls

PS CMD OFF

PS CMD ON

PS RESET

Power Supply Status

NOT IN REMOTE MODE

Current Set 0.00 Amps

Current ReadBack 0.00 Amps

Voltage ReadBack 0.00 V

DAC ReadBack 0.00

Ramp Rate 40 Amps/Sec

Setpoint Wait Time 0

Interlocks and Alarms

Remote Mode

Input Power Fault

Firing Circuit Fault

ZPCT Fault

Local Stop/Open Door Fault

Xmfr/Thy Overtemp Fault

Over Current Fault

Over Voltage Fault

Ground Fault

Power Failure Shutdown

LCW Fault

External Safety Interlock

Voltage Limit Warning

Serial Communication Status