



KBE/SHIVRATNA/ 27 /13-14

Date: 12/04/2013

TO WHOM SO EVER IT MAY CONCERN

To

M/S. ANPAM ENGINEERING,

9/1, A-7, Kumaramangalam Infil, Estate,

Mathur - 622515, Pudukkottai District,

Tamil Nadu.

Kind Attn: Mr. A.P.Maheshwara

Dear Sir,

Sub: Performance Certificate for Start-up Vent Silencer

Ref: PO No. : 5500000055 dated 25/10/2012 & Vendor Code - 85411138

This is to certify that the Design, Engineering, Manufacturing, Supply of Start-up Vent Silencer by M/S. ANPAM ENGINEERING has been received and working satisfactorily. The Silencer confirms to all technical details stipulated. The noise level after installation has brought down to 85 dBA, against a guaranteed Noise level of 90 dBA.

KAY BOUVET ENGINEERING LTD

AUTHORIZED SIGNATORY