

TIN: 28440173745

APGST.No.KDA/05/2/1463 Dt. 27-10-1957

CST.No.KDA/05/2/1158 Dt. 27-10-1957

Grams: SARVARAYA

STD Code: 91-08837

FAX No.: 242369

Office: 242701 to 242708

e-mail: ssdhd_rmta@sarl.in

Sri Sarvaraya Sugars Limited

CHELLURU - 593 261

Rayasani Mandal,

East Godavari Dt. A.P.

TO WHOM SO EVER IT MAY CONCERN

Ref: 2862

5 March 2013

To

M/S. ANPAM ENGINEERING,

9/1, A-7, Kumaramangalam Indl. Estate,

Mathur - 622515, Pudukkottai District.

Tamil Nadu,

Kind Attn: Mr. A.P.Maheshwara

Dear Sir,

Sub: Performance Certificate for Steam Exhaust Silencer - Reg.

This is to certify that the design, engineering, manufacturing, supply of **Steam Exhaust Silencer for Steam Line** by **M/S.ANPAM ENGINEERING** has been received and working satisfactorily. The Silencer confirms to all technical details stipulated. The noise level after installation has **brought down to 85 dBA**, against a guaranteed Noise level of 90 dBA.

for **SRI SARVARAYA SUGARS LIMITED**


General Manager

