

BFP BRIEFING AND INSPECTION



College of Engineering



Non-serviceable Automatic
Fire Sprinkler System & Control panel



Non-serviceable and defective wet standpipe



Lack of Exit Signages



Non-serviceable jockey
pump and fire pump



Obstructed hallway



Exposed wires

Engineering and Technology Complex



Unplugged and defective emergency light



Non-illuminated exit sign



Obstructed hallway


College of Economics and Business Administration



Lacking of Fire
Extinguisher



No evacuation plan



Blocked exit door

Old College of Arts and Social Sciences



No exit signage



No emergency lights



Fire extinguisher not
mounted on the wall

College of Science and Mathematics



Poor illumination on the stair
at the museum



Non-pressurized fire
extinguisher




No proper ventilation of the
fuel lines



No proper storage of the
Chemicals



No exit signage and
emergency lights



Fire escape ladder is not
based on the standard

College of Computer Studies



Non-serviceable elevator



Defective fire alarm



Utility rooms w/out
floor/concrete slab