g		GE Energ	у	Functional T	esting Spe	ecification	
	Parts & Repair Services Louisville, KY			LOU-G	LOU-GED-DS200SVAA		
	Test Procedure for a DS200SVAA card						
	MENT REVISION STATUS	: Determined by the last	entry in the "REV" an				
REV.		DESCRIPTION			GNATURE	REV. DATE	
Α	Initial release, trans	ferred from GEDS Sal	em procedure	C	C. Wade	3/30/2012	
В							
С							
	YRIGHT GENERAL ELECT						
PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.							
C. Wa	ARED BY ade	REVIEWED BY	REVIEWEI	D BY	Charlie Wa		
3/30/2	2012	DATE	DATE		DATE 3/30/2012		

	g	
LOU-GED-DS200SVAA	GE Energy	Page 2 of 3
REV. A	Parts & Repair Services	
	Louisville, KY	

1. SCOPE

1.1 This is a functional testing procedure for a DS200SVAA voltage attenuator Card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - 4.2.1.3 Components visually damaged
 - **4.2.1.4** Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		10.0VDC Power Supply

LOU-GED-DS200SVAA REV. A **GE Energy**Parts & Repair Services
Louisville, KY

Page 3 of 3

6. Modifications/Upgrades

6.1 Fill out if applicable.

7. Testing Process

7.1 Setup

7.1.1 Verify that no shorts exist between adjacent traces.

g

- **7.1.2** Verify that all parts shown on the silk-screen are present.
- **7.1.3** Verify that all leads are properly soldered and connections are properly filleted and clipped.
- **7.1.4** Verify all saddle clamp (qty. 8) screws are tightly screwed down.
- **7.1.5** Connect +10.000 VDC to PT-11 and connect common (or -) to PT-17 Verify the voltage is between minimum and maximum listed below:

From	То	Minimum	Maximum
SC1	SC2	10.0V	10.0V
PT-12	PT-18	10.0V	10.0V
PT-13	PT-19	7.95V	8.143V
PT-14	PT-20	6.1V	6.284V
PT-15	PT-21	4.3V	4.424V
SC3	SC4	4.3V	4.424V

7.1.6 Connect +10.000 VDC to PT-31 connect common (or -) to PT-37. Verify the voltage is between minimum and maximum listed below:

From	То	Minimum	Maximum
SC5	SC6	10.0V	10.0V
PT-32	PT-38	10.0V	10.0V
PT-33	PT-39	7.95V	8.143V
PT-34	PT-40	6.1V	6.284V
PT-35	PT-41	4.3V	4.424V
SC7	SC8	4.3V	4.424V

7.2 ***TEST COMPLETE ***

8. Notes

8.1 None at this time.

9. Attachments

9.1 None at this time.