



GE Energy

Functional Testing Specification

*Parts & Repair Services
Louisville, KY*

LOU-GENEVA-IS200EDGMH1

Test Procedure for an IS200EDGM1 card.

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	R. Johnson	10/2/2012
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY R. Johnson	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 10/2/2012	DATE	DATE	DATE 10/2/2012

Functional test procedure for an IS200EDGMH1 card tested on the GENRAD® GENEVA system

1. SCOPE

1.1 This is a functional testing procedure for the IS200EDGMH1A circuit boards.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information.

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection


4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

- 4.2.1.1 Wires broken or cracked
- 4.2.1.2 Terminal strips / connectors broken or cracked
- 4.2.1.3 Loose wires
- 4.2.1.4 Components visually damaged
- 4.2.1.5 Capacitors leaking
- 4.2.1.6 Solder joints damaged or cold
- 4.2.1.7 Circuit board burned or de-laminated
- 4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	H188912	GENRAD Geneva Test System
1	H190034	IS200EDGMH1A Test Fixture

LOU-GENEVA-IS200EDGMH1 REV. A	 GE Energy <i>Part & Repair Services</i> Louisville, KY	Page 3 of 3
----------------------------------	--	-------------

6. Testing Process

6.1 Setup

6.1.1 Install fixture H190034 onto Geneva test System.

6.1.2 Install UUT into test fixture.

6.2 Testing Procedure

6.2.1 Load appropriate test program and follow instructions on screen.

6.3 *****TEST COMPLETE*****

7. Notes

7.1 Changes to the electronic GENEVA test are recorded in the following directory;

C:\Geneva Info\Geneva, file name is "Geneva Test Fixture Notes".

8. Attachments

8.1 None at this time.