P3K-AL-0012

CONT ON SHEET

REVISIONS

P3K-AL-0012

CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD WITH 2-SLOPE DIODE FUNCTION GENERATOR

CONT ON SHEET 2

FIRST MADE FOR

TITLE

### GENERAL DESCRIPTION

Fig. 1 shows a schematic circuit diagram of the PREAMPLIFIER FUNCTION BOARD with a 2-SLOPE DIODE FUNCTION GENERATOR which is called subsequently simply function board. The function board receives one input  $(E_L)$  from the load control unit and another one  $(E_{\overline{F}})$  from the SADI-board, (Servo Amplifier, Demodulator, Indicator). The signal  $E_{\underline{L}}$  at the load control input represents load demand (or flow demand); and varies from Ov to +5v. The input from the SADI board is the feedback signal  $\mathbf{E}_{\mathbf{F}}$  representing actual valve position which also varies from +5 to 0 volt. There is a separate SADI board for each function board.

The voltage definition of the signals  $E_{\overline{F}}$  and  $E_{\overline{L}}$  with respect to value position are as follows:

corresponds during steady state to valve closed at cracking point.

corresponds during steady state to valve wide open.

corresponds to/valve closed at gracking point. E<sub>17</sub> = 45v

En = Ov corresponds to valve wide open.

The feedback signal Ep feeds a resistor-diode network also known as diode function generator (DFG). (Fig. 1) which generates a 2-slope linear approximation to the valve characteristic (stem-lift versus flow).

As long as the inverting operational amplifier (op. amp.) operates in its linear range, it will try, due to its high gain (approx. 100 000 at Ocps) and negative feedback, to keep the summing junction SJ at a very

right 1983 generál Electric Co.

T.B. White, Sept. 29,

Steam Turbine Schenectady, N. Y.

P3K-AL-0012

LOCATION CONT ON SHEET 2


ISSUED OCT 1 0 1969

DIV OR

FF-805-WA (8-60) PRINTED IN U-S-A-

4

4



CONT ON SHEET TITLE CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD P3K-AL-0012 WITH 2-SLOPE DIODE FUNCTION GENERATOR SH NO. FIRST MADE FOR

1.0 (Continued)

+

REVISIONS

small voltage  $E_{\rm SJ}$  (approx. 50 uv). Therefore, the current  $I_{\rm L}$  is practi-

cally determined only by  $E_L$ .  $(I_L = E_L/R_I)$ . Similar considerations hold for the other currents  $I_B$ ,  $I_F$ ,  $I_{FB}$  which feed the summing junction SJ. Since the voltage  $E_{SJ}$  is so small, the current  $I_{SJ}$  that flows into the op. amp., will also be very small (approx. 50 pa). Therefore, the op. amp. feedback current  $I_{\mbox{\scriptsize FB}}$  will be equal to the algebraic sum of all other currents contributing to the summing junction; i.e.,  $I_{FB} = I_L + I_F + I_B$ . The output error voltage  $E_{OUT} = R_F * I_{FB}$  will be proportional to the algebraic sum of the currents feeding the summing junction from outside (i.e., currents other than op. amp. feedback current) into the summing junction. Since there is a 5% mechanical bias in the servovalve in closing direction the voltage EOUT will be -0.25v in the steady state; i.e., actual valve position is equal to desired valve position. An error voltage EOUT (more positive)/than -0.25v actuates the valve in closing direction and a voltage EOUT (less positive)/than -0.25v actuates the valve in opening direction. The bias current IB (Fig. 1) is used to cancel the LVDT-off-set (Linear Variable Differential Transformor). Part of this bias is also used to produce the error voltage signal of  $E_{OUT} = -0.25v$  during steadystate at the board output EOUT. When this board is used in a valve set where valves open sequentially, a part of this bias current is additionally used to allow sequential valve opening. This sequential bias current IB SEQU Will keep the error voltage EOUT positive (keeping the valve closed) until the load control voltage E reaches a certain value between Ov and +5v at which the sequential bias will be overcome.

ET-273 273-71

273-2

<u> 273-138</u>

R2*H* PRINTS TO

Made By T.B. White Sept. 29, 169 OCT 1 0 1969

DIV OR Steem Turbine. Schenectady, N. Y.

APPROVALS

P3K-AL-0012 LOCATION CONT ON SHEET 4

As an example

SH NO. 3

CODE IDENT NO.

PP-663-WA (8-66)

÷

P3K-AL-0012

**REVISIONS** 

TITLE P3K-AL-0012 5

CONT ON SHEET 5 CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD WITH 2-SLOPE DIODE FUNCTION GENERATOR

FIRST MADE FOR

#### 1.0 (Continued)

+


+

the number two control valve is to start opening when the load control input  $E_{L}$  reaches  $E_{LMIN} = +1.800$  volt.

The bias current  $I_{\overline{B}}$  will be adjusted such that the error signal  $E_{\overline{OUT}}$  is -0.25 volt when  $E_{L} = +1.8v$ . Further increases of  $E_{L}$  will cause the error voltage EOUT to go more negative to open the number two control valve.

At the output of the op. amp. (Fig. 1) there is a diode which together with the -22v network on the right hand side of the op. amp. R3, RI4, RIO and the dashed resistor R SADI (since it is located on the SADI BOARD) determines the maximal opening rate. This circuit is sometimes called a hard limit in opening direction. During a valve test the NO contact KF is closed and makes the opening rate limit voltage level positive. Thus, the valve will close.

#### 1.1 TEST SET-UP FOR SLOPE - ADJ.



NOTE: Make sure digital voltmeter (DVM) reads zero when input terminals are shorted. If not, adjust DVM.

FIG. 1: Test Set-up for variable resistance adjustment.

The test set-up as shown in Fig. 1 can be used for the adjustment of all two slopes. During these adjustments the circuit board has to be disconnected. Notice that the PLUS-side of the variable power supply is connected to the 1 terminal.

T.B. White Sept. 29.

DIV OR Steam Turbine

P3K-AL-0012

CODE IDENT NO.

ян No. 4

73-138 RAA

PRINTS TO

Schenectady, N. Y. LODATION CONT ON SHEET

PRINTED IN USIA

GENERAL & ELECTRIC

P3K-AL-0012

CONT ON SHEET 6

REVISIONS

P3K-AL-0012

CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD WITH 2-SLOPE DIODE FUNCTION GENERATOR

CONT ON SHEET

SH NO. 5

FIRST MADE FOR

TITLE

1.2 M1 - SLOPE ADJ. (LOWER SLOPE)

- 1. Set switch SW to A position.
- 2. Adj. variable voltage source until voltmeter reads voltage  $V_1$ .
- 3. Connect terminal 1 with TP7 (BLUE). (TP means Test Point).
- 4. Connect terminal 2 with TP3 (NAT).
- 5. Set switch SW to B position.
- 6. Adj. M1 potentiometer R7 until ammeter reads current I1.

### 1.3 M2 - SLOPE ADJ. (UPPER SLOPE)

- 1. Set switch SW to A position.
- 2. Adj. variable voltage source until voltmeter reads voltage V2.
- 3. Connect terminal 1 with TP3.
- 4. Connect terminal 2 with TP4.
- 5. Set switch SW to B position.
- 6. Add. M2 potentiometer R4 until ammeter reads current I2.

R JA

PRINTS TO

White Sept. 29, 169 OCT 1 0 1969

Steam Turbine Schenectady, N. Y.

DIV OR

P3K-AL-0012

PHINTED IN U.B.A.

LOCATION CONT ON SHEET

CODE IDENT NO.

6H NO. 5

# GENERAL & ELECTRIC

P3K-AL-0012

P3K-AL-0012

CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD

WITH 2-SLOPE DIODE FUNCTION GENERATOR

NT ON SHEET 7 SH NO. 6

+

FIRST MADE FOR

TITLE

REVISIONS

2.0 ADJUSTMENT OF OP. AMP. FEEDBACK RESISTORS

With the same arrangement as shown in Fig. 1 and the VPU-board disconnected, set the variable resistors in the op. amp. feedback path as follows:

- 1. Set switch SW to A position.
- 2. Adjust variable voltage source until voltmeter reads Voltage V4.
- 3. Connect terminal 1 with TP1 (WH).
- 4. Gonnect terminal 2 with TP3 (NAT).
- 5. Set switch SW to B position.
- 6. Adjust potentiometer R1 until ammeter reads current I4.

### 3.0 GENERAL TEST SET-UP

Fig. 3 and Fig. 4 represent an analog simulation of the <u>valve position</u> control system. Fig. 3 shows on the left hand side below the ramp generator which is used for the X-Y plot. At the top of Fig. 4 there is a voltage divider (29.4 Kohm, 500 Ohm) (POT 3) which represents the servovalve bias. The -Bv bias circuit (POT 4) is used to simulate the LVDT offset. Various switches are used to supply the test voltages to the preamplifier function board.

Fig. 2 shows the  $E_L$  -  $E_F$  characteristic for steady state. The  $E_L$  and  $E_F$  axis are so arranged, that the curve looks like the valve characteristic (stemlift versus flow).

ET-27.3

273-71

273-12

273-132

273-138

RAA PRINTS TO

T.B. White Sept. 29, 169

Steam Turbine Schenectady, N. Y.

DIV OR

P3K-AL-0012

ан нь. б

1//


MATERIA (STATES


4

LOCATION CONT ON SHEET 7

CODE IDENT NO.

GENERAL & ELECTRIC P3K-AL-0012 B, TREND INCO TITLE CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD P3K-AL-0012 WITH 2-SLOPE DIODE FUNCTION GENERATOR CONT ON SHEET 8 FIRST MADE FOR REVISIONS OE ... OPEN END I P. . . INTERCEPT POINT VOLT] CP... CRACKING POINT + M2-SLOPE (UPPERSLOPE) MI- SLOPE (LOWER SLOPE) ELMIN 4 The  $E_L$  -  $E_F$  STEADY-STATE CHARACTERISTIC 4 PRINTS TO White Sept. 29, 169 DIV ON Steam Turbine P3K-AL-0012 OCT 1 0 1969 Schenectady, N. Y. LOCATION CONT ON SHEET 8 8H NO. 7 PHINTED IN USIA CODE IDENT NO.





P3K-AL-0012

CONT ON SHEET 11

REVISIONS

P3K-AL-0012

CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD WITH 2-SLOPE DIODE FUNCTION GENERATOR

FIRST MADE FOR

TITLE

The valve position control system is made up of a function board, a SADI board, a servo-valve, a hydraulic cylinder, and an LVDT. This control system is also known as valve position unit (VPU).

#### 3.1 PRELIMINARY SETTINGS

+

- 1. Hook up board as per test set-up (Fig. 3 and 4). The recorder will not be used in the first part of the test. Insert board into connector.
- 2. Set S1, S2, S3, S4 and S5, S12, S13, S14 to the "A" position. Open \$7, S8, S10 and S11. Close S6 and S9. These settings represent the "RESET" state, from which all other settings will be defined.
- 3. Adjust POT 2 for -1.0v at BP15. (BP means Binding Post).
- Adjust POT\_3\_for\_+0.25v\_at\_BP16.
- Adjust POT 4 for -5 v at BP17.

## ADJ. OF OPENING RATE LIMIT

- 1. Verify that 422 volts are applied to pin 21 of function board and that pin 19 is grounded; e.g., connected to the PLUS terminal of 22v power supply.
- Adjust variable resistor R3 until voltage at TP1 (WH) reads VOP LIMIT

#### 3.3 ADJ. OF CLOSING RATE BIAS

- 1. Verify that +30v is applied to pin 17 of function board and -22v applied to pin 21 and ground pin 19 is connected with the common potential of +30v and -22v power supplies.
- 2. Connect pin 5 with pin 12.

273-138

ROA **PRINTS TO** 

T.B. White Sept. 29. '69 198UED OCT 1 U 1969

Steam Turbine

Schenectady, N. Y.

DIV OR

P3K-AL-0012

FF:803:WA (2:69) PN(NTED IN U.B.A.

+

LOCATION CONT ON SHEET 11

CODE IDENT NO.

APPROVALE

REVISIONS

NO.	<i>p</i> /
· '	
	P3K-AL-0012

TITLE

CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD WITH 2-SLOPE DIODE FUNCTION GENERATOR

FIRST MADE FOR

CONT ON SHEET

3.3 (Continued)

+

- 3. Adjust valve test closing into potentiometer R2 until voltage at TP1 (WH) reads V<sub>CL</sub> LIMIT\*
- 4. Remove lead that connects pin 5 with pin 12.

#### 3.4 EB BREAK POINT ADJUSTMENT

- 1. Set S4 to B position.
- <sup>2</sup>. Apply  $E_F = +6v$  at pin 18  $(E_F)$ .
- 3. Adjust EB potentiometer R5 until voltage at TP5 (GRN) reads  $E_{\rm p}$ .
- 4. Reset S4 to A position.

#### 3.5 BLAS ADJUSTMENT

- 1. Set 54 to B position.
- 2. If ELMIN = Ov, leave S5 in A position.

If  $E_{LMIN} \neq Ov$ , set S5 to B - position.

- 3. Apply  $E_p = +5v$  at pin 18  $(E_p)$ .
- 4. Apply  $E_{L} = E_{LMIN}$  at pin 36 ( $E_{L}$ ).
- 5. Open S6. Close S7 and S8.
- 6. Adjust bias pot R6 until voltage at pin 3 ( $E_{
  m OUT}$ ) reads -0.25v.
- 7. Reset S4 and S5 to A position.
- 8. Reclose S6. Reopen S7 and S8.

273-138

PRINTS TO

White Sept. 29. 169 OCT 1 0 1969

Steam Turbine

Schenectady, N. Y. LOGATION CONT ON SHEET 12

P3K-AL-0012

+

# GENERAL & ELECTRIC

P3K-AL-0012

P3K-AL-0012

CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD

WITH 2-SLOPE DIODE FUNCTION GENERATOR

CONT ON SHEET 13 SH NO. 12 FIRST MADE FOR

REVISIONS

### 3.6 CALIBRATION OF AUXILIARY AMPLIFIERS

(If several boards are tested in sequence, this procedure has to be done only for the first board test).

- Turn POT 4 down to bottom. Check voltage BP17 for 0 volts ± 5 mv.
- 2. Check voltage at BP18 for 0 volts  $\pm$  5 mv. If outside this range, adjust op.amp. A4 at zero adjustment.
- 3. Adjust POT 4 until it reads -5v at BP17 within ± 5 mv.
- 4. Abserve voltage at BP18. Adjust POT 5 until voltage at BP18 reads +5v within instrument accuracy.
- 5. Observe voltage at BP19. It should be  $0v \pm 5$  mv. If outside this range, adjust op. amp. A5 at zero adjustment.
- 6. Set switch S13 to B position.
- 7. Voltage at BP19 should read -5v within ± 5 mv. If not, adjust POT 6 until correct reading is obtained.
- 8. Reset switch S13 to A position.

### 3.7 RECORDING OF STATIC DFG-CURVE

- 1. Turn on recorder. Set function selector switch at STANDBY. Set sensitivity switch at 1 volt/inch on the X and Y inputs.
- 2. Turn POT 1 to bottom position and make sure voltage at BP14 is Ov ± 5 mv.
- 3. Insert curve sheet from engineering into X-Y PLOTTER.
- 4. Set zero adjustments on X and Y channel such that pen coincides with (Ov/Ov) position marked on the lower right hand side of the sheet.
- 5. Set switch S13 to B position. This should cause the pen to drive 5

R2A
PRINTS TO

MADE 87 White Sept. 29, '69 Steam Turbine DIV OR P3K-AL-0012

Schenectady, N. Y. LOCATION CONT ON SHEET 13 SH NO. 12

PRINTS TO

Schenectady, N. Y. LOCATION CONT ON SHEET 13 SH NO. 12

4

+

GENERAL & ELECTRIC P3K-AL-0012 TITLE CONT ON SHEET 14 SH NO. 13 CIRCUIT BOARD TEST FOR PREAMPLIFIER FUNCTION BOARD P3K-AL-0012 WITH 2-SLOPE DIODE FUNCTION GENERATOR CONT ON SHEET 14 FIRST MADE FOR SH NO. 13 REVISIONS 3.7 (Continued) inches to the left. If not, adjust gain of X-channel until this is the case. 6. Close switch Sll. Turn POT 1 upwards until BP14 reads +5v within  $\pm$  5 mv. This should cause the pen to drive 5 inches upwards. If not, + adjust gain of Y-channel until this is the case. Turn POT 1 downwards to the bottom. Reset switch S13 to A - position. Reopen switch S11. The pen should be now again at the (0v/0v) position. 8. Set S1, S2, S3 and S12, S13, S14 to B - position. 10. Close S7, S8 and S10. Open S6. Open S9. The plotter starts now plotting the curve. When it reaches the upper right corner the pen should be lifted first and then S9 should be closed. 12. If curve deviates too much, the DFG has to be readjusted. 13. If this is necessary: Open S10 and close S11. The pen can be moved manually along the curve by turning the knob of POT 1. Slope pots break point pots, and bias pot can be adjusted until plotted curve coincides with the curve supplied by engineering. Send final recorded trace up to EMC engineering (Bldg. 285, Rm. 241). Apply red paint on slope pot - and break pot adjustment screws. 16. NOTE: Write board serial number, signature and date on each XY trace. R⊅A

APPROVAL

Steam Turbine Schenectady, N. Y.

P3K-AL-0012

LOCATION CONT ON SHEET 14 SH NO. 13

White

Sept. 29, 169

OCT 1 (1 1869

+

DIV OR

PRINTS TO

30.72	MITH 2-SI MADE FOR Design E	ngineering	DATE 10	CONT ON SHEET  IFIER FUNC  NERATOR	TION BOA	ARD CLOP 27 UNK
PREPARED BY:  T. B. White Turbine Control  APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	0/7/6		25 000 35 000 000 000 000 000 000 000 000
T. B. White Turbine Control  APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	0/7/6	9-	EL 0) 2 C G 11
T. B. White Turbine Control  APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	7/7/6		01Cl 97 148
APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	0/7/6		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	0/7/6		3 CHAN
APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	7/7/6		
T. B. White Turbine Control  APPROVED BY:  P. C. Callan, M.	Design E		DATE 10	776	cy .	
APPROVED BY: P. C. Callan, M.	M. anager		DATE/C	17/6	<b>4</b>	
P. C. Callan. M.	anager Design E	ngineering	/	776	cy-	
P. C. Callan. M.	anager Design E	ngineering	/	17/6.	9- 12-1 11-70 12-12-13-13-13-13-13-13-13-13-13-13-13-13-13-	
P. C. Callan. M.	anager Design E	ngineering	/	17/6	9	
P. C. Callan. M.	anager Design E	ngineering	/	17/6	<i>G</i>	
P. C. Callan. M.	anager Design E	ngineering	/	776.	<u> </u>	
P. C. Callan, M Turbine Control	anager Design E	ngineering				₩ Parija Bilandaria
	-cordi El	drueering				***
	1	- H.				J
	537		1			- 1
		A (6)				
	*					
9				0.		
	3.					
		Ü				
Ŷ.						
25						-
						<u> </u>
			85			27
						27.
				*0	3*	27
1 A 12 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1						27
というない 日本教育などの教育などの教育を		89	80 Y			27
		1.	į.	KQ8.	atant i	
B. White Sept. 29, 169	.5	***************************************	***************************************	<u> </u>	Mary Jan J	PR
B. White Sept. 29, '69 OCTIO 1969	Steam	n Turbine	DIV OR	P3K-/	AL-0012	

+