g		GE Industri	al Systems	Functional Testing Specification				
	Renewal Services Louisville,KY			LOU-GED-7556D34				
Test Procedure for a Servo Amp FunctionCard								
DOCUM	MENT REVISION STATUS	: Determined by the last er	ntry in the "REV" ar	nd "DATE" colum	ın			
REV.		DESCRIPTION			SIGNATURE	REV. DATE		
Α	Initial release				Dan Laemmle	10/01/03		
В								
С								
© COPY	YRIGHT GENERAL ELECT	RIC COMPANY						
PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.								
	ARED BY aemmle	REVIEWED BY	REVIEWE	D BY	Rober o	ROVAL Dunll		
DATE 10/01/	/03	DATE	DATE		DATE 10/10/03	J. 34740 - 4		

LOU-GED-07556D34 REV. A

GE Industrial Systems Renewal Services Louisville, KY

Page 2 of 8

Functional test procedure for a 7556D34G1 Card

1. SCOPE

1.1 This is a functional testing procedure for a 7556D34G1 Card.

g

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.3.1.1

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.
- 4.2 Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken or cracked
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - **4.2.1.3** Loose wires
 - 4.2.1.4 Components visually damaged
 - 4.2.1.5 Capacitors leaking
 - 4.2.1.6 Solder joints damaged or cold
 - 4.2.1.7 Circuit board burned or de-laminated
 - 4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description	
2		Fluke 85 DMM (or Equivalent)	
1		Sinewave Generator 3 Khz	
1		Factory Test Fixture # 5.2.1.1	
1	H188540	GM 5005 Transducer	

GE Industrial Systems
Renewal Services
Louisville, KY

Page 3 of 8

LOU-GED-07556D34 REV. A

6. TESTING PROCESS

- **6.1** Setup
 - 6.1.1 Generator must be capable of supplying 6.0 v RMS at 3 Khz into the primary of T1. The shop Wavetek and Tenma Function Generator will not put out enough. Connect to J4 and J5 on Test Fixture.
 - **6.1.2** Connect +30Vdc and -22Vdc to Test Fixture. Connect Fluke meter on MA to J13 and J14
 - 6.1.3 Connect Transducer to Amp connector on Test Fixture. Top stop is with rod out 16.125 inches from transducer body. Bottom stop is 3.125 inches from transducer body.
 - **6.1.4** Follow Test Fixture setup and Test Instructions below.



- 6.2 Testing Procedure
 - **6.2.1** See attached sheets below.
- 6.3 ***TEST COMPLETE ***

	g	
LOU-GED-07556D34	GE Industrial Systems	Page 4 of 8
REV. A	Renewal Services	
	Louisville, KY	

7. NOTES

g

LOU-GED-07556D34 REV. A

GE Industrial Systems Renewal Services Louisville, KY

Page 5 of 8

MARK II TEST RECORDS Servo Amplifier APPLICATION P.C. BD. NO. BD. NO. SER. NO. 7486D72 G2 (PA) 8171628 7486D72 Gl(Func) 817D632 FBINE: 7556D34 G2 (PA) 8170628 7556D34 G1 817D632 ·· EQUIPMENT TEST: INSTRUCTIONS A-1077J13 DATE TRANSD. SN GM 5005 TREDSDUCER 1.0 INSPECTION 15" .l Identification .3 Solder/Wire Key Slot (19)PA .2 Comp./Conn. Temp. Cycle •6 (17)FUNC .7 REMARKS: Initial Conditions: INPUT 2 OFF; COMMAND SW at (+); Dials at 0.00. SERVO CURRENT sw. at 80 ma, VALVE POSIT. sw at 41, S5 (IND.). Equipment Checkout; First use each day; FB Transd. Stroke/Spec Preparation of Eds; Func. R20 and R26 CW, R12 and R15 no change. P.A. R121 CW, R108 Center; Plug both bds. in. 5.0 6.0 TEST PROCEDURES: TP's for PA Bd. in (). 7.0 7.1 Lower Gear Offset Adjustment: (Transducer 1" above Top Stop) Jump TP8 to TP5; Vary COMMAND for ERROR Z = 0. Remove jumper from TP8; Note TP8 = +0.28V + 0.05 = V7.1.2. 7.1.1 Note ERROR \leq = V7.1.2 xR6/R27 = x = - Rotate R26 CCW; Note TP8 = -0.60 + 0.05 = V7.1.4. Note ERROR \leq = V7.1.4 x R6/R27 = x = + Replace jumper TP8 to TP5; Note ERROR \leq returns to OV. •5 Check Other Gains: COMMAND at 0.00, Valve Pos. Transd. for ERROR £ = 0. Note ERROR ≥ = -(COM. GAIN) V COMMAND at +0.5V; 2 7.3 NULL Pos. FB Transd: Set Transd. 1" beyond Top Stop. Scope at TP4, Adj. R12 and R15 for null (less than 150 MV P-P). MV P Note UNREG. VLV. POS. OUTPUT = OV \pm 0.1. .4 Adjust Amplifier Zero: Adjust COMMAND for ERROR \(\mathbb{E} = \text{OV.} \) Adjust R113 for FIDELITY METER = 0. Adjust Amplifier Gain: Increase COMMAND for ERROR ≤ = -5V. •5 Note TP9 & (TP4) each -5V. Repeat 7.4 and 7.5 until no change needed. •6 Amplifier Linearity: Vary ERROR ≤ Voltage per Table. Adjust (R108) if necessary. ERROR 差 . V 0 -18.4 +1 +18.4 +50.4 Current -77.8 -45.6 -13.6 -1 +13.6 MA Observed Position FB Gain; Posit. transd. 1" above Top Stop. Adjust COMMAND for +5.38V. Adjust R121 for ERROR \leq = OV; Note (TP8) = -4.5V + 0.1. Position transd. 1" above Bot. Stop; COMMAND +0.38V. Adjust R2O for ERROR ≤ = OV. Note REG. VALVE POS. OUTPUT and $(TP5) = +5.000 \pm 0.10$ Note UNREG. VALVE POS. OUTPUT IS +6. 6 min.

g

10- 1-03; 2:15PM;GE |NDSYS

LOU-GED-07556D34 REV. A

GE Industrial Systems Renewal Services Louisville, KY

Page 6 of 8

	TOP 1-03: 2:16PM:GE TNDSYS	493 0640 # 2/ 2
Servo	Amplifier 5.2.1.2.04	- PAGE 2 -
· ·	*	
7	Note TP3 = UNREG. VAINE POS. OUTPUT.	
7.8	Valve Position Indicator Adjustment:	
1.0	Position Transducer at Bot. Stop; Adjust R131 for Zero.	
	Position Transducer at Top Stop; Adjust R125 for Full Scale.	·
8.0	Amplifier Noise Level: ERROR ≤ = OV.	
	Scope (TP2); Note Noise Level is less than 10 MV P-P	MV P-
9.0	Demodulator Output Wave Forms: (CR2 Bot) Scope on DC.	
.1	Note pos. full-wave rectified wave form decr. to 0 as transd.	is
•	extended beyond Top Stop to Sync. Posit.	
.2	Note neg. full-wave rectified wave form as transd. is extende	d farther.
10.0	Valve Position: Filter Output TP3; Scope at UNREG. Jack	
	Pos. Transd. at Bot. Stop; Note ripple and noise less than 60	MV P-P. MV P-
11.0	Additional Voltage Checks: (Command at +5.0V)	
.1	Funct. Bd. TP2 to JJ (6.6 to 7.0V rms) TP2 to J7 (11.0 to 11.6V rms)	<u>v</u>
		^
	R16R to R17R (22.5 to 23.5V rms)	
	TP4 to TP5, more than 16V P-P	+ V
•	TPll with COM = +4.99 to 5.01V P.A. Bd. CRIOLL to COM (-0.5 to -0.8V)	v
•2	P.A. Bd. CRIOLL to COM (-0.5 to -0.8V) R11OT to COM (-1.0 to -1.6V)	v
	R114L to COM (+14.2 to +15.8V)	v
	TP7 to TP3 (-5.2 to -6.0V)	<u> </u>
	TP10 to TP3 (+5.2 to +6.0V)	<u></u>
12.0	Temp. Coef. Check P.A. Bd:	
Z	Temps does direct time but	
(, ,	VM Cond. Cold Volts Heat at (30 se	<u>A Volts</u>
	TP9 Bot. Stop (+4.6 to +5.0) + V R126 (CR112	e) + lomv mv
	TP8 - (-4.4 to -4.6) - V R118 (CR109	

LOU-GED-07556D34 REV. A g

GE Industrial Systems Renewal Services Louisville, KY Page 7 of 8

Huse 317D605GI as DC amp - Sine ware

Need 7556D34G2 on something to Mode

to for Somo comp Pur, Bord. plot

(Bare bid. 817D628)

We have

Similar with arange tag

UUT in Servo. amp Function Brd.

+1

LOU-GED-07556D34
REV. A

GE Industrial Systems
Renewal Services
Louisville, KY

Page 8 of 8

8. Oscilloscope Verification Examples:

Fig. 1

Fig. 2