

g

GE Energy

Functional Testing Specification

*Parts & Repair Services
Louisville, KY*

LOU-GED-DS3820DOSx

Test Procedure for a Drop-in Operator Station


DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	David Smith	12-17-02
B	Added reviewer's name and change header and footer.	C. Wade	4/21/2009
C	Added asset number to DS3820DOS_ unit.	C. Wade	6/29/2010
D	Added steps to test communication card	Steve Pharris	10/19/11

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY David Smith	REVIEWED BY Steve Pharris	REVIEWED BY S. Pharris	QUALITY APPROVAL 
DATE 12-17-02	DATE 4/21/2009	DATE 10/19/2011	DATE 12-18-02

<p>LOU-GED-DS3820DOSx REV. B</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 2 of 5</p>
---	--	---------------------------

Functional test procedure for a Drop in Operator Station

1. SCOPE

1.1 This is a functional testing procedure for a operator station.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check electronic folder for more information.

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires broken or cracked

4.2.1.2 Terminal strips / connectors broken or cracked

4.2.1.3 Loose wires

4.2.1.4 Components visually damaged

4.2.1.5 Capacitors leaking or bloated

4.2.1.6 Solder joints damaged or cold

4.2.1.7 Circuit board burned or de-laminated

4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 85 DMM (or Equivalent)
1	H188924	DS3820DOS_ for testing customer's cards.
1		O-Scope
1		Function Generator
1		300 Ohm Resistor
1		DOSx Display Interface

<p>LOU-GED-DS3820DOSx REV. B</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 3 of 5</p>
---	--	---------------------------

6. TESTING PROCESS

6.1 Setup

- 6.1.1** If you are testing one of the cards that go into this unit, test and validate the unit first before inserting customer's card.

6.2 Testing Procedure

- 6.2.1** Disassemble unit completely
- 6.2.2** Replace all push button switches
- 6.2.3** Visually inspect DS3800HPIB card for corrosion.
- 6.2.4** Replace all electrolytic caps on DS3800NPZA.
- 6.2.5** Re-assemble unit but do not put cover on.
- 6.2.6** Place a jumper between TBAC2-3 and TBAC4-5
- 6.2.7** Apply 115VAC between TBAC 2 and 5
- 6.2.8** Verify IMOK led on DS3800DPZA card is on. Note delay then led will come on then go out then stay on solid after 3 to 4 seconds.
- 6.2.9** Check power supplies on DS3800NPZA card
- 6.2.10** Connect voltmeter between TP5 (+) and TP1 (-) verify 16 to 19.5 VDC
- 6.2.11** Connect voltmeter between TP2 (+) and TP1 (-) verify +5.00 VDC. If not correct adjust pot R18 on DS3800NPZA for +5.00 VDC.
- 6.2.12** Connect voltmeter between TP4 (+) and TP3 (-) verify +5.00 VDC. If not correct adjust pot R19 on DS3800NPZA for +5.00 VDC.
- 6.2.13** Remove power from unit.

CONTINUED BELOW

6.2.14 Please note the Push button chart below and verify test sequence.

27	25	23	21	19	17
28	26	24	22	20	18

29

1

30	14	11	9	7	4
31	15	12	10	6	3
32	16	13	8	5	2

Apply power to unit and verify the following self-test sequence.

1. All push button lights come on.
2. Push buttons 1-8 come on.
3. Push buttons 9-16 come on
4. Push buttons 17-24 come on
5. Push buttons 25-32 come on
6. All lights come on for 10 seconds then go out.
7. Press all switches individually and verify respective light illuminates.

6.2.15 Remove power

6.2.16 Remove the DPZA card and install a 300 Ohm Resistor across C9 on the NPZA card.

6.2.17 Reinstall DPZA card

6.2.18 Connect an O-Scope to TBDL-1 with common from scope attached to TBDL-12

6.2.19 Apply Power

6.2.20 Verify O-Scope displays a data pattern.

<p>LOU-GED-DS3820DOSx REV. B</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 5 of 5</p>
---	--	---------------------------

- 6.2.21 Move positive lead from scope to TBDL-2 and verify inverted signal from previous step.
- 6.2.22 Remove power
- 6.2.23 Remove DPZA and 300 Ohm resistor across C9 installed previously.
- 6.2.24 Remove O-Scope
- 6.2.25 Reinstall DPZA card
- 6.2.26 Connect function generator set for 1Khz at 3.85VRMS to TBDL-5 with respect to TBDL-12 but **DO NOT APPLY POWER TO FUNCTION GENERATOR.**
- 6.2.27 Apply power to UUT and wait for all lights to extinguish after self-test, just as before.
- 6.2.28 Apply power to function generator
- 6.2.29 Verify all lights on front panel illuminate and stay illuminated for approx. 30 seconds.
- 6.2.30 Remove power from function generator and UUT.
- 6.2.31 Move output from function generator to TBDL-6 with respect to TBDL-12 but **DO NOT APPLY POWER TO FUNCTION GENERATOR.**
- 6.2.32 Apply power to UUT and wait for all lights to extinguish after self-test, just as before.
- 6.2.33 Apply power to function generator
- 6.2.34 Verify all lights on front panel illuminate and stay illuminated for approx. 30 seconds.
- 6.2.35 Remove power from function generator and UUT.
- 6.2.36 Completely assemble unit.
- 6.2.37 Connect DOSx display interface to JB of DPZA card
- 6.2.38 Apply power to UUT
- 6.2.39 Verify during self-test display reads 77777.
- 6.2.40 Remove power from UUT
- 6.2.41 Remove DOSx display interface

6.3 *****TEST COMPLETE*****

7. **Notes**

- 7.1 DOSx display interface will display random data until self-test is almost finished and then change from 77777 back to random data.

8. **Attachments**

- 8.1 None at this time.