



GE Energy

Functional Testing Specification

*Parts & Repair Services
Louisville, KY*

LOU-GED-DS200TBQF

Test Procedure for a Transition Module

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Jeff Barton	08/31/15
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Jeff Barton	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL L. Groves
DATE 08/31/15	DATE	DATE	DATE 8/31/2015

<p>LOU-GED-DS200TBQF REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 2 of 3</p>
--	--	---------------------------

1. SCOPE

1.1 This is a functional testing procedure for a DS200TBQFG1B.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 **DS200TBQFG1B SH 4AA-4DA**

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		DC Power Supply

<p>LOU-GED-DS200TBQF REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 3 of 3</p>
--	--	---------------------------

6. TESTING PROCESS

6.1 Setup

- 6.1.1 Set power supply to ~26VDC
- 6.1.2 Connect (-) from power supply to C1 (-)
- 6.1.3 Connect (+) from PS to C1 (+)
- 6.1.4 Connect common from DMM to C1 (-)

6.2 Testing Procedure

- 6.2.1 Apply power to card
- 6.2.2 Check for +24VDC +/- .2VDC at the following points. TB37, TB38, TB43, TB44, TB49, TB50, TB55, TB56, TB61, TB62, TB67, TB68, TB73, TB74, TB79
- 6.2.3 Component check remainder of card

6.3 ***TEST COMPLETE***

7. NOTES

- 7.1 None at this time

8. ATTACHMENTS

- 8.1 None at this time