

g

GE Industrial Systems

Functional Testing Specification

*Renewal Services
Louisville, KY.*

LOU-GED-193X528XX

Test Procedure for: 193X528XXG01

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	<i>Jeffrey D. Barton</i>	3/17/2021
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Jeffrey D. Barton	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Robert D. Dwyer</i>
DATE 3/17/2021	DATE	DATE	DATE 07/09/02

Functional test procedure for: **193X528XXG01**

1. SCOPE

1.1 This is a functional testing procedure for a 193X528XX card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

2.1.1

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires broken or cracked

4.2.1.2 Terminal strips / connectors broken or cracked

4.2.1.3 Loose wires

4.2.1.4 Components visually damaged

4.2.1.5 Capacitors leaking

4.2.1.6 Solder joints damaged or cold

4.2.1.7 Circuit board burned or de-laminated

4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Non-Reversible Valutrol Drive
1		Oscilloscope
1		Oscilloscope Probe

<p>LOU-GED-193X528XX REV. A</p>	<p>g</p> <p>GE Industrial Systems Renewal Services Louisville, KY</p>	<p>Page 3 of 4</p>
-------------------------------------	---	--------------------

6. TESTING PROCESS

6.1 Setup

6.1.1 Connect Jumper from: CC to COM

6.1.2 Connect Jumper from: NT to CEMF

6.1.3 Install unit (IFC) in test system.

6.1.4 Connect all labeled interface wires:

6.1.4.1 RN

6.1.4.2 RP

6.1.5 Connect firing pulse interfaces:

6.1.5.1 White wire to: IN

6.1.5.2 Red wire to: IP

6.2 Testing Procedure

6.2.1 Connect Oscilloscope to LR and COM on MCC.

6.2.2 Adjust Oscilloscope to 2mS/DIV.

6.2.3 Release E-STOP button.

6.2.4 Using Diag. Card, switch from neutral to Static, (move switch to left).

6.2.5 Using SPEED REF. Pot, adjust LR for 0Vdc.

6.2.6 Connect Oscilloscope to CFB and COM on MCC.

6.2.7 Using CFB pot on Diag. Card, adjust CFB to 0Vdc.

6.2.8 Using Diag. Card, switch from Static to neutral (move to center position).

6.2.9 Connect Oscilloscope to VFB and COM on MCC.

6.2.10 Using Diag. Card, switch from neutral to RUN, (move to right position).

6.2.11 Using SPEED REF. pot rotate CW, (REVERSE Direction) and verify ALL (approx. 8 pulses are visible and amplitude adjusts to approximately to 10Vpp at maximum speed accordingly per SPEED REF. pot. **See Fig. 1 in Oscilloscope Verification Examples.**

6.2.12 Return SPEED REF. pot back to centered position so that all pulses disappear, (centered zero position).

6.2.13 Using Diag. Card, switch from Static to neutral (move to center position).

6.2.14 On Operator Station, switch to RUN position.

6.2.15 Adjust SPEED pot CW, on Operator Station and verify ALL pulses are visible and amplitude adjusts to approximately to 10Vpp at maximum accordingly per SPEED pot. **See Fig. 1 in Oscilloscope Verification Examples.**

6.2.16 Return SPEED pot CCW to 0.

6.2.17 On Operator Station, switch to STOP position.

6.2.18 Engage E-STOP Button.

6.3 *****TEST COMPLETE *****

7. **NOTES:**

8. **Oscilloscope Verification Examples:**

Fig. 1
Reverse Direction

