PENERAL 39 FIECIKIC

P3K-AL-0559-A01

CONT ON SHEET 2

P3K-AL-0559-A01

TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS Circuit ILI-U001 ASSY Drawing 137D6155G1

FIRST MADE FOR EHC Mark II LCU

X781/x623

I SCOPE

CONT ON SHEET . 2

+

sh No. 1

TITLE

REVISIONS

This instruction outlines the test specifications for circuit board 1L1-U001 (Ref. Drwg 137D6155). System Schematic 137D6131.

Circuit Description

The purpose of the CV test Bias circuit is to combine the speed error, load reference, and stage pressure signals and continuously compute a test bias signal which is applied to the CVA to provide a zero transfer error when switching in stage pressure feedback for control valve testing. This test bias signal will cause the CV flow reference signal, Ep, to be the same before and after stage pressure feedback is switched in. Subsequent changes in the stage pressure signal due to the tested valve being closed will cause E_{L} to change and open the appropriate control valves during valve test. The bias signal is removed from the input of the CVA simultaneously with the removal of SPFDBK upon completion of a control valve test (after dropout of 15 secTDDOrelay). The logic circuitry will inhibit the application of the CV Test bias signal when the SPF transfer circuit is in "MANUAL" or Auto mode.

The summing operations are accomplished with an operational amplifier referred to as IC1. The output of IC1 is the input to the sample/hold amplifier IC3. The switching of IC3 from sample to hold is provided by IC2. When pin 17 is grounded IC3 will be in the sample mode. Removing pin 17 from ground will switch IC3 from sample to hold mode.

> 273-2 273-12°

273-221

273-227 $273 - 71^{2}$

PRINTS TO

June 2, 1977 APPROVALS MADE BY J. Polacek 1311 JUN Z ISSUED

Steam Turbine Schenectady, N.Y.

P3K-AL-0559-A01

LOCATION CONT ON SHEET 2

SH NO. 1

Output Loads

(Pin 12)

- 1. Load 1: 133K Ohm ± 1% (Max. load) (Pin 34)
- 2. Load 2: (Pin 32)
- 3. Load 3: $500K \pm 1\%$ VC(Std) (Pin 33)

82

+

REV (

P3K-AL-0559-A01

В.

3

SH NO.

CONT ON SHEET

PRINTS TO

J. Polacek APPROVALS June 2, 1977 P3K-AL-0559-A01 DIV OR Steam Turbine _____DEPT. ISSUED JUN 2 1977 Schenectady, N.Y. LOCATION CONT ON SHEET 3 sh No. 2

FF-803-WA (2-75) PRINTED IN U.S.A.

CODE IDENT NO.

P3K-AL-0559-A01 4 CONT ON SHEET sh No. 3 REY () TITLE TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS P3K-AL-0559-A01 CIRCUIT 1L1-U001 (Assembly Dwg. 137D6155 G1) FIRST MADE FOR EHC MARK II (LOAD CONTROL UNIT) X781/X623 CONT ON SHEET 4 REVISIONS Offset Adjustment Procedure for IC3 Zero ICI by grounding all inputs. Adjust VR51 for zero at TP8. Jumpee 10, 11, 12 to ground. The offset adjust pot VR50 should be adjusted with zero at TP8. During the adjustment, the sample/hold should be switching continously between the sample and hold mode. This can be accomplished by switching pin 17 to pin 16 (open & closed). The error at TP9 should then be adjusted to zero with pin 17 open and IC3 in the hold mode. In this way, charge offset as well as amplifier offset will be adjusted. Voltage divider network for Speed Error signal (VR3, VR2, R7, VR1 Max CW), R5, R6). Voltage at Pin 9 set to +10.000 Remove Pins 10;11, 12 From Ground on Voltage at TP5 VR2 Position VR3 Position CCW 10.000 VDC CW 4.228 to 235 VDC 2.941 ± .135 VDC CW CW 2-94-10-125-VDC-11-228±,235 VD C CW CCW Kenove 10 vlc from Pin 9,1 PRINTS TO J. Polacek APPROVALS June 2,1977 DIV OR Steam Turbine P3K-AL-0559-A01 DEPT. JUN 2 1977 Schenectady, N.Y. LOCATION CONT ON SHEET 4 sh No. 3

FF-803-WA (2-75) PRINTED IN U.S.A.

+

CODE IDENT NO.

GENERAL (%) ELECTRIC P3K-AL-0559-A01 REV () CONT ON SHEET 5 SH NO.4 TITLE TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS P3K-AL-0559-A01 CIRCUIT 1L1-U001 Assembly Drawing 137D6155 G1 CONT ON SHEET 5 SH NO. FIRST MADE FOR EHC MARK II (LOAD CONTROL UNIT) X781/X623 **REVISIONS** III. CIRCUIT SPECIFICATIONS (continued) Individual Stage Performance Specifications F. Power Supply (CR1, 2, 3 & 4) TP1: +15.7 ± 1.0 VDC TP2: -15.7 ± 1.0 VDC 2. Amplifier (IC1) Acceptable Offset at TP8 (zero input): ±1.0 mv DC b. Transfer Function for Speed Error (VR1, R5, C6, R6, R15, TP8, TP5) VR1 Full CW Where: Gain $(G_1) = -4.616 \pm 0.092$ volts/volt Noise Suppression Lag Time Constant (T1) = 1.40 ± 0.15 msec. Noise Suppression Breakpoint (F1) = 115.3 ± 12.7 HZ VR1 full CCW Where: Gain (G_1) -3.337 \pm 0.150 volts/volt Noise Suppression lag time constant (T1) = 1.93 ± 0.25 msec Noise Suppression breakpoint (F1) = 83.8 + 10.7HZ VRI Mid-position (normal gain) Se T Where: Gain (G1) -4.0008 = 0.080 volts/volt Noise Suppression lag time constant (T1) = 1.65 ± .18 msec Noise Suppression breakpoint (F1) $= 97.6 \pm 10.7 \text{ HZ}$

JUN 2 1977

APPROVALS

Steam Turbine DIV OR DEPT.

Schenectady, N.Y. LOCATION CONT O

P3K-AL-0559-A01

LOCATION CONT ON SHEET 5 SH NO. 4

+

+ .

PRINTS TO

REV () cont on sheet 6 sh No. 5 TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS P3K-AL-0559-A01 CIRCUIT 1L1-U001 Assembly Drawing 137D6155 G1 FIRST MADE FOR EHC MARK II (LOAD CONTROL UNIT) X781/X623 CONT ON SHEET sh No. 5

III. CIRCUIT SPECIFICATIONS

+

REVISIONS

- Individual Stage Performance Specifications (continued)
 - Transfer Function for Load Reference Signal (VR4, R3, C5, R4, R15, TP6, TP8)

VR4 Full CW

Where: Gain $(G_2) = -1.081 \pm 0.022 \text{ Volts/Volt}$ Noise Suppression Lag Time Constant (T2) = 0.99 ± 0.11 msec Noise Suppression Breakpoint (F2) = 162.4 ± 17.8 HZ

VR4 Full CCW

Where: Gain (G2) -0.917 ± 0.031 Volts/Volt Noise suppression lag time constant (T2) = 2.38 ± 0.37 msec Noise suppression breakpoint $(F_2) = 68.6 \pm 10.5 \text{ HZ}$

VR4 Mid-position (Nominal Gain)

APPROVALS

set Where: Gain (G_2) = -1.002 \pm 0.020 Volts/Volt Noise Suppression lag time constant (T2) = 1.67 ± 0.18 msec Noise Suppression breakpoint (F2) $\approx 96.6 \pm 10.6 \text{ HZ}$

PRINTS TO

J. Polacek June 2, 1977 ISSUED 1977 JUN 2

Steam Turbine Schenectady, N.Y.

P3K-AL-0559-A01

LOCATION CONT ON SHEET 6

DIV OR

CODE IDENT NO.

GENERAL (%) ELECTRIC P3K-AL-0559-A01 sh No. 6 CONT ON SHEET 7 TITLE TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS P3K-AL-0559-A01 CIRCUIT 1L1-U001 Assembly Drawing 137D6155 G1 CONT ON SHEET 7 FIRST MADE FOR EHC MARK II (LOAD CONTROL UNIT) X781/X623 REVISIONS III. CIRCUIT SPECIFICATIONS Individual Stage Performance Specifications (continued) 2. (Continued) d. Transfer Function for Stage Pressure Feedback Signal (VR5. R8, C7, R9, R15, TP7, TP8) VR5 Full CW Where: Gain $(G_3)=-1.081\pm0.022$ Volts/Volt Noise Suppression Lag Time Constant (T3) = 0.99 to.11 msec Noise Suppression Breakpoint (F3) = 162.4 ±17.8 HZ VR5 Full CCW Where: Gain $(G3) = 0.917 \pm 0.031 \text{ Volts/Volt}$ Noise suppression lag time constant (T3) = 2.38 ±0.37 msec Noise suppression breakpoint $(F_3) = 68.6 \pm 10.5 \text{ HZ}$ VR5 Mid-position (normal gain) yet Where: Gain $(G3) = -1.002 \pm 0.020 \text{ volts/volt}$ Noise Suppression lag time constant (T3)= 1.67 ± 0.18 msec Noise Suppression breakpoint (F3) = 96.6 ± 10.6 HZ Saturation limits (TP8) 13 VDC Minimum

PRINTS TO

J. Polacek June 2, 1977

Steam Turbine

Schenectady, N.Y.

APPROVALS

DIV OR

P3K-AL-0559-A01

LOCATION CONT ON SHEET 7

PRINTS TO

CODE IDENT NO.

June 2, 1977

Steam Turbine

JUN 2 1977

Schenectady, N.Y.

DIV OR

P3K-AL-0559-A01

LOCATION CONT ON SHEET 8

sh no. 7

+

- Reset voltage at pin 12 to +10.000 VDC
- 4. Decrease voltage at pin 11 to zero (in steps of 1.0 VDC) and note that voltage at TP9 decreases from 0 to -10.000 VDC.
- 5. Reset voltage at pin 11 to -10.000 VDC. TP9 should = 0.00 VDC.

PRINTS TO

APPROVALS

J. Polacek June 2, 1977

Steam Turbine

DIV OR DEPT.

P3K-AL-0559-A01

Schenectady, N.Y. Location cont on sheet 9 sh no. 8

F-803-WA (2-75) RINTED IN U.S.A.

+

+

+

CODE IDENT NO

LOCATION CONT ON SHEET 10

9

CODE IDENT NO.

GENERAL (%) ELECTRIC CONT ON SHEET 10 SH NO. TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS TITLE REV (CIRCUIT 1L1-U001 Assembly Dwg. 137D6155 G1 P3K-AL-0559-A01 X781/X623 FIRST MADE FOR EHC MARK II (LOAD CONTROL UNIT). SH NO. CONT ON SHEET 10 REVISIONS Check Operation of IC3 (Hold Mode) -10.0 at Pin 11 7P6 Set voltage at pin 12 to +8.00 VDC. Output at TP9 =+2.00 VDC. Remove ground from pin 17. Note that voltage at TP9 = +2.00 VDC 2. Decrease voltage at pin 12 toward zero and note that TP9 voltage remains at +2.00 VDC (1005) Decrease voltage at pin 11 toward zero and note that TP9 voltage remains at +2.00 VDC (40LD) Remove TP6 unitage Ground pin 17. (SAUPLE) Note that output at TP9 is zero volts. PRINTS TO DIV OR APPROVALS P3K-AL-0559-A01 J. Polacek June 2, 1977 Steam Turbine _____DEPT.

Schenectady, N.Y.

FF-803-WA (2-75) PRINTED IN U.S.A.

ISSUED

GENERAL (%) ELECTRIC P3K-AL-0559-A01 CONT ON SHEET sh No. 10 TITLE TEST INSTRUCTIONS FOR CONTROL VALVE TEST BIAS P3K-AL-0559-A01 CIRCUIT 1L1-U001 Assembly Dwg. 137D6155 G1 sh No. 10 FIRST MADE FOR EHC Mark II LCU CONT ON SHEET X781/X623 **REVISIONS** PREPARED BY: J. Dombrosky EHC DESIGN ENGINEERING APPROVED BY: PC Callan EHC DESIGN ENGINEERING + PRINTS TO MAGE BY APPROVALS DIV OR .I. Polacek June 2, 1977 Steam Turbine P3K-AL-0559-A01 _ DEPT. IOSUED JUN 2 1977 Schenectady, N.Y. sh No. 10 CONT ON SHEET LOCATION

FF-803-WA (2-76) PRINTED IN U.S.A. CODE IDENT NO.