GE Power Generation Engineering

Materials and Processes Engineering
Schenectady, NY 12345

PROCESS SPECIFICATION

P3K-AL-0456-A01

TEST INSTRUCTIONS FOR LOAD CONTROL UNIT MAIN STOP VALVE INTERCEPT VALVE AMPLIFIER ANALOG LOGIC

DOCUMENT REVISION STATUS: DETERMINED BY THE LAST ENTRY IN THE "REV" AND "DATE" COLUMN

REV.	AN NO.	DESCRIPTION	SIGNATURE	REV. DATE
A	YA00096	SPECIFICATION LISTED IN STEAM TURBINE/GENERATOR INDEX AS "INACTIVE" HAS BEEN FORMALLY REVISED AS "INACTIVE FOR NEW DESIGN". (PR BUDKA)	C.R. Trupp	DEC 0 2 1991

INACTIVE FOR NEW DESIGN

AS OF 12/02/91

PREPARED BY: P.R. BUDKA

ORIG. ISSUE DATE: --

DT-3C

TITLE
TEST INSTRUCTIONS - LOAD CONTROL UNIT MAIN STOP VALVE/ INTERCEPT VALVE AMPLIFIER ANALOG/LOGIC (LCU MSV/IV AMP A/L)
FIRST MADE FOR DRAWING NUMBER 125D3609 G1 EHC MARK II

REVISIONS

I. CIRCUIT DESCRIPTION

This circuit board contains the logic pertaining to the Main Stop/ Intercept Valve Logic system. Various relays energize and de-energize to steer signals to other components.

II. EQUIPMENT NEEDED

The following equipment, or its equivalent, is recommended for testing this board.

a. SPST switches
b. 24 VDC indicators
c. DC power supplies
d. Wire, screws, miscellaneous hardware

III. CIRCUIT SPECIFICATION

The reference board shall be connected as per Figure 1 and tested as follows:

273-5
273-3/4
~~273-2~~
273-12
273-13
~~273-22~~
~~273-22~~
273-71
PRINTS TO

REV NO. Ø A

P3K-AL-0456-A01
CONT ON SHEET 4 SH NO. 3

TITLE
TEST INSTRUCTIONS - LOAD CONTROL UNIT MAIN STOP VALVE/ INTERCEPT VALVE AMPLIFIER ANALOG/LOGIC (LCU MSV/IV AMP A/L)
FIRST MADE FOR DRAWING NUMBER 125D3609 G1 EHC MARK II

REVISIONS



FIGURE 1

PRINTS TO

TITLE
TEST INSTRUCTIONS - LOAD CONTROL UNIT MAIN STOP VALVE/ INTERCEPT VALVE AMPLIFIER ANALOG/LOGIC (LCU MSV/IV AMP A/L)
FIRST MADE FOR DRAWING NUMBER 125D3609 G1 EHC MARK II

REVISIONS

	S1	S2	S3	S4	S5	B1	B2	B3	B4	B5	B6	TP 1
24 VDC APPLIED				1	1		1	1		1	1	1
K1 ENERGIZED	1			1	1	1				1	1	1
K2 ENERGIZED		1		1	1		1	1	1		1	1
K3 ENERGIZED			1	1	1		1	1		1		1
K1, K2, K3 ENERGIZED	1	1	1	1	1	1			1			1
S4 OPEN	1	1	1	1		1			1			
S5 OPEN	1	1	1	1								1

1 = ENERGIZED/ILLUMINATED

PRINTS TO

REVISIONS

TEST INSTRUCTIONS 1L3-E002

Assembly 125D3609
Schematic 118D2193

PROCEDURE:

A. Refer to P3K-AL-0494-A02 for test circuits, equipment list, and set up instructions.

B. Table A provides the step by step procedure to follow in testing this circuit.

C. Table B provides a step by step description of input voltages (to use as a troubleshooting aid).

PRINTS TO

GENERAL ELECTRIC

P3K-AL-0456-A01
CONT ON SHEET 7 SH NO. 6

REV NO. 0 A

P3K-AL-0456-A01
CONT ON SHEET 7 SH NO. 6

TITLE
TEST INSTRUCTION FOR LCU MSV/IV AMP A/L

FIRST MADE FOR MK II

REVISIONS

ACTION	VOLTAGE AT PINS									
	11	12	13	16	21	23				
STEP 1 INIT. COND.										
STEP 2 APP P38										
STEP 3 APP P10						A				
STEP 4 APP P26			A		0					
STEP 5 APP P24	A									
STEP 6 APP P25		0		A						
STEP 7 APP P27	0	A		0						
STEP 8 REM P27	A	0		A						
STEP 9 APP P36			0		A					
STEP 10 REM P36			A		0					
STEP 11 APP P5						0				
STEP 12 REM P5						A				
STEP 13 REM P10										
STEP 14 REM P26										
STEP 15 REM P24										
STEP 16 REM P25										
STEP 17 REM P38										

PRINTS TO

MADE BY D.Mone July 23, 1976
ISSUED JUL 23 1976 JUL 23 1976

APPROVALS

LST
DIV OR DEPT.
Schenectady
LOCATION

P3K-AL-0456-A01
CONT ON SHEET 7 SH NO. 6

CODE IDENT NO.

GENERAL ELECTRIC

P3K-AL-0456-A01
CONT ON SHEET 8 SH NO. 7

REV NO. Ø A

P3K-AL-0456-A01
CONT ON SHEET 8 SH NO. 7

TITLE
TEST INSTRUCTION FOR LCU MSV/IV AMP A/L

FIRST MADE FOR MK II

ACTION	INPUT AT PINS									
	5	10	24	25	26	27	36	38		
STEP 1										
STEP 2 APP P38								X		
STEP 3 APP P10		X						X		
STEP 4 APP P26		X			X			X		
STEP 5 APP P24		X	X		X			X		
STEP 6 APP P25		X	X	X	X			X		
STEP 7 APP P27		X	X	X	X	X		X		
STEP 8 REM P27		X	X	X	X			X		
STEP 9 APP P36		X	X	X	X		X	X		
STEP 10 REM P36		X	X	X	X			X		
STEP 11 APP P5	X	X	X	X	X			X		
STEP 12 REM P5		X	X	X	X			X		
STEP 13 REM P10			X	X	X			X		
STEP 14 REM P26			X	X				X		
STEP 15 REM P24				X				X		
STEP 16 REM P25								X		
STEP 17 REM P38										

REVISIONS

PRINTS TO

MADE BY D.Mone July 23, 1976
ISSUED JUL 23 1976

APPROVALS

LST DIV OR DEPT.
Schenectady LOCATION

P3K-AL-0456-A01
CONT ON SHEET 8 SH NO. 7

FP-803-WA (5-74)
PRINTED IN U.S.A.

CODE IDENT NO.

GENERAL ELECTRIC

P3K-AL-0456-A01
CONT ON SHEET — SH NO. 8

REV NO. 0 A

P3K-AL-0456-A01
CONT ON SHEET — SH NO. 8

TITLE
TEST INSTRUCTIONS - LOAD CONTROL UNIT MAIN STOP VALVE/ INTERCEPT VALVE AMPLIFIER ANALOG/LOGIC (LCU MSV/IV AMP A/L)
FIRST MADE FOR DRAWING NUMBER 125D3609 G1 EHC MARK II

REVISIONS

PREPARED BY C.J. Barrigher DATE 11/7/75
C.J. Barrigher
EHC DESIGN ENGINEERING

APPROVED BY P C Callan DATE 7-21-76
P.C. Callan - MANAGER
EHC DESIGN ENGINEERING

TEST PROCEDURE PREPARED BY C R Bugg DATE 7/2/76
C. Bugg
EHC TEST ENGINEER

TEST PROCEDURE APPROVED BY C.J. Barrigher DATE 7/20/76
C.J. Barrigher
EHC DESIGN ENGINEERING

PRINTS T

MADE BY D.Mone July 23, 1976
ISSUED JUL 23 1976
APPROVALS
Steam Turbine DIV OR DEPT.
Schenectady, N.Y. LOCATION
P3K-AL-0456-A01
CONT ON SHEET — SH NO. 8
CODE IDENT N

FF-803-WA (2-74)
PRINTED IN U.S.A.