



GE Energy

Functional Testing Specification

Parts & Repair Services
Louisville, KY

LOU-GED-IS200ICCA

Test Procedure for a IS200ICCA card

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Dan Waddy	3/27/2014
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY D. Waddy	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 3/27/2014	DATE	DATE	DATE 3/28/2014

LOU-GED-IS200ICCA REV. A	g GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 2 of 3
-------------------------------------	---	--------------------

1. **SCOPE**

1.1 This is a functional testing procedure for a IS200ICCA Card.

2. **STANDARDS OF QUALITY**

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. **APPLICABLE DOCUMENTS**

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. **EQUIPMENT REQUIRED**

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference	Description
1	H190111	DC 2000 Test Drive w/digital front end.

<p>LOU-GED-IS200ICCA REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 3 of 3</p>
--	--	---------------------------

6. Testing Process

6.1 Setup

- 6.1.1 Inspect the customer's card for any signs of damage or physical defects.
- 6.1.2 Remove test card from the drive and install the customer's card into the proper slot.



Note: It is recommended to make sure that the drive is functioning properly with the test card before installing the customer's card. This can be accomplished by verifying that the drive powers up properly, will perform the cell test, run, and reverse polarity without fault.

6.2 Testing Procedure

- 6.2.1 Apply power to the drive.
- 6.2.2 At the computer open MY DOCUMENTS -> ISDC2000 -> DRIVE -> Innovation Drive with DCFBG2.icb.
- 6.2.3 From there download the firmware by selecting Device -> Download to Drive -> Pattern Flash (runtime).
- 6.2.4 Once the firmware has downloaded select Device -> Download to Drive -> Parameter Values to complete that download.
- 6.2.5 Once the parameter values have been downloaded cycle power to the drive.
- 6.2.6 Verify that the drive powers up and gives voltage and current outputs on the gauges.
- 6.2.7 Left click the run wizard icon on the toolbar. Select the cell test and follow prompts to execute.
- 6.2.8 If the card passes the cell test start the drive motor by switching the RUN-34 into the on position.
- 6.2.9 Allow the motor to run for approximately 30 minutes.
- 6.2.10 Reverse the polarity of the motor by switching POL-38 switch. Allow the motor to run in that direction for another 30 minutes.

6.3 *****TEST COMPLETE*****

7. Notes

- 7.1 None at this time.