



GE Energy

Functional Testing Specification

*Parts & Repair Services
Louisville, KY*

LOU-GED-531X175SSBx

Test Procedure for a 531X175SSBA

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial Release	James Archibald	1/28/2010
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY James Archibald	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL Charlie Wade
DATE 01/28/2010	DATE	DATE	DATE 2/10/2010

<p>LOU-GED-531X175SSBx REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 2 of 3</p>
--	--	---------------------------

1. SCOPE

1.1 This is a functional testing procedure for a 531X175SSBA Card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check electronic folder for more information.

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	H033766	DC300/ Series 6 PLC

<p>LOU-GED-531X175SSBx REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 3 of 3</p>
---------------------------------------	--	--------------------

6. TESTING PROCESS

6.1 Setup

6.1.1 Connect as described on connection diagram sheet.



Note: This card has 2 separate Channels. Channel 1 is TPA,TPB and GND. Channel 2 is TQA, TQB and GND

6.2 Testing Procedure

6.2.1 On the DC300 pull the E stop out, LED's should scroll from right to Left.

6.2.2 On the programmer Hit set drive 77 enter, (programmer should display parameter), hit 000 then type in 2315 and enter.

6.2.3 Set jumpers on card the same as test card and plug in to slot 1.

6.2.4 Turn RUN/ STOP switch to RUN.

6.2.5 On the I/O switches push I10 up, push I9 up then push I10 back to the center position

6.2.6 On the display on the PLC (after a few seconds) the display should read 0001 then after a few more seconds should display 0002.

6.2.7 The PLC should run the drive through several test automatically.

6.2.8 After drive runs push I10 down, turn RUN/STOP switch to Stop.

6.2.9 Repeat steps 6.2.4 thru 6.2.8 for channel 2.

6.2.10 *****TEST COMPLETE**

6.3 *****TEST COMPLETE *****

7. NOTES

7.1 None at this time

8. ATTACHMENTS

8.1 None at this time