



GE Energy

Functional Testing Specification

Parts & Repair Services
Louisville, KY

LOU-GED-DS3800HSAC

Test Procedure for a DS3800HSAC

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Steve Pharris	2/7/2011
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Steve Pharris	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 2/7/2011	DATE	DATE	DATE 2/17/2011

LOU-GED-DS3800HSAC REV. A	g GE Energy Parts & Repair Services Louisville, KY	Page 2 of 11
------------------------------	--	--------------

1. SCOPE

1.1 This is a functional testing procedure for a DS3800HSAC.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		O-Scope
1		DS3800 Power Supply
1		DS3800 Connector Box
1		Rainbow Box
1		Fluke Voltage Source
1		Auxiliary Input Box

<p>LOU-GED-DS3800HSAC REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 3 of 11</p>
---	--	----------------------------

6. Modifications/Upgrades

6.1 None at this time.

7. Testing Process

7.1 Setup

7.1.1 Make the following connections and set switches as follows.

PA1-PA9

PA68-SW81-L

PA66-SW82-L

PA74-SW83-L

PA64-SW84-L

PA76-SW85-L

PA61-SW86-L

PA72-SW87-L

PA70-SW88-L

PA41-SW89-L

PA48-SW90-L

PA47-SW91-L

PA50-SW92-L

PA51-SW93-L

PA49-SW94-L

PA46-SW95-L

PA39-SW96-H

(From auxiliary box)

PA36-1-L

PA40-2-L

PA31-3-L

PA35-4-L

PA42-5-L


PA33-6-L

PA34-7-H

PA38-8-L

(Other connections)

PA37-COM

LOU-GED-DS3800HSAC REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 4 of 11
--------------------------------------	--	---------------------

PA44-COM

PA63-COM

PA11-COM

7.1.2 Set jumpers J1-J6 to “T”

7.2 Testing Procedure

7.2.1 Apply Power.

7.2.2 Adjust R138 for 10V at U2P6

7.2.3 Verify PA78 = 9.9V

7.2.4 Set SW96-L

7.2.5 Verify PA78 = 0V

7.2.6 Set SW95-H

7.2.7 Verify PA78 = -5V

7.2.8 Set SW94-H

7.2.9 Verify PA78 = -7.5V

7.2.10 Verify PA23 = -7.5V

7.2.11 Set SW93-H

7.2.12 Verify PA78 = -8.7V

7.2.13 Set SW92-H

7.2.14 Verify PA78 = -9.3V

7.2.15 Set SW91-H

7.2.16 Verify PA78 = -9.6V

7.2.17 Set SW90-H

7.2.18 Verify PA78 = -9.8V

7.2.19 Set SW95-L

7.2.20 Verify PA78 = -4.8V

7.2.21 Set SW89-H

7.2.22 Verify PA78 = -4.9V

7.2.23 Set SW94-L

7.2.24 Verify PA78 = -2.41V


7.2.25 Set SW88-H

7.2.26 Verify PA78 = -2.45V


7.2.27 Verify PA23 = -2.45V

7.2.28 Set SW87-H


7.2.29 Verify PA78 = -2.47V

LOU-GED-DS3800HSAC REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 5 of 11
--------------------------------------	--	---------------------


- 7.2.30** Set SW86-H
- 7.2.31** Verify PA78 = -2.48V
- 7.2.32** Set SW84-H and SW85-H
- 7.2.33** Verify PA78 = -2.49V
- 7.2.34** Set SW83, SW82, and SW81-H
- 7.2.35** Verify PA78 = -2.5V
- 7.2.36** Set SW81-SW96-H
- 7.2.37** Verify PA78 = 0V
- 7.2.38** Set SW83, SW82, and SW81-L
- 7.2.39** Verify PA78 = 0V
- 7.2.40** Set SW84-L
- 7.2.41** Verify PA78 = .001V
- 7.2.42** Set SW85-L
- 7.2.43** Verify PA78 = .007V
- 7.2.44** Set SW86-L
- 7.2.45** Verify PA78 = .016V
- 7.2.46** Set SW87-L
- 7.2.47** Verify PA78 = .036V
- 7.2.48** Set SW88-L
- 7.2.49** Verify PA78 = .075V
- 7.2.50** Set SW89-L
- 7.2.51** Verify PA78 = .153V
- 7.2.52** Set SW90-L
- 7.2.53** Verify PA78 = .3V
- 7.2.54** Set SW91-L
- 7.2.55** Verify PA78 = .62V
- 7.2.56** Set SW92-L
- 7.2.57** Verify PA78 = 1.24V
- 7.2.58** Set SW93-L
- 7.2.59** Verify PA78 = 2.48V
- 7.2.60** Set SW94-L
- 7.2.61** Verify PA78 = 4.98V
- 7.2.62** Set SW95-L
- 7.2.63** Verify PA78 = 9.96V

LOU-GED-DS3800HSAC REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 6 of 11
--------------------------------------	--	---------------------

- 7.2.64** Remove PA11
- 7.2.65** Verify PA78 does NOT change while toggling any switches 81-96
- 7.2.66** Reconnect PA11
- 7.2.67** Set 7-L (on aux box)
- 7.2.68** Verify PA78 does NOT change while toggling any switches 81-96
- 7.2.69** Set J1-J6=F
- 7.2.70** Set SW1-7-H (on aux box)
- 7.2.71** Set SW8-L (on aux box)
- 7.2.72** Verify PA78 DOES change while toggling any switches 81-96
- 7.2.73** Make the following connections
 - PA63-L
 - PA37-H
 - PA44-H
 - PA56-L
- 7.2.74** Verify PA78 = 10V
- 7.2.75** Set SW96-L
- 7.2.76** Verify PA78 = 0V
- 7.2.77** Set SW95-H
- 7.2.78** Verify PA78 = -5V
- 7.2.79** Verify PA24 = -5V
- 7.2.80** Set SW94-H
- 7.2.81** Verify PA78 = -7.5V
- 7.2.82** Set SW93-H
- 7.2.83** Verify PA78 = -8.7V
- 7.2.84** Set SW92-H
- 7.2.85** Verify PA78 = -9.3V
- 7.2.86** Set SW91-H
- 7.2.87** Verify PA78 = -9.6V
- 7.2.88** Set SW90-H
- 7.2.89** Verify PA78 = -9.8V
- 7.2.90** Set SW95-L
- 7.2.91** Verify PA78 = -4.8V
- 7.2.92** Set SW89-H
- 7.2.93** Verify PA78 = -4.9V

LOU-GED-DS3800HSAC REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 7 of 11
--------------------------------------	--	---------------------

- 7.2.94** Set SW94-L
- 7.2.95** Verify PA78 = -2.4V
- 7.2.96** Set SW88-H
- 7.2.97** Verify PA78 = -2.44V
- 7.2.98** Set SW87-H
- 7.2.99** Verify PA78 = -2.46V
- 7.2.100** Set SW86-H
- 7.2.101** Verify PA78 = -2.47V
- 7.2.102** Set SW84 and SW85-H
- 7.2.103** Verify PA78 = -2.48V
- 7.2.104** Set SW83, SW82, and SW81-H
- 7.2.105** Verify PA78 = -2.49V
- 7.2.106** Set SW94, SW95, and SW96-H (switches 81-96 should be H)
- 7.2.107** Verify PA78 = 0V
- 7.2.108** Set SW83, SW82, and SW81-L
- 7.2.109** Verify PA78 = 0V
- 7.2.110** Set SW84-L
- 7.2.111** Verify PA78 = .017V
- 7.2.112** Set SW85-L
- 7.2.113** Verify PA78 = .022V
- 7.2.114** Set SW86-L
- 7.2.115** Verify PA78 = .032V
- 7.2.116** Set SW87-L
- 7.2.117** Verify PA78 = .05V
- 7.2.118** Set SW88-L
- 7.2.119** Verify PA78 = .09V
- 7.2.120** Set SW89-L
- 7.2.121** Verify PA78 = .168V
- 7.2.122** Set SW90-L
- 7.2.123** Verify PA78 = .325V
- 7.2.124** Set SW91-L
- 7.2.125** Verify PA78 = .63V
- 7.2.126** Set SW92-L
- 7.2.127** Verify PA78 = 1.26V

LOU-GED-DS3800HSAC REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 8 of 11
--------------------------------------	--	---------------------

- 7.2.128** Set SW93-L
- 7.2.129** Verify PA78 = 2.5V
- 7.2.130** Set SW94-L
- 7.2.131** Verify PA78 = 5V
- 7.2.132** Verify PA24 = 5V
- 7.2.133** Set SW95-L
- 7.2.134** Verify PA78 = 10V
- 7.2.135** Verify PA20 = L
- 7.2.136** Remove PA11
- 7.2.137** Verify PA20 = H
- 7.2.138** Set jumpers as follows
 - J24-L
 - J18-L
 - J20-L
 - J7-CHAR
- 7.2.139** Connect JA7-COM
- 7.2.140** Apply 3VDC-JA5
- 7.2.141** Verify PA44 = L
- 7.2.142** Verify PA78 = -6.3V
- 7.2.143** Set J24-H
- 7.2.144** Verify PA78 = -2.2V
- 7.2.145** Set J18-H
- 7.2.146** Verify PA78 = -1.7V
- 7.2.147** Set J20-H
- 7.2.148** Verify PA78 = -2.5V
- 7.2.149** Set J7-NOR
- 7.2.150** Verify PA78 = -8.5V
- 7.2.151** Reverse polarity at JA5
- 7.2.152** Verify PA78 = -8.5V
- 7.2.153** Connect JA5-COM
- 7.2.154** Apply 3VDC-JA7
- 7.2.155** Verify PA78 = -8.5V
- 7.2.156** Reverse polarity at JA7
- 7.2.157** Verify PA78 = -8.5V

LOU-GED-DS3800HSAC REV. A	<div data-bbox="544 199 584 262" data-label="Image"></div> <div data-bbox="730 252 982 336" data-label="Text"> <p>GE Energy Parts & Repair Services Louisville, KY</p> </div>	Page 9 of 11
--------------------------------------	--	---------------------

- 7.2.158** Verify PA21 = -8.5V
- 7.2.159** Set jumper “PFB1”-IN
- 7.2.160** Set jumper J30-A
- 7.2.161** Verify U12P7 = 8.8V
- 7.2.162** Set jumper “PFB1”-OUT
- 7.2.163** Verify U12P7 = 0V
- 7.2.164** Set jumpers as follows
 - J25-L
 - J21-L
 - J23-L
 - J8-CHAR
- 7.2.165** Connect PA63-H
- 7.2.166** Connect PA37-L
- 7.2.167** Connect PA44-L
- 7.2.168** Remove connections at JA5 and JA7
- 7.2.169** Apply 3VDC-JA11
- 7.2.170** Connect JA9-COM
- 7.2.171** Verify PA78 = -6.3V
- 7.2.172** Set J25-H
- 7.2.173** Verify PA78 = -2.2V
- 7.2.174** Set J21-H
- 7.2.175** Verify PA78 = -1.7V
- 7.2.176** Set J23-H
- 7.2.177** Verify PA78 = -2.5V
- 7.2.178** Set J8-NOR
- 7.2.179** Verify PA78 = -8.5V
- 7.2.180** Connect JA11-COM
- 7.2.181** Apply 3VDC-JA9
- 7.2.182** Verify PA78 = -8.5V
- 7.2.183** Verify PA30 = -8.5V
- 7.2.184** Set jumper “PFB2”-IN
- 7.2.185** Set jumper J33-A
- 7.2.186** Verify U12P1 = 0V
- 7.2.187** Connect PA44-H

LOU-GED-DS3800HSAC REV. A	<div data-bbox="548 201 581 252" data-label="Image"></div> <div data-bbox="737 258 980 333" data-label="Text"> <p>GE Energy Parts & Repair Services Louisville, KY</p> </div>	Page 10 of 11
--------------------------------------	--	----------------------

- 7.2.188** Verify PA78 = 5V
- 7.2.189** Connect PA37-H
- 7.2.190** Rotate R144 fully CCW
- 7.2.191** Rotate R139 fully CCW
- 7.2.192** Set J12-3.3
- 7.2.193** Verify JA20 = 26Vpk-pk @ 2.6Khz sine wave
- 7.2.194** Rotate R144 fully CW
- 7.2.195** Verify JA20 frequency increases to 3.9Khz
- 7.2.196** Set R144 for 3.3Khz @ JA20
- 7.2.197** Set J12-3.0
- 7.2.198** Verify JA20 = 26Vpk-pk @ 3.0Khz sine wave
- 7.2.199** Set J12-2.7
- 7.2.200** Verify JA20 = 26Vpk-pk @ 2.7Khz sine wave
- 7.2.201** Rotate R139 fully CW
- 7.2.202** Verify JA20 amplitude decrease to 17Vpk-pk
- 7.2.203** Verify PA78 varies between -3.4V to -2.7V as R144 is adjusted
- 7.2.204** Set R144 for 2.7Khz @ JA20
- 7.2.205** Verify PA78 = -2.9V
- 7.2.206** Set jumper J14-A
- 7.2.207** Set jumper J13-A
- 7.2.208** Connect PA63-L
- 7.2.209** Connect PA37-L
- 7.2.210** Remove connections at JA9 and JA11
- 7.2.211** Apply -1V-JA18
- 7.2.212** Verify PA78 = -1V
- 7.2.213** Verify JA12 = -15V
- 7.2.214** Set jumper INH2-IN
- 7.2.215** Connect PA4 to COM
- 7.2.216** Connect PA10 to COM
- 7.2.217** Verify JA12 = 15V
- 7.2.218** Remove PA10
- 7.2.219** Verify JA12 = -15V
- 7.2.220** Set jumper INH2-OUT
- 7.2.221** Verify JA12 = 15V

<p>LOU-GED-DS3800HSAC REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 11 of 11</p>
---	--	-----------------------------

7.2.222 Verify PA69 = L

7.2.223 Remove PA4

7.2.224 Verify PA69 = H

7.2.225 Apply -1V-JA16

7.2.226 Make the following connections

PA63-H

PA37-H

PA44-L

7.2.227 Set jumpers as follows

J15-A

J16-A

7.2.228 Verify PA78 = -1V

7.2.229 Verify JA14 = -15V

7.2.230 Connect PA4-COM

7.2.231 Verify JA14 = 15V

7.2.232 Remove PA4

7.2.233 Verify JA14 = -15V

7.3 *TEST COMPLETE*****

8. Notes

8.1 None at this time.

9. Attachments

9.1 None at this time.