g	GE Energy	Functional Testing Specification
	Parts & Repair Services Louisville, KY	LOU-GED-DS200PTBAG1B

## Test Procedure for a DS200PTBAG1B card

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column				
REV.	DESCRIPTION	SIGNATURE	REV. DATE	
Α	Initial release	Scott Cash	02/01/2011	
В	Removed incorrect measurement points	Steve Pharris	03/28/2014	
С	Replaced the phrase "test the capacitors" with actual capacitor values to be measured in step 6.2.2.	Cristyn Edlin	07/02/2014	
D	Removed Rev C edits and verified IN-CIRCUIT Cap Testing with DMM	J.Barton	08/31/2015	

#### © COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Scott Cash	REVIEWED BY S. Pharris	J. Barton	Charlie Wade
<b>DATE</b> 2/1/2011	3/28/2014	<b>DATE</b> 8/31/2015	<b>DATE</b> 2/3/2011

	g	
LOU-GED-DS200PTBAG1B	GE Energy	Page 2 of 6
REV. D	Parts & Repair Services	
	Louisville, KY	

#### 1. SCOPE

**1.1** This is a functional testing procedure for a DS200PTBAG.

#### 2. STANDARDS OF QUALITY

**2.1** Refer to the current revision of the IPC-A-610 standard for workmanship standards.

### 3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
  - **3.1.1** Check board's electronic folder for more information

#### 4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
  - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
  - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
    - 4.2.1.1 Wires broken, cracked, or loosely connected
    - 4.2.1.2 Terminal strips / connectors broken or cracked
    - 4.2.1.3 Components visually damaged
    - **4.2.1.4** Capacitors bloated or leaking
    - 4.2.1.5 Solder joints damaged or cold
    - 4.2.1.6 Circuit board burned or de-laminated
    - 4.2.1.7 Printed wire runs / Traces burned or damaged

#### 5. EQUIPMENT REQUIRED

**5.1** The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)

	g	
LOU-GED-DS200PTBAG1B	GE Energy	Page 3 of 6
REV. D	Parts & Repair Services	_
	Louisville, KY	

## 6. <u>TESTING PROCESS</u>

## 6.1 Testing Procedure

**6.1.1** Please check the following points. For those reading at 0 ohm, tolerance will be +- 1 ohm. All other readings will be +- 5%.

FROM	ТО	Reading in Ohms	Notes
TB-1	JU-1	0	
TB-1	JJR-1	0	
TB-1	JJS-1	0	
TB-1	JJT-1	0	
TB-2	JJR-2	0	
TB-2	JJS-2	0	
TB-2	JJT-2	0	
TB-2	JU-2	0	
TB-3	JU-3	0	
TB-3	JJR-3	0	
TB-3	JJS-3	0	
TB-3	JJT-3	0	
TB-4	JJR-4	0	
TB-4	JJS-4	0	
TB-4	JJT-4	0	
TB-4	JU-4	0	
TB-5	JU-5	0	
TB-5	JJR-5	0	
TB-5	JJS-5	0	
TB-5	JJT-5	0	
TB-6	JJR-6	0	
TB-6	JJS-6	0	
TB-6	JJT-6	0	
TB-6	JU-6	0	
TB-7	JU-7	0	
TB-7	JJR-7	0	
TB-7	JJS-7	0	
TB-7	JJT-7	0	
TB-8	JJR-8	0	
TB-8	JJS-8	0	
TB-8	JJT-8	0	
TB-8	JU-8	0	

LOU-GED-DS200PTBAG1B REV. D

g

GE Energy Parts & Repair Services Louisville, KY

Page 4 of 6

FROM	ТО	Reading in Ohms	Notes
JU-13	JU-19	1.5K	
JU-13	JU-20	1.5K	
JU-13	JU-21	1.5K	
JU-13	JU-22	1.5K	
JU-13	JU-23	1.5K	
JU-13	JU-24	1.5K	
JU-13	JU-25	1.5K	
JU-13	JU-26	1.5K	
TB-09	JU-9	0	
TB-11	JU-11	0	
TB-10	JU-10	0	
TB-12	JU-12	0	
TB-13	JVA-1	2.7K	
TB-14	JU-19	3.3K	
TB-15	JVB-1	2.7K	
TB-16	JU-20	3.3K	
TB-17	JVA-2	2.7K	
TB-18	JU-21	3.3K	
TB-19	JVB-2	2.7K	
TB-20	JU-22	3.3K	
TB-21	JVA-3	2.7K	
TB-22	JU-23	3.3K	
TB-23	JVB-3	2.7K	
TB-24	JU-24	3.3K	
TB-25	JVA-4	2.7K	
TB-26	JU-25	3.3K	
TB-27	JVB-4	2.7K	
TB-28	JU-26	3.3K	
TB-29	JV-1	155ohms	
TB-30	JV-2	155ohms	
TB-31	JV-3	155ohms	
TB-32	JV-4	155ohms	
TB-33	JV-5	155ohms	
TB-34	JV-6	155ohms	
TB-35	JN-4	0	
TB-36	JN-5	0	
TB-37	JM-6	0	
TB-38	JM-3	0	

LOU-GED-DS200PTBAG1B REV. D

g

GE Energy Parts & Repair Services Louisville, KY

Page 5 of 6

FROM	ТО	Reading in Ohms	Notes
TB-39	TB-40	0	
TB-41	JN-6	Diode Drop	Negative lead on TB-41
TB-41	TB-38	Diode Drop	Positive lead on TB-41
TB-42	JM-11	0	
TB-43	JN-1	0	
TB-44	TB-45	0	
TB-46	TB-47	0	
TB-48	JN-2	0	
TB-49	JN-2	0	
TB-48	TB-49	0	
TB-50	TB-51	0	
TB-52	TB-53	0	
TB-54	TB-55	0	
TB-56	JN-3	0	
JU-15	JN-7	0	
JU-16	JN-8	0	
JU-14	JN-9	0	
TB-57	JM-1	0	
TB-58	TB-59	0	
TB-58	JM-4	0	
TB-59	JM-4	0	
TB-60	JM-5	0	
TB-61	TB-70	0	
TB-61	JM-2	0	
TB-62	TB-63	0	
TB-62	TB-71	0	
TB-63	TB-71	0	
TB-62	JM-7	0	
TB-63	JM-7	0	
TB-64	JM-8	0	
TB-65	JM-9	0	
TB-66	JM-10	0	
TB-67	TB-62	0	
TB-67	TB-63	0	
TB-67	TB-69	0	
TB-68	JM-12	0	
TB-70	JM-2	0	
TB-61	TB-70	0	
TB-72	JN-10	0	

# LOU-GED-DS200PTBAG1B REV. D

g

GE Energy Parts & Repair Services Louisville, KY

Page 6 of 6

FROM	ТО	Reading in Ohms	Notes
TB-73	TB-74	Diode Drop	~.450
TB-74	TB-73	Diode Drop	~.450
TB-73	JV-7	0	
TB-74	JV-8	0	
TB-75	TB-76	Diode Drop	~.450
TB-76	TB-75	Diode Drop	~.450
TB-75	JV-9	0	
TB-76	JV-10	0	
TB-77	TB-78	Diode Drop	~.450
TB-78	TB-77	Diode Drop	~.450
TB-77	JV-11	0	
TB-78	JV-12	0	
JU-18	JN-12	0	
JU-17	JN-11	0	BJ1 Installed

#### **6.1.2** Capacitor measurements with the DMM.

TB-73	CGND	NEG on CGND	~.175uF
TB-74	CGND	NEG on CGND	~.175uF
TB-75	CGND	NEG on CGND	~.175uF
TB-76	CGND	NEG on CGND	~.175uF
TB-77	CGND	NEG on CGND	~.175uF
TB-78	CGND	NEG on CGND	~.175uF

## 6.2 \*\*\*TEST COMPLETE \*\*\*

### 7. NOTES

**7.1** None at this time.

### 8. ATTACHMENTS

**8.1** None at this time.