g		GE Energy	Functi	ional Testing Sp	ecification	
Parts & Repair Services Louisville, KY				LOU-GED-DS3800NVMB		
		Test Procedure for a A				
	MENT REVISION STATUS:	Determined by the last entry in t	he "REV" and "DATE" co			
REV.		DESCRIPTION		SIGNATURE	REV. DATE	
A	Initial release writt	en for DS3800NVMB.		S. Pharris	11/23/2010	
DDEDA	DED BY	REVIEWED BY	REVIEWED BY	OHALITY AT	PPOVA!	
PREPARED BY S. Pharris		VEAIEMED DI	VEAIEMED DI	VED BY QUALITY APPROVAL Charlie Wade		

DATE

DATE

DATE

12/2/2010

DATE

11/23/2010

g

LOU-GED-DS3800NVMB REV. A

GE Energy Parts & Repair Services Louisville, KY Page 2 of 4

Functional test procedure for an AC Source Monitor Card

1. SCOPE

1.1 This is a functional testing procedure for a High Voltage Card

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** UUT documentation folder

4. ENGINEERING REQUIREMENTS

- **4.1** Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - **4.2.1.1** Wires broken or cracked
 - **4.2.1.2** Terminal strips / connectors broken or cracked
 - **4.2.1.3** Loose wires
 - **4.2.1.4** Components visually damaged
 - **4.2.1.5** Capacitors leaking
 - **4.2.1.6** Solder joints damaged or cold
 - **4.2.1.7** Circuit board burned or de-laminated
 - **4.2.1.8** Printed wire runs burned or damaged

g

LOU-GED-DS3800NVMB REV. A

GE Energy Parts & Repair Services Louisville, KY Page 3 of 4

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		Variac
1		Power Supply
1		Cable Assembly for DS3800NVMB

6. Modifications/Upgrades

6.1 None

7. <u>Testing Process</u>

7.1 Setup

- **7.1.1** Turn pot R10 fully CCW
- **7.1.2** Set Variac for 0VAC
- **7.1.3** Set power supply for 18.5VDC
- **7.1.4** Connect cable to J1
- 7.1.5 Connect green and yellow jacks to power supply (polarity is not important)
- **7.1.6** Connect blue and grey jacks to DMM (polarity is not important)

7.2 Testing Procedure

- **7.2.1** Turn on DC supply
- **7.2.2** Turn on Variac
- **7.2.3** Verify LED is off
- **7.2.4** Increase voltage on Variac while monitoring DMM
- 7.2.5 Verify LED turns on at approx. 80VAC +/- 5VAC
- **7.2.6** Turn pot R10 fully CW
- **7.2.7** Verify LED turns off
- **7.2.8** Increase voltage on Variac while monitoring DMM

GE Energy
Parts & Repair Services
Page 4 of 4

LOU-GED-DS3800NVMB REV. A

- 7.2.9 Verify LED turns on at approx. 110VAC +/- 5VAC
- 7.2.10 Decrease Variac to 0VAC
- **7.2.11** Reverse green and yellow jacks to switch incoming polarity

Louisville, KY

- 7.2.12 Turn pot R10 fully CCW
- **7.2.13** Verify LED is off
- 7.2.14 Increase voltage on Variac while monitoring DMM
- 7.2.15 Verify LED turns on at approx. 80VAC +/- 5VAC
- **7.2.16** Turn pot R10 fully CW
- 7.2.17 Verify LED turns off
- **7.2.18** Increase voltage on Variac while monitoring DMM
- **7.2.19** Verify LED turns on at approx. 110VAC +/- 5VAC
- **7.2.20** Remove all power to UUT
- 7.3 ***TEST COMPLETE ***

8. Notes

8.1 None at this time.

9. Attachments

9.1 None at this time.