



GE Energy

## Functional Testing Specification

*Parts & Repair Services  
Louisville, KY*

**LOU-GED-115D2277Gxxx**

### Test Procedure for a board.

**DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Copied pre-written procedure over to this format.	C. Wade	5/14/2009
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

<b>PREPARED BY</b> G. Chandler	<b>REVIEWED BY</b>	<b>REVIEWED BY</b>	<b>QUALITY APPROVAL</b> Charlie Wade
<b>DATE</b> 5/14/2009	<b>DATE</b>	<b>DATE</b>	<b>DATE</b> 5/14/2009

LOU-GED-115D2277Gxxx REV. A	g  <b>GE Energy</b> Parts & Repair Services Louisville, KY	Page 2 of 7
--------------------------------	--	-------------

## 1. SCOPE

1.1 This is a functional testing procedure for a Card.

## 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

## 3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 P3K-AL-0401-A01

## 4. ENGINEERING REQUIREMENTS

### 4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.

### 4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

## 5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
3		0-30 Power supplies
1		Mark II breakout box

<p><b>LOU-GED-115D2277Gxxx</b> <b>REV. A</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i></p>	<p><b>Page 3 of 7</b></p>
--	--	---------------------------

## 6. TESTING PROCESS

### 6.1 Setup

#### 6.1.1 Power Inputs

6.1.1.1 +22 VDC to pin 37.

6.1.1.2 -22 VDC to pin 41.

6.1.1.3 Common to pin 39.

#### 6.1.2 Power Supplies

6.1.2.1 VTP1 = 15.7 +/- 1 VDC.

6.1.2.2 VTP2 = -15.7 +/- 1 VDC.

VR1 Full CW

6.1.2.3 I Pin 37 = 63 +/- 15ma DC.

6.1.2.4 I Pin 41 = 62 +/- 15ma DC.

#### 6.1.3 IC1 Voltages

6.1.3.1 VTP50(Violet) = 1.45 to 1.9 VDC.

VR8 CW

6.1.3.2 VTP50(Violet) = -7.5 to -6.2 VDC.

VR8 CCW

#### 6.1.4 IC1 Gains

6.1.4.1 Adjust VR8 for VTP50(Violet) = 0 VDC

6.1.4.2 Ground pin 33

6.1.4.3 +1 VDC to pin 35 (VR9 CCW)

TP7 = -5 VDC +/- .1 VDC

6.1.4.4 Move input to pin 36 = +5.0 VDC

TP7 = -2.55 to -2.48 VDC

6.1.4.5 Move input to pin 33 = +1.0 VDC

6.1.4.5.1 Move ground from pin 33 to pin 35

TP7 = -4.9 to -5.1 VDC

6.1.4.6 Move input to pin 32 = +5.0 VDC

TP7 = -2.48 to -2.55 VDC

6.1.4.7 Remove voltage from pin 32.

6.1.4.7.1 Ground pin 33.

6.1.4.8 VR8 CW

TP7 = -1.56 to -2.04 VDC.

6.1.4.9 VR8 CCW

TP7 = 6.0 to 7.0 VDC.

6.1.4.10 Set VR8 = 0.0 VDC.

<b>LOU-GED-115D2277Gxxx</b> <b>REV. A</b>	<div data-bbox="548 201 581 252" data-label="Text"> <b>g</b> </div> <div data-bbox="737 258 980 333" data-label="Text"> <b>GE Energy</b>  <i>Parts &amp; Repair Services</i>  <i>Louisville, KY</i> </div>	<b>Page 4 of 7</b>
--	--	--------------------

### 6.1.5 Meter Amplifier (IC3)

**6.1.5.1** VTP53(Black) = -22 VDC VR10 CW

**6.1.5.2** VTP53(Black) = -5.8 to -6.85 VDC VR10 CCW

**6.1.5.3** Attach a milli-ammeter from pin 24 to ground.

**6.1.5.3.1** Ground TP5 and null IC3. TP4 = 0.0 VDC.

**6.1.5.3.2** Insure that VR50 runs TP4 through zero.

**6.1.5.3.3** Remove ground at TP5.

**6.1.5.4** Apply 10.0 VDC to pin 6.

**6.1.5.4.1** Amp Meter = 1.5 to 1.6 ma DC VR5 CW

**6.1.5.4.2** Amp Meter = 0.82 to 0.92 ma DC VR5 CCW

**6.1.5.4.3** Remove amp meter from pin 24.

### 6.1.6 Summing Amplifier (IC2)

#### 6.1.6.1 Voltage Ranges

**6.1.6.1.1** VTP60(Violet) = 0.0 VDC VR4 CCW

**6.1.6.1.2** VTP60(Violet) = -5.0 to -6.0 VDC VR4 CW

**6.1.6.1.3** VTP55(Green) = 0.0 VDC VR7 CCW VR53 CCW

**6.1.6.1.4** VTP55(Green) = -12 to -14.1 VDC VR7 CW

**6.1.6.1.5** VTP51(White) = 5.42 to 5.58 VDC VR1 CCW VR2 CW

**6.1.6.1.6** VTP51(White) = 19.02 to 19.49 VDC VR1 CW

#### 6.1.6.2 G3 only

**6.1.6.2.1** VTP51(White) = 7.26 to 7.3 VDC VR1 CCW VR2 CW

**6.1.6.2.2** VTP51(White) = 17.28 to 16.7 VDC VR1 CW

**6.1.6.2.3** VTP61 should read one diode drop less than VTP51 (White) = approx. .6 VDC.

**6.1.6.2.4** VTP64(Brown) = 0.0 VDC VR3 CCW VR54 CCW

**6.1.6.2.5** VTP64(Brown) = -14.17 to -15.17 VDC VR3 CCW

<p><b>LOU-GED-115D2277Gxxx</b> <b>REV. A</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i></p>	<p><b>Page 5 of 7</b></p>
--	--	---------------------------

### **6.1.6.3 Amplifier Gains**

**6.1.6.3.1** Release input to pin 6.

**6.1.6.3.2** VR7 = CCW

**6.1.6.3.2.1** Ground TP63(Black) TP66(Orange) TP62(Red) TP67(Blue)

**6.1.6.3.2.2** TP57(Blue) TP52(Red) – Shorted

**6.1.6.3.2.3** TP58(Yellow) to TP59(Gray) – Shorted

**6.1.6.3.2.4** Set VTP61 to 5.0 VDC with VR1

**6.1.6.3.2.5** VTP3 = -4.05 to -4.21 VDC VR2 CW

**6.1.6.3.2.6** VTP3 = -4.06 to -3.87 VDC VR2 CCW

**6.1.6.3.2.7** Remove all grounds TP63(Black) TP66(Orange) TP62(Red)  
TP67(Blue) and the short between TP57(Blue) & TP52(Red).

**6.1.6.3.2.8** Ground TP7, TP54(Brown), TP61(White), TP5, TP66(Orange),  
TP65(Green).

**6.1.6.3.2.9** Input 1 VDC to TP56(Orange)

**6.1.6.3.2.10** VTP3 = -1.23 to -1.27 VDC VR55 & VR6 CCW

**6.1.6.3.2.11** Reduce input TP56(Orange) = .2 VDC

**6.1.6.3.2.12** VTP3 = -9.54 to -11.86 VDC VR55 & VR6 CW

**6.1.6.3.2.13** Put a negative voltage into TP56(Orange) until TP3 stops changing.  
Final value (limit) is 5.79 to 5.96 VDC. Input will be about -4.5 VAC.  
Pull jumper between TP58(Yellow) and TP59(Gray). Voltage at TP3  
will be about 0.33 VDC.

**6.1.6.3.2.14** Replaced jumper TP58(Yellow) and TP59(Gray).

**6.1.6.3.3** Remove grounds then

**6.1.6.3.3.1** TP57(Blue) to TP52(Red) shunted.

**6.1.6.3.3.2** TP66(Orange), TP63(Black), TP61(White) grounded.

**6.1.6.3.3.3** Input +5.0 VDC to TP56(Orange).

**6.1.6.3.3.4** Set TP54 for -5.0 VDC with VR7. (Note TP55(Green) is one diode drop more than TP54(Brown) = approx. -5.7 VDC).

**6.1.6.3.3.5** Read TP3 = -0.97 VDC +/- .14 VDC.

**6.1.6.3.3.6** Set VR53 full CW. TP3 = -4.025 to -4.38 VDC.

**6.1.6.3.3.7** Read TP7 = approx. 0 VDC (no inputs)

**6.1.6.3.3.8** Set VR7 full CCW.

**6.1.6.3.3.9** Set TP7 for +5.0 VDC with VR8. Remove +5.0 VDC from TP56(Orange).

**6.1.6.3.3.10** Set VR51 full CCW.

**6.1.6.3.3.11** Read TP3 = -9.85 to -10.25 VDC.

**6.1.6.3.3.12** Set VR51 full CW.

**6.1.6.3.3.13** Read TP3 = -.342 to -.432 VDC.

**6.1.6.3.3.14** Read TP54(Brown) = approx. 0.0 VDC

**6.1.6.3.3.15** Remove grounds.

**6.1.6.3.3.16** Ground TP61(White), TP62(Red), TP67(Blue).

**6.1.6.3.3.17** Re-apply +5 VDC to TP56(Orange).

**6.1.6.3.3.18** Set TP65(Green) for -5.0 VDC with VR3.

**6.1.6.3.3.19** Read TP63(Black) = Approx. 0 VDC.

**6.1.6.3.3.20** VR54 full CW

**6.1.6.3.3.21** Read TP3 = -0.75 to -1.05 VDC.

**6.1.6.3.3.22** VR54 full CCW.

**6.1.6.3.3.23** TP3 = -4.5 to -4.82 VDC.

**6.1.6.3.3.24** Set VR3 full CCW and Set VR52 CW.

**6.1.6.3.3.25** Move the +5.00 VDC input from TP56(Orange) to pin 6.

**6.1.6.3.3.26** TP65(Green) = approx. 0 VDC

**6.1.6.3.3.27** TP3 = -9.85 to -10.25 VDC

**6.1.6.3.3.28** VR52 full CCW.

**6.1.6.3.3.29** TP3 = -0.338 to -0.435 VDC

**6.1.6.3.3.30** Remove all power input from the card

LOU-GED-115D2277Gxxx REV. A	g  <b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i>	Page 7 of 7
--------------------------------	--	-------------

#### 6.1.6.3.3.31 End of Test

**6.2 Post Testing Burn-in**                      **Required**     \_\_\_ Yes     \_\_\_ No



**Note:** All MARK I, II, & III Turbine related cards require a post testing burn-in of 100 hours.

**6.2.1**    Apply BUS or Operational power to the card for a period of 100 hours.

**6.2.2**    Re-test card while warm using the above procedure.

**6.3    \*\*\*TEST COMPLETE \*\*\***

## 7. NOTES

**7.1**    None at this time

## 8. ATTACHMENTS

**8.1**    None at this time