

g

GE Energy

Functional Testing Specification*Parts & Repair Services
Louisville, KY***LOU-GED-DS200TCEBG1****Test Procedure for a Protection Termination Expander****DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Scott Cash	3-12-2009
B	Added Data Sheet to procedure, Page 5	C. Wade	4/2/2009
C	Added comments to section 6-2 and reviewed procedure	J Hardin	5/12/2009
D	Changed voltage from 24 to 12 volts in line 6.2.12.	J. Hardin	7/28/2009
E	Change function generator to Variac	J. Hardin	10/14/2009
F	Added section 6.2.14	J. Hardin	8/25/2011
G	Changed wording in procedure	J. Hardin	12/7/2011

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Scott Cash	REVIEWED BY J Hardin	REVIEWED BY J Hardin	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 3/12/2009	DATE 5/12/2009	DATE 12/7/2011	DATE 3/12/2009

LOU-GED-DS200TCEBG1 REV. G	g GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 2 of 5
-------------------------------	------------------------------------------------------------------------------------------	-------------

1. SCOPE

1.1 This is a functional testing procedure for a Card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check electronic folder for more information

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		Variac

6. TESTING PROCESS

6.1 Setup

6.1.1 You will need two Fluke meters, a Variac outputting 10VAC sine wave and some clip on meter leads

6.1.2 Perform the following additional inspections from factory test procedure.

6.1.2.1 Verify that no shorts exist between adjacent traces

6.1.2.2 Using the material list, verify that all parts shown on the silk-screen are present, and are assembled per the silk-screen.

6.1.2.3 Verify proper part number and mounting of T5, T6 and T7.

6.1.2.4 Verify that all leads are properly soldered and connections are properly filleted and clipped.

6.2 Testing Procedure

6.2.1 Verify the following resistance between the cathode terminal of CR1, 2, or 3 (cathodes are tied together) and the points below: The DS200TCEBG1A only has the JVA connector, whereas the DS200TCEBG1B has both the JVA & JVB connectors.

DS200TCEBG1A

JVA-1	809K to 842K
JVA-2	809K to 842K
JVA-3	809K to 842K
JVA-4	809K to 842K
JVA-5	809K to 842K
JVA-6	809K to 842K
JVA-7	809K to 842K
JVA-8	809K to 842K

DS200TCEBG1B

JVA-1	809K to 842K
JVA-3	809K to 842K
JVA-5	809K to 842K
JVA-7	809K to 842K
JVB-1	809K to 842K
JVB-3	809K to 842K
JVB-5	809K to 842K
JVB-7	809K to 842K

6.2.2 With (-) minus lead on cathode of CR1 and Fluke meter set to diode test, verify reading of 0.50 to 0.85 to each of the following points:

JWX-1
JWY-1
JWZ-1

6.2.3 Verify the resistance between each pair of points listed below:

JV-1	JV-2	1.220 to 1.820K ohms
JV-3	JV-2	1.220 to 1.820K ohms
JV-4	JV-5	1.220 to 1.820K ohms
JV-6	JV-5	1.220 to 1.820K ohms
JKX-11	JKX-12	16.5 to 24.9 Ohms
JKX-10	JKX-12	16.5 to 24.9 Ohms
JPU\V\W-4	JPU\V\W-5	20 to 32 Ohms
JPU\V\W-6	JPU\V\W-7	20 to 32 Ohms
JPU\V\W-8	JPU\V\W-9	20 to 32 Ohms
JMP-6	JMP-9	21 to 32 Ohms
JMP-7	JMP-9	22 to 32 Ohms
JMP-8	JMP-9	23 to 32 Ohms

6.2.4 Using the variac, apply 10 +/- .01 volts rms at 60 Hz between JV-1 and JV-2 (continue to monitor on Fluke 8050A or equiv. for rest of test).

6.2.5 Adjust R20 until the voltage across JMP-1 and JU-16 is (.4350 +/- .0002 volts rms).

6.2.6 Attach the variac at the same setting to JV-2 and JV-3.

6.2.7 Adjust R22 until the voltage across JMP-3 and JU-16 is (.4350 +/- .0002 volts rms).

6.2.8 Attach the variac at the same setting to JV-4 and JV-5

6.2.9 Adjust R21 until the voltage across JMP-2 and JU-16 is (.4350 +/- .0002 volts rms).

6.2.10 Attach the variac at the same setting to JV-5 and JV-6.

6.2.11 Adjust R23 until the voltage across JMP-4 and JU-16 is (.4350 +/- .0002 volts rms).

6.2.12 Test the beeper by applying <12 volts DC between JU-18 (+) and JU-17 (-). You may wish to hold one finger over top of the beeper so it won't sound so loud.

6.2.13 If card passes all the above tests, seal all pots and apply proper stamps.

6.2.14 Seal pots R20 thru R23

6.3 *TEST COMPLETE*****

7. NOTES

7.1 None at this time

8. ATTACHMENTS

8.1 See Data Sheet on next page

Data Sheet for Test for __LOU-GED-DS200TCEB__

Test Procedure Step	Nominal	Lower Limit	Results	Upper Limit	Pass/Fail
6.2.1-1	820K ohms	809K ohms		842K ohms	
6.2.1-2	820K ohms	809K ohms		842K ohms	
6.2.1-3	820K ohms	809K ohms		842K ohms	
6.2.1-4	820K ohms	809K ohms		842K ohms	
6.2.1-5	820K ohms	809K ohms		842K ohms	
6.2.1-6	820K ohms	809K ohms		842K ohms	
6.2.1-7	820K ohms	809K ohms		842K ohms	
6.2.1-8	820K ohms	809K ohms		842K ohms	
6.2.2-1	.540	.500		.850	
6.2.2-2	.540	.500		.850	
6.2.2-3	.540	.500		.850	
6.2.3-1	1.6K ohms	1.22K ohms		1.82K ohms	
6.2.3-2	1.6K ohms	1.22K ohms		1.82K ohms	
6.2.3-3	1.6K ohms	1.22K ohms		1.82K ohms	
6.2.3-4	1.6K ohms	1.22K ohms		1.82K ohms	
6.2.3-5	20.7 ohms	16.5 ohms		24.9 ohms	
6.2.3-6	20.7 ohms	16.5 ohms		24.9 ohms	
6.2.3-7	26 ohms	20 ohms		32 ohms	
6.2.3-8	26 ohms	20 ohms		32 ohms	
6.2.3-9	26 ohms	20 ohms		32 ohms	
6.2.3-10	26 ohms	20 ohms		32 ohms	
6.2.3-11	26 ohms	20 ohms		32 ohms	
6.2.3-12	26 ohms	20 ohms		32 ohms	
6.2.5 *	.4350V RMS	.4348V RMS		.4352V RMS	
6.2.7 *	.4350V RMS	.4348V RMS		.4352V RMS	
6.2.9 *	.4350V RMS	.4348V RMS		.4352V RMS	
6.2.11 *	.4350V RMS	.4348V RMS		.4352V RMS	

* Note must use true RMS meter or digital scope