



GE Energy

Functional Testing Specification

Parts & Repair Services
Louisville, KY

LOU-GED-DS200TBCAG1A

Test Procedure for a DS200TBCAG1A

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column


REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Steve Pharris	02/10/12
B	Clarified burn-in requirements	C. Wade	12/17/2013
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Steve Pharris	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 02/10/2012	DATE	DATE	DATE 2/16/2012

LOU-GED-DS200TBCAG1A REV. B	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 2 of 6
--	--	--------------------

1. SCOPE

1.1 This is a functional testing procedure for a DS200TBCAG1A.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

3.1.2 Reference sheets DS200TBCA_AASH4AA thru DS200TBCA_AASH4CA can be found in the following directory, N:\Design Folders\DS\DS200\DS200T\DS200TB\TBCA.

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.


Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		LCR 103


6. Testing Process


6.1 Testing Procedure

6.1.1 Verify continuity per DS200TBCAG_AASH4AA through SH4CA.

6.1.2 Verify capacitor values per same chart. Check BOM for tolerance levels of cap.







<p>LOU-GED-DS200TBCAG1A REV. B</p>	<p>g</p> <p>GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 6 of 6</p>
---	--	---------------------------

6.2 For all normal repairs; card does not have any active components so unit does not require any burn-in.

6.3 *****TEST COMPLETE** ***

7. Notes

7.1 None at this time.

8. Attachments

8.1 None at this time.