



GE Energy

## Functional Testing Specification

Parts & Repair Services  
Louisville, KY

LOU-GED-IS200ITBA

### Test Procedure for a DC Drive Terminal Board IS200ITBA

**DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Cristyn Edlin	5/6/2013
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

<b>PREPARED BY</b> Cristyn Edlin	<b>REVIEWED BY</b>	<b>REVIEWED BY</b>	<b>QUALITY APPROVAL</b> <i>Charlie Wade</i>
<b>DATE</b> 5/6/2013	<b>DATE</b>	<b>DATE</b>	<b>DATE</b> 5/8/2013

<p><b>LOU-GED-IS200ITBA REV. A</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> Parts &amp; Repair Services Louisville, KY</p>	<p><b>Page 2 of 5</b></p>
--	--	---------------------------

## 1. SCOPE

1.1 This is a functional testing procedure for an IS200ITBA.

## 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

## 3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information.

3.1.2 Schematic IS200ITBAG#AA.

## 4. ENGINEERING REQUIREMENTS

### 4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.

### 4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires: broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors: broken or cracked

4.2.1.3 Components: visually damaged

4.2.1.4 Capacitors: bloated or leaking

4.2.1.5 Solder joints: damaged or cold

4.2.1.6 Circuit board: burned or de-laminated

4.2.1.7 Printed wire runs / Traces: burned or damaged

## 5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.


Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)

<p><b>LOU-GED-IS200ITBA REV. A</b></p>	<p><b>g</b></p> <p><b>GE Energy</b> Parts &amp; Repair Services Louisville, KY</p>	<p><b>Page 3 of 5</b></p>
--	--	---------------------------

## 6. TEST PROCESS

**6.1** Ensure less than 1 ohm between each of the following points. You are checking for continuity between these points.

- 6.1.1** TB1-1 to TBP1-20.
- 6.1.2** TB1-2 to TBP1-10.
- 6.1.3** TB1-3 to TBP1-19.
- 6.1.4** TB1-4 to TBP1-9.
- 6.1.5** TB1-5 to TBP1-18.
- 6.1.6** TB1-6 to TBP1-8.
- 6.1.7** TB1-7 to TBP2-16.
- 6.1.8** TB1-8 to TBP1-17.
- 6.1.9** TB1-9 to TBP2-8.
- 6.1.10** TB1-10 to TBP1-7.
- 6.1.11** TB1-11 to TBP1-16.
- 6.1.12** TB1-12 to TBP1-6.
- 6.1.13** TB1-13 to TBP1-15.
- 6.1.14** TB1-14 to TBP2-15.
- 6.1.15** TB1-15 to TBP1-5.
- 6.1.16** TB1-16 to TBP2-7.
- 6.1.17** TB1-17 to TBP1-14.
- 6.1.18** TB1-18 to TBP2-14.
- 6.1.19** TB1-19 to TBP1-4.
- 6.1.20** TB1-20 to TBP2-6.
- 6.1.21** TB1-21 to TBP1-13.
- 6.1.22** TB1-22 to TBP2-13.
- 6.1.23** TB1-23 to TBP1-3.
- 6.1.24** TB1-24 to TBP2-5.
- 6.1.25** TB1-25 to TBP1-12.
- 6.1.26** TB1-26 to TBP2-12.
- 6.1.27** TB1-27 to TBP1-2.
- 6.1.28** TB1-28 to TBP2-4.
- 6.1.29** TB1-29 to TBP1-11.
- 6.1.30** TB1-30 to TBP2-11.

<b>LOU-GED-IS200ITBA REV. A</b>	  <b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i>	<b>Page 4 of 5</b>
-------------------------------------	--	--------------------

- 6.1.31** TB1-31 to TBP1-1.
- 6.1.32** TB1-32 to TBP2-3.
- 6.1.33** TB1-33 to TBP2-10.
- 6.1.34** TB1-34 to TBP2-9.
- 6.1.35** TB1-35 to TBP2-2.
- 6.1.36** TB1-36 to TBP2-1.
- 6.1.37** TB1-37 to TBP3-24.
- 6.1.38** TB1-38 to TBP3-23.
- 6.1.39** TB1-39 to TBP3-12.
- 6.1.40** TB1-40 to TBP3-11.
- 6.1.41** TB1-41 to TBP3-22.
- 6.1.42** TB1-43 to TBP3-10.
- 6.1.43** TB1-44 to TBP3-20.
- 6.1.44** TB1-46 to TBP3-8.
- 6.1.45** TB1-47 to TBP3-19.
- 6.1.46** TB1-48 to TBP3-18.
- 6.1.47** TB1-49 to TBP3-7.
- 6.1.48** TB1-50 to TBP3-6.
- 6.1.49** TB1-51 to TBP3-17.
- 6.1.50** TB1-52 to TBP3-16.
- 6.1.51** TB1-53 to TBP3-5.
- 6.1.52** TB1-54 to TBP3-4.
- 6.1.53** TB1-57 to TBP3-13.
- 6.1.54** TB1-58 to TBP3-14.
- 6.1.55** TB1-59 to TBP3-1.
- 6.1.56** TB1-60 to TBP3-2.
- 6.1.57** TB1-42 to TB1-45 to TB1-55 to TB1-56 to E1 to E2.
- 6.1.58** TB2-1 to ECPL-1.
- 6.1.59** TB2-3 to ECPL-2.
- 6.1.60** TB2-9 to 4PL-1.
- 6.1.61** TB2-10 to 4PL-2.
- 6.1.62** TB2-11 to 4PL-3.
- 6.1.63** TB2-13 to 4PL-4 to OPTPL-2.
- 6.1.64** TB2-14 to 4PL-5 to OPTPL-1.

<b>LOU-GED-IS200ITBA REV. A</b>	<b>gg</b>	<b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i>	<b>Page 5 of 5</b>
-------------------------------------	-----------	---	--------------------

**6.2   \*\*\*End of test\*\*\***

**7.   NOTES**

**7.1**   None at this time.

**8.   ATTACHMENTS**

**8.1**   None at this time.