

68A989271

REV A
NO.

TITLE

CONT ON SHEET FL. SH NO. 1

68A989271

GAYNO 15V POWER SUPPLY
TEST SPECIFICATION

CONT ON SHEET FL. SH NO. 1

FIRST MADE FOR STANDARD LINE


REVISIONS

ELEMENTARY - IC3600APSG1A 5-157 J.C

POWER INPUT - 100 VOLTS PER CIRCUIT BELOW.

LOADS - 50 OHMS, 50 WATTS
100 OHMS, 200 WATTS

CONNECT BOARD IN TEST CIRCUIT



SET OUTPUT VOLTAGE - WITH SW-1 OPEN ADJUST TRIMPOT R43 TO OBTAIN 28 (± 1) VOLTS FROM PIN 12 (+) TO PIN 34 (-).

CHECK REGULATION - CLOSE SWITCH SW-1. VOLTAGE FROM PIN 10 (+) TO PIN 34 (-) SHOULD CHANGE LESS THAN .01 VOLTS -S SWITCH IS CLOSED.

APSG

133B

K6A

S6A

PRINTS TO

MADE BY

S. POWERS

APPROVALS

B. Jarvinen

INDUSTRY CONTROL

DIV OR
DEPT

68A989271

ISSUED

June 22, 1964

SALEM, VIRGINIA

LOCATION

CONT ON SHEET FL. SH NO. 1