P3K-AL-0380-A01

CONT ON SHEET

P3K-AL-0380-A01

2

CONT ON SHEET

+

TITLE TEST INSTRUCTIONS FOR 125 VOLTA

24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002

ASS'Y DRAWING 1-1801-237-61 FIRST MADE FOR EHC MARK II

SH NO.

REVISIONS

CIRCUIT DESCRIPTION I.

1TM2-A001 CIRCUIT BOARD REVISION #1 1TM2-A002 CIRCUIT BOARD REVISION #0

This board contains the 125 volt trip system and the 24 volt trip system. The 125 volt trip system energizes the Master Trip Solenoid (MSTV) under abnormal conditions and causes the Emergency Trip System to trip the turbine. The 24 volt trip system de-energizes both Electrical Trip Solenoid Valves (ETSV) under abnormal conditions and causes the ETS to trip the turbine.

A 125 volt trip will be locked-up and cause 24 volt trip and a 24 volt trip (unless caused by Trip Anticipator action) will be locked-up and cause 125 volt trip.

Thus two lines of defense are provided at this level.

A loss of the 24V power on this board causes 24V trip and 125V trip. Loss of the 125V power causes 24V trip when speed is below 75% of rated.

Many functions on the board are performed by three relays with two out of three logic arrangement of contacts. This decreases considerably both the probability of erroneous trip command and the probability of inaction during a trip condition.

11801374

273-2 273-12

273-71 273-136

273-221

273-221

PRINTS TO

The Polacek Sept. 16, 1977 24 16, 1977

APPROVALS.

Steam Turbine _____ DEPT.

P3K-AL-0380-A01

Schenectady, New Yorkocation cont on sheet

SH NO.

TITLE

TEST INSTRUCTIONS FOR 125 VOLT/

24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, ASS'Y DRAWING 118D1574-G1, 118D1337-G1 /374

P3K-AL-0380-A01

3 CONT ON SHEET SH NO. FIRST MADE FOR

REVISIONS

CIRCUIT SPECIFICATIONS II.

DIODE REDUNDANCY 1.

Before the board is coated each diode should be checked in the reverse direction to insure redundancy is effective.

PERMANENT CONTINUITY 2.

2

Each terminal in the following groups of terminals must show permanent continuity with all other terminals of the same group (Resistance less than 0.1 Ohms):

- 1, 3, 6, 9, 14, 51, 54, 57, 67, 111, 114, 20, 27, 87, 40, 42, 46, 163, 171, 172, 175
- 2, 157

152, 179, d. 110 HPC 12/84

- 34, 36 e.
- 4,5 f.
- 7,8 g.
- 12, 13 h.
- i. 15, 16
- 52, 53, 55, 56
- 60, 61 k.
- 1. 62, 63
- 64, 70, 71, 72
- 17, 18 n.
- 23, 24, 30
- 98, 99 p.
- 100, 101
- 94, 95 r.
- 92, 93

PRINTS (C

J. Polacek Sept. 16, 1977 6214 16,1977

Steam Turbine

Schenectady, N.Y.

DIV OR

P3K-AL-0380-A01

LOCATION CONT ON SHEET

SH NO.

CODE INCAL !

+

APPROVALS

P3K-AL-0380-A01

REVISIONS

	•			
REV NO.	TITLE	CONT ON SHE	EET 4 SH NO.	3
NO.	TEST INSTRUCTIONS FOR 125 VOLT/		.	
P3K-AL-0380-A01	24 VOLT TRIP BUS CIRCUIT BOARD 17	IM2-A001	, 1TM2-A002	

4 sh NO. CONT ON SHEET

FIRST MADE FOR MARK II

CIRCUIT SPECIFICATIONS (continued)

PERMANENT CONTINUITY (continued)

3

- 164, 165
- 153, 154
- 166, 167, 168
- 107, 106
- 105, 104 х.
- 148, 149, 151

191, 192 onit ADC

- 182, 183
- 181, 180 bb.
- 184, 185 cc.

FUSED CONTINUITY

The following fuses are rated 1/8A and establish conductive paths between the two corresponding terminals, which otherwise are isolated from each other.

- 160-108 F1:
- F4: 1-103
- 1-102 F5:
- F6: 90-100
- F7: 89**-9**8
- f. F8: 88-97
- F9: 84-96
- F10: 83-94
- 85-92 i. F11:
- F12: 1-91

(Fuses F2 and F3 are rated 1/8A and are not observable from terminal points - their continuity is checked in subsequent steps).

APPROVALS DIV OR Polacek Sept. 16, 1977 Steam Turbine 64 16, 1977

P3K-AL-0380-A01

LOCATION CONT ON SHEET Schenectady, N.Y.

SH NO. CODE IDENT "

PRINTS TO

FF-803-WA (2-73) PHINTED IN U.S.A.

GENERAL (%) ELECTRIC P3K-AL-0380-A01 CONT ON SHEET TITLE TEST INSTRUCTIONS FOR 125 VOLT/ 24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002 ASS'Y DRAWING 118D1374 G1, 1180137 G1 P3K-AL-0380-A01 FIRST MADE FOR EHC MARK II CONT ON SHEET 5 SH NO. REVISIONS CIRCUIT SPECIFICATIONS (continued) II. LOGIC 4. To check the logic the following connections should be made: Terminal 1: 125 VDC 125 VDC common [1] [1] 73: / 87 74: 24 VDC common 33: 115 VAC 115 VAC common 34: 1.74K Ohms \pm 1%, 9W load (other end of load to terminal 157) 17.5 Ohms \pm 1%, 33W load (other end of load to terminal 150) 149: 17.5 Ohms \pm 1%, 33W load (other end of load to terminal 150) 151: After power supply connections are made the circuit should be RESET by momentarily applying \$24 VDC to terminal \$6 In subsequent discussion the term RESET as defined here will be used freely. All voltages are DC unless otherwise specified. In each section some of the logic outputs responses to inputs are omitted if specified in previous or subsequent Non-Latching 125V Trip 4.1 With 125 VDC connected to terminal 159 (after the circuit is RESET) MASTER 153 the following voltages should exist: Terminal 158: 125 V 00 TP18: TP19: Upon removal of this voltage from terminal 159 all three points should have 0 VDC. Typical Latching 125V Trip 4.2 This can be caused by applying 125 VDC to terminal 164; the conditions that should exist prior to and after the trip are shown in the

APPROVALS DIV OR

J. Polacek Sept. 16, 1977 15416,1977

following table:

Steam Turbine

Schenectady, N.Y.

P3K-AL-0380-A01

LOCATION CONT ON SHEET SH IIU.

CODE 15541 H

PRINTS TO

FF-803-WA (2-73) PRINTED IN U.S.A.

+

+

+

REV NO. TITLE TEST INSTR

P3K-AL-0380-A01

CONT ON SHEET

+

TITLE TEST INSTRUCTIONS FOR 125 VOLT/

TEST INSTRUCTIONS FOR 125 VOLT/
24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002

CONT ON SHEET

ASS'Y DRAWING 118D1373 G1, 11966 G1

FIRST MADE FOR

EHC MARK (II

REVISIONS

5

II. CIRCUIT SPECIFICATIONS (continued)

6 sh No.

4.2 Typical Latching 125V Trip (continued)

5

TABLE I

		,					Y
INPU	rs at		C	REMARKS			
164	153 (RESET INPUT)	158 161 162 TP18 TP19	184 186 TP30 TP31	193 TP23 TP24	TP20 TP21 TP22	TP16 TP17	
ΟV	OV	OV	OV	24V	O RAME	ov	Res. between TP16-TP17, TP17-161, TP30-TP31 and TP31-186 should be more than 10M Ohms.
125V 125V		125V 125V	24V 24V	ov ov	SAN CONTRACTOR	0V 125V	After 0.1 <u>+</u> 0.02 sec.
OV	OV	125V	24V	ov	78H	125V	Res. between TP23- RP24 and TP24-193 should be more than 10M Ohms.
ΟV	24V	OV	OV	24V	OAM	OV	
οV	OV	ov	OV	24V	O ZHAK	OA	

The time intervals between the moment at which voltage at terminal 193 goes from 24V to 0V and the moments at which voltages at TP20, TP21, and TP22 go from to should be sec. ± 0.002 sec.

The correct function of the 2 out of 3 logic of relays K18, 19, 20, and 23, 24, 25 is verified by the resistance measurements under REMARKS (Table I) and in addition by the following:

- a. With circuit reset and any one of K18, 19, or 20 removed (unplugged) voltage at 193 should be 24V.
- b. With circuit tripped and any one of K18, 19 or 20 unplugged voltage at 186 should be 24V.
- c. With anyone of K23, 24, 25 unplugged the circuit trip is still being latched in (24V at 158 after removal of input at 164). 933^{10}

J. Polacek Sept. 16, 1977

Steam Turbine

ON OR

P3K-AL-0380-A01

Schenectady, N.Y. Location CONT ON SHEET 6 SH NO. 5

FF 803-V/A (2-73) PRINTED IN U.S.A. CODE TOEHT NO

CONT ON SHEET TITLE TEST INSTRUCTIONS FOR 125 VOLT/ 24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002 P3K-AL-0380-A01 ASS'Y DRAWING 118D1374 G1, 118D1397 G1 EHC MARK II FIRST MADE FOR CONT ON SHEET SH NO.

CIRCUIT SPECIFICATIONS (continued)

REVISIONS

6

4.3 Other Latching 125V Trips

The following conditions should also cause latching 125V trip. It is not necessary to verify the compliance with Table I, since this was done for the case 4.2 (terminal 164). The occurance of trip is sufficiently verified by observing 125V at terminal 158. The circuit should be RESET after each condition is created and the trip verified before creating the next condition.

- a. Momentary application of 125 V to terminal 4 causes 125 V trip. (Momentary here and subsequently means having a duration more than 0.2 sec. but not sustained; essentially it is a short way to say that the trip is latched after removal of the input).
- Momentary application of 125 V to terminal 7 causes 125 V trip. b.
- Momentary application of 125 V to terminal 12 while 24 V is applied to only one or none of the terminals 76, 77, 78 causes 125 V trip, and 125 V voltage to appear at TP1 and TP2. (All 4 cases should be verified). (TP15102 Read 125V ON V White 125V AS APPEAD. To Termino 1d. 158 should read 125V until Chris reset) On the contrary momentary application of 125 V to terminal 12 while 24 V is applied to any two, or to all three of the terminals 76, 77, 78 does not cause trip. (At least the first 3 of the 4 cases should be verified).
- Momentary application of 125 V to terminal 15 causes 125 V trip. d.
- Momentary application of 125 V to terminal 52 causes 125 V trip. e.
- Momentary application of 125 V to terminal 60 causes 125 V trip. In addition as long as 125 V is applied to terminal 60 the voltage of terminal 80 becomes OV while otherwise it is 24 V.
- Momentary application of 125 V to terminal 62 causes 125 V trip. ģ.
- Application of 125 V to terminal 64 causes after 10 sec. \pm 1 sec. this voltage to appear at TP4, TP3, and terminal 32 and produces a trip. Subsequent removal of the input makes all points to return to OV while the trip is latched. (For board 118D1337G1 the time is 5 min. + 0.5 min.) These statements hold true even if any one of relays K51, K52, K53 is unplugged. When 64 voltage is OV, the resistance between TP3-TP4 and 32 - TP3 should be more than 10M Ohms, and TP4 voltage OV.
- Momentary application of 125 V to terminal 17 causes 125 V trip.
- Momentary application of 125 V to terminal 23 causes 125 V trip. *In this case the trip is resettable even if the input is still on. The details of the function of this part of the circuit are given in ON 1180 1374 G 1, Ga, G.Z NOT TRUE

J. Polacek	Sept.	16,	1977
ICSUED SECAY	416,	197	7

Steam Turbine Schenectady, New Yorkocation cont on SHEET

P3K-AL-0380-A01

SH NO.

6 CODE TOENT N'

FF-803-WA (2-73) PRILITED IN U.S.A.

+

+

TEST INSTRUCTIONS FOR 125 VOLT/

TITLE

CONT ON SHEET

TABLE II

P3K-AL-0380-A01

CONT ON SHEET

THISPART

OFCHART

DOES NOT APPLY To 11801374 6-1,62,63

SH NO.

118D1374 G1, T18D1337 G1 ASS'Y DRAWING

FIRST MADE FOR EHC MARK II

II. CIRCUIT SPECIFICATIONS (continued)

REVISIONS

PRINTS TO

- 4.3 Other Latching 125V Trips (continued)
 - (continued) i.

Table II:

* NOT USED ON 118013746162,63

24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002

,	INPU'	TS AT	CORRECT OUTPUTS AT										
	23	153 (RESET)	158 (TRIP)	19	31	81	82	121	122				
フ -	0V 125V 125V 125V 0V	-24V -0V -0V	——	i I	125V - 0V	•	0V 24V 0V 0V	24V OV OV OV 24V	OV 24V 24V 24V OV				
_	7	-0V -0V 24V -0V	125V 125V OV OV	125V OV OV OV	0V 0V 0V	0V 24V 24V 24V	24V OV OV OV	0V 24V 24V 24V	24V- OV OV OV				
			<u> </u>	l	<u> </u>	<u> </u>	L		<u> </u>				

Momentary application of 125V to terminal 89 or 83 causes 125 V trip. This is the Thrust Bearing Wear Detector Trip. The logic permits testing the circuit without tripping, continuous monitoring of the actuating pressure switch contacts, interlocking between the two testing circuits and other fail safe features.

The function of this circuit is described in Table III. is in fact two tables with different headings and identical entries superimposed. The upper heading coresponds to the lower bearing circuit and vise versa.

Part of the circuit logic is not included in Table III for clarity. It is given in Table IV.

J. Polacek Sept. 16, 1977 APPROVALS DIV OR STeam Turbine P3K-AL-0380-A01 _ DEPT. AUN-16,1977 Schenectady, N.Y. LOCATION CONT ON SHEET CODE HEENT TO

FF 803-WA (2-73) PRINTED IN U.S.A

REV ()						TITLE	:	E N							*******	VOI :		1	P3K-			80- <i>i</i> 9 ·	\01 5н г	no. 3
P3K-		0380-	-A01 9 sh no.	8		FIRST	24	VOI	LT^{-1}	TRI	ΡВ	US (CIR	CUI	тв	OAR		IM2	-A0(01,	11	M2	A002	
			T			talah dalkariyas			*********															REVISIONS
(0)		TP11	DETECTOR TP15	 DETECTOR	0	0	0	0,	0	0	125V	125V	125V	125V	125V	125V	0	0	0	0	0	0	0	
0		\circ	WEAK D	WEAR D	0	0	0	0	0	. 0	0	0	125V	125V	125V	125V	125V	125V	0	0	0	0	0	
1 7		TP9	BEAKING 2 TP13	BEARING	0	0	0		0	125V	125V	125V	125V	125V	125V	125V	125V	125V	· 0	0	0	0	0	
de de la companya de	UTPU	α	Ii	ī	125V	125V	125V	125V	125V	125V	125V	125V	125V	0	125V	125V	125V	125V	125V	125V	125V	125V	125V	
2	RECT	35	LOWER 37 TP:	UPPER	0	0	0	0	0	0	115VAC	115VAC	115VACI	115VAC	115VAC	115VAC	0	0	0	0	0	0	0	
ہر	COR	44	87		0	0	. 0	0	0	125V	125V	125V	125V	0	125V	0	0	0	0	0	0	0	0	
	4	88	84		0	125V	0	0	0	0	0 4			源	Ac Zec	**	ASE 1350	0	0	0	0	0	0	
	~	158 TRIP			0	125V	125V	0		0	0		0		0	0	0	0	0	0	0	0	0	
	N	131	135		240	24Λ	24Ω	24V	24V	0	0	0	0	0	0	0	0	0	24V	247	24∇	24Λ	24V	
sw (Bis		124	128		0	0	0	0	0	0.	0	0	24V	24Λ	240	24V	24V	24Λ	0	0	0	24V	O CONTRACTOR CONTRACTO	
E III																								
TABLE		153 RESET			0	0	0	240	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	-	45	67		0	0	0	0	0	0	125V	125V	125V	125V	125V	125V	0	0	0	125V	0	0	0	
		43	147		0	0	0	0	0	0	0	0	125V	125V	125V	125V	125V	125V	0	0	0	125V	0	
	S AT	68	83	:	0	125V	0	0	0	0	0	125V	:125V	125V	125V	125V	125V	0	0	0	0	0	0	
,	INPUTS	127	123		0	0	0	0	0	0	0	0	0	24V	0	0	0	0	0	0	0	0	0	
		123	127		0	0	0	0	0	24V	24Λ	24V	24Λ	24V	24Λ	0	0	0	0	0		0	0	PRINTS TO
MADE 97 J. PO. ISSUED FF-803-VIA PRINTED III	E fin	f /				API	PROVAI	LS		eau hen			ne_N	1.T.			DIV OF DEPT	1				380 9		HO. 8-

+

+

P3K-AL-0380-A01

CONT ON SHEET

TEST INSTRUCTIONS FOR 125 VOLT/ 24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002 ASS'Y DRAWING 118D1374G1, 118D137 GI FIRST MADE FOR ENC MARK II P3K-AL-0380-A01 REVISIONS 0 0 0 0 0 0 0 0 0 0 **\$** 0 22 Q FU 55 \$ € 334 N E SOROS Γ TABLE 41 0 0 0 0 0 0 0 0 0 0 0 0 , 137 133 PRINTS TO J. Polacek Sept. 16, 1977 Steam Turbine DEPT. P3K-AL-0380-A01

FF-BO3-WA (2-73) PRINTED IN U.S.A

155UCO Step 4-16, 1977

+

Schenectady, N.Y. LOCATION CONT ON SHEET: 10

CONT ON SHEET REV / TITLE 11 TEST INSTRUCTIONS FOR 125 VOLT/ 24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002 P3K-AL-0380-A01 ASS'Y DRAWING 118D1374 G1, 119D1397 G1 11 зн но. FIRST MADE FOR CONT ON SHEET

CIRCUIT SPECIFICATIONS (continued)

REVISIONS

4.4 24V Trip, Non Latching, Non-Crosstripping

a. Applying 24V to any two or all three of terminals 141, 144, 147 causes 24V trip, ie. deneergizes the two Electrical Trip Solenoids connected to terminals 149, 151. In addition to the trip these inputs energize relay K55 on the circuit board.

The term non crosstripping implies that these inputs do not cause a 125V trip. (This refers to the circuit board level; at the system level a given condition may create simultaneous 125V trip by energizing two inputs to the board.) When the inputs are removed, the circuit resets by itself (non latching).

The function of this part of the circuit is described in Table V.

The logic related to K55 will be specified later.

b. Application of 24V to terminal 140 causes 24V nonlatching noncrosstripping trip. To verify the trip here and in subsequent steps it is sufficient to observe OV at terminal 148.

4.5 24V Trip, Latching, Non-Crosstripping

Application of 24V to terminal 139 causes 24V to appear at TP38 and (after 0 + 0.002 sec) at TP40.

Application of 24V to terminal 143 causes 24V to appear at TP42 and (after 0.14 0.02 sec) at TP44.

Application of a 24V to terminal 146 causes 24V to appear at TP46 and (after 0:1 + 0.102 sec) at TP48.

Application of 24V to anyone (only one) of these terminals does not cause a 24V trip.

Simultaneous application of 24V for over 0.12 sec. to any two or all three of terminals 139, 143 or 146 causes 24V trip that is latched after removal of the inputs and can be reset (only after removal of the inputs) by applying 24V to terminal 153 (as for 125V trips).

During this trip 24V should appear also at TP27, TP28, TP29 and terminal 184.

APPROVALS J. Polacek Sept. 16, 1977 pr-16, 1977

Steam Turbine

Schenectady, N.Y.

DIV OR _ DCPT.

P3K-AL-0380-A01

LOCATION CONT ON SHEET

sн No. 10

PE-803-WA (2-73)

+

COOR IDENT HI

GENERAL (%) ELECTRIC P3K-AL-0380-A01 CONT ON SHEET REV () 12 TITLE TEST INSTRUCTIONS FOR 125 VOLT/ 24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-AQ01, 1TM2-A002 P3K-AL-0380-A01 118D1374 G1, 118D1337 ASS'Y DRAWING FIRST MADE FOR 12 11 EHC MARK II CONT ON SHEET SH NO. REVISIONS II. CIRCUIT SPECIFICATIONS (continued) 24V Trip, Latching, Non-Crosstripping (continued) 4.5 Application of 24V for over 0.12 sec to terminal 181 causes 24V latching trip. Disconnecting the 125 VDC power supply to the board (terminal 1) causes 24V to appear at terminal 79. In addition to the above disconnecting the 125V supply to the board and at the same time applying 24V to anyone of terminals 76, 77, or 78 causes 24V to appear at TP34, 35, or 36 respectively, but not a trip. Finally disconnecting the 125V supply and at the same time applying 24V to any two or all three of terminals 76, 77, or 78 causes 24V latching trip. (All other output conditions are non latching). 4.6 24V Trip, Latching, Crosstripping Application of 24V to any one (only one)of terminals 138, 142 or 145 causes 24V to appear at the corresponding TP37, 41 or 45 but not a 24V or a 125V trip and does not cause 24V to appear at terminal 156. Application of 24V to any two or all three of terminals 138, 142, or 145 causes (1) 24V latching trip, (2) 125V trip, (3) 24V to appear at 156, TP32 and TP33, and (4) 125V to appear at 107 (only if F2 is in place), 105 (only if F3 is in place, and 160. b. Application of 24V to terminal 182 causes latching 24V trip and 125V trip. 4.7 Auxiliary Logic Table VI specifies the function of minor parts of the circuit board which was not included in the previous sections mainly to prevent excessive complexity of the tables there.

4.8 Lamp Test Circuit

Common 186

With +24 VDC power supply disconnected from terminal and connected to terminal 75,44 oltage of 24V or slightly less will appear at the following terminals:

80, @, 121, 122, 124, 125, 128, 129, , 189, 189, 190.

The exact voltage value is 24 volts minus the voltage drop across the 68.1 ohms resistors and depends on the loading during the measurement, and should be observed to detect any erroneous resistance values. 10 MA loading the acceptable voltage drop is 681 ± 7 mV.)

APPROVALS J. Polacek Sept. 16, 1977 DIV OR Steam Turbine P3K-AL-0380-A01 15SUED Scip416, 1977 SH NO. 11 Schenectady, N.Y. LOCATION CONT ON SHEET CODE IDENT !

+

JE STAIRG

GENERAL & ELECTRIC

P3K-AL-0380-A01

CONT ON SHEET 13 TITLE TEST INSTRUCTIONS FOR 125 VOLT/

P3K-AL-0380-A01

REV 🔿

CONT ON SHEET 13 sh No. 12

24 VOLT TRIP BUS CIRCUIT BOARD 1TM2-A001, 1TM2-A002 ASS'Y DRAWING 118D1374G1, 118D137761 FIRST MADE FOR EHC MARK II

> REVISIONS TO A TO THE ST

П					TAB	LE V									
		•			,										
	IN	PUTS AT	TERMIN	NALS		CORRECT OUTPUTS AT TERMINALS OR TEST POINTS									
					1.	ح	3	OR TEST	r POINTS	6	\				
		141	144	147	TP 39	TP43	TP47	TP25	TP26	177	į				
	1.	0	0	0	0	0	0	0	0	0					
	2.	24	0	0	24	0	0	125	0	. 0					
	3.	0	24	0	0	24	0	125	125	0					
	4.	0	0	24	0	0	24	0	0	0					
	5.	24	24	0	24	24	-0	125	125	125					
	6.	24	0	24	24	0	24	125	125	125					
	7.	0	24	24	0	24	24	125	125	125 '					
	8.	24	24	24	24	24	24	125	125	125					
					(continued	below)									

إصدسي					
	7	CORRECT C	OUTPUTS AT TERMIN	IALS OR TEST POIN	ITS
	117	118	119	120	148
1.	23.865 <u>+</u> 0.003V	23.865 <u>+</u> 0.003V	23.865 <u>+</u> 0.003V	23.865 <u>+ 0</u> .003V	23.729 <u>+</u> 0.005V
2.	23.600 ± 0.008V	23.733 <u>+</u> 0.006V	23.600 ± 0.008V	$23.733 \pm 0.006V$	23.333 ± 0.013
3.	23.734 <u>+</u> 0.005V	23.468 + 0.011V	$23.379 \pm 0.012V$	23.468 ± 0.011V	23.290 ± 0.014V
4.	23.822 ± 0.004V	23.912 ± 0.003V	$23.822 \pm 0.004V$	23.556 ± 0.008V	23.290 ± 0.014V
5.	0.000v	0.000V	0.000v	0.000v	0.000V
6.	24.000V	24.000V	24.000V	24.000V	0.000V
7.	24.000V	24.000V	0.000V	0.000v	0.000V
8.	0.000V	0.000V	0.000 v	0.000V	0.000V
1 '		l			<u> </u>

Measurements made with a 24.000V power supply to the board.

J. Polacek Sept. 16, 1977 APPROVALS DIV OR Steam Turbine __ _ DEPT. ISSUED LEAY 16.1977

P3K-AL-0380-A01

+

sн но. 12

					GI	ENE	RAL	(36)	ELE	CTR	RIC				AL-038			
P3K-AL-03	80-A01 14 sh	_{NO.} 1	3	TITLE FIRST	24	V.С s ' Y	DRAW	RIP	BUS	CIRC 118D	UIT 1374	VOLT BOAR G1,	/ D I	TTM2-A	A001,		-Λ002	
5	190	24	24	24	24	24	24	24	24	24	3 24	24	0	24			RE	VISIONS
೨	189	0	0	0	0	0	0	0	0	0	0	0	\$28	0				
	(88)	12/	4	A	4/	72	44	4	14/	12/	14/	404	10	24	-			•
	1821	161	18	10/	1	10/	6	9	6	19	7	10/	the state of the s	7				
\	130	0	0	0	0	o ·	0	0	24 1/	0	0	0	0	0				-
OUTS AT	177	0	0	0	125	125	125	0	0	0	0	o J	0	0				
T OUTPUTS	194	27.0	**	O	624	* CO	S # 24	M. 0	6	9	だる	74 ************************************	22	î, e				
VI CORRECT	191	0	0	0		0	0	0	0	6	24	0	8	9		•		
TABLE	169	0	125	125	0	0	0	0	0	0	0	0	0	0				
3	176	0	0	0	0	0	0	0	0	0	0	0	125	0				
	174	0	0	0	0	0	0	0	0	0	125	0	0	0				
	RESET 153	0	0	0	0	0	0	0	24	0	0	0	0	0				
AT	141 144 147	0	0	0	24	0	0	0	0	0	0	0	0	0				
INPUTS	155	0	0	5 4	24	24	0	0	0	0	0	0	0	0				
	166	0	125	125	125	125	125	0	0		0	0	0	0			191	RINTS 1
J. Polac				^_/	PROYAL	S .		am T					OR EPT.	P3K-AI	L-0380)-A01		1 ')
ISSUED A PA	4-16,1	977	,]			Sch	enec	tady	, N.	Υ.	LOCA	TION	CONT ON SI	IEET	14		1.3

+

		GE	NERAL 🍪 EI	LECTRIC		P3K-AL-03	80-A01	
REV ,	************************************	24 V	INSTRUCTIONS	CIRCUIT		CONT ON SHEET TM2-AOO1	5H #	ю. 14
P3K-AL-0380-A	О1. н No. ¬ <u>Л</u> ,	ASS'	Y DRAWING 1	L18D1374 RK II				
								REVISION
		•						
TEST INSTRUCT PREPARED BY	ION	Jim.	Economou	V	DATE	9/24/1	1973	
	D. Economo	ou N ENGINEERI	NG					
								
		•						
	00							
APPROVED BY	D'C	Cel			_ DATE	C-C.	77	
		ı - MANAGER ENGINEERIN						
							•	
TEST PROCEDURE	E ,, , ,	1 41					,	
REVIEWER BY	. Deberto	<u>Cartifin</u>			DATE	<u> </u>	<u> 22 </u>	
Ī	EHC TEST E	ENGINEER						
			·					***************************************
;							~	The second secon
					•			PRINTS TO
малыну. J. Polacek Sept.	16, 1977	APPROVALS	Steam Turbi	ne	DIV OR	P3K-AL-03	80A01	Annual control
155UED ECP 16,1	977		Schenectady	, N.Y.	I	CONT ON SHEET	SH 1	1)

#53-WA (2-73) PRINTED IN U.S.A.

+

CODE TOLAT N