



GE Energy

Functional Testing Specification

*Parts & Repair Services
Louisville, KY*

LOU-GENEVA-IS200EROC

Test Procedure for cards tested on the Geneva Test System

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Roger Johnson	8/31/2012
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY R. Johnson	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 8/31/2012	DATE	DATE	DATE 8/31/2012

<p>LOU-GENEVA-IS200EROC REV. A</p>	<p>g</p> <p>GE Energy Part & Repair Services Louisville, KY</p>	<p>Page 2 of 3</p>
---	---	---------------------------

Functional test procedure for equipment tested on the GENRAD® GENEVA system

1. SCOPE

1.1 This is a functional testing procedure for testing IS200EROC circuit boards.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information.

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires broken or cracked

4.2.1.2 Terminal strips / connectors broken or cracked

4.2.1.3 Loose wires

4.2.1.4 Components visually damaged

4.2.1.5 Capacitors leaking

4.2.1.6 Solder joints damaged or cold

4.2.1.7 Circuit board burned or de-laminated

4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	H188912	GENRAD Geneva Test System or equivalent system
1	H188804	EROc Fixture

<p>LOU-GENEVA-IS200ERO REV. A</p>	<p>g</p> <p><i>GE Energy</i> <i>Part & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 3 of 3</p>
---------------------------------------	--	--------------------

6. TESTING PROCESS

6.1 Setup

6.1.1 Install EROC fixture H188804 onto Geneva test System.

6.1.2 Install UUT into test fixture.

6.2 Testing Procedure

6.2.1 Load appropriate test program and follow instructions on screen.

6.3 *****TEST COMPLETE*****

7. NOTES

7.1 None at this time.