



GE Energy

## Functional Testing Specification

*Parts & Repair Services  
Louisville, KY*

**LOU-GED-320L85D2082**

### Test Procedure for a Rectifier module

**DOCUMENT REVISION STATUS:** Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	J. Archibald	05/15/2017
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

<b>PREPARED BY</b> J. Archibald	<b>REVIEWED BY</b>	<b>REVIEWED BY</b>	<b>QUALITY APPROVAL</b> L. Groves
<b>DATE</b> 05/15/2017	<b>DATE</b>	<b>DATE</b>	<b>DATE</b> 5/15/2017

LOU- REV. A	g  <b>GE Energy</b> <i>Parts &amp; Repair Services</i> <i>Louisville, KY</i>	Page 2 of 3
----------------	--	-------------

## 1. SCOPE

1.1 This is a functional testing procedure for a Card.

## 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

## 3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

## 4. ENGINEERING REQUIREMENTS

### 4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

### 4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

## 5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		H188763 Light Bulb load
1		Oscilloscope

<p style="text-align: center;"><b>LOU- REV. A</b></p>	<p style="text-align: center;">g</p> <p style="text-align: center;"><b>GE Energy</b> Parts &amp; Repair Services Louisville, KY</p>	<p style="text-align: center;"><b>Page 3 of 3</b></p>
---	---	---

**6. Modifications/Upgrades**

**6.1** Fill out if applicable.

**7. Testing Process**

**7.1 Setup**

Hook Light Bulb load (H188763) to top and bottom Bus.

Hook Oscilloscope leads to top and bottom bus.



**Note:**

**7.2 Testing Procedure**

Turn on Load and Oscilloscope

Verify scope has half wave rectification of A.C signal.

Static check snubber for proper operation.

**7.3 Post Testing Burn-in**

**Required**    ☐ Yes    ☐ No



**7.3.1**

**7.4 \*\*\*TEST COMPLETE\*\*\***

**8. Notes**

**8.1** None at this time?

**9. Attachments**

**9.1** None at this time?