

g

GE Industrial Systems

Functional Testing Specification

*Renewal Services
Louisville, KY*

LOU-GED-DS3820BFBA

Test Procedure for a DS3820HSMX Heat Sink Assembly

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	James Archibald	08/28/2015
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY James Archibald	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL L. Groves
DATE 08/28/2015	DATE	DATE	DATE 08/28/2015

test procedure for DS3820BFBA Heat Sink Assembly

1. SCOPE

1.1 This is a functional testing procedure for a.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Refer to shop folder for DS3820BFBA

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to the local documented procedures for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires broken or cracked

4.2.1.2 Terminal strips / connectors broken or cracked

4.2.1.3 Loose wires

4.2.1.4 Components visually damaged

4.2.1.5 Capacitors leaking

4.2.1.6 Solder joints damaged or cold


4.2.1.7 Circuit board burned or de-laminated

4.2.1.8 Printed wire runs burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 85 DMM (or Equivalent)

LOU-GED-DS3820BFBA	 GE Energy <i>Parts and Repair Services</i> <i>Louisville, KY</i>	Page 3 of 3
--------------------	--	-------------

6. TESTING PROCESS

6.1 Testing Procedure:

- A. Put negative lead of the meter on the cathode
Put positive lead of the meter on the anode
Meter should read diode drop (appx .4 volts)

- B. Reverse meter leads
Meter should read appx infinity.

6.2 ***TEST COMPLETE

Fig. 1