



GE Energy

Functional Testing Specification

Parts & Repair Services
Louisville, KY

LOU-GED-531X189LTBA

Test Procedure for a 531X189LTBAJG1 a LAN option board.

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Steve Pharris	9/19/2011
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Steve Pharris	REVIEWED BY Cristyn Edlin	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 9/19/2011	DATE 9/20/11	DATE	DATE 9/20/2011

LOU-GED-531X189LTBA REV. A	g GE Energy Parts & Repair Services Louisville, KY	Page 2 of 7
-------------------------------	--	-------------

1. SCOPE

1.1 This is a functional testing procedure for a 531X189LTBAJG1.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		Tenma Power Supply
1	H188703	Sencore LC103

6. Testing Process

6.1 Continuity Test

6.1.1 Verify less than 2 ohms between the following points.

LTB1	RPL1	LTB25	6PL5	LTB49	10PL7
LTB2	RPL3	LTB26	6PL6	LTB50	10PL8
LTB3	RPL5	LTB27	6PL7	LTB51	10PL11
LTB4	RPL7	LTB28	6PL9	LTB52	10PL16
LTB5	RPL9	LTB29	6PL10	LTB56	10PL13
LTB6	RPL11	LTB30	6PL11	LTB57	10PL14
LTB7	RPL13	LTB31	6PL12	LTB58	10PL15
LTB8	RPL15	LTB32	6PL13	LTB59	PSPL
LTB9	29PL1	LTB33	6PL14	LTB60	30PL20
LTB10	29PL2	LTB34	6PL15	LTB61	LTB66
LTB11	29PL3	LTB35	6PL16	LTB62	4PL1
LTB12	29PL4	LTB36	6PL18	LTB63	4PL2
LTB13	29PL5	LTB37	6PL19	LTB64	4PL3
LTB14	29PL6	LTB38	6PL20	LTB65	6PL8
LTB15	29PL7	LTB39	6PL22	LTB66	30PL20
LTB16	29PL8	LTB40	6PL23	30PL24	MUP4(tp)
LTB17	29PL9	LTB41	6PL24	6PL4	30PL15
LTB18	29PL10	LTB42	10PL1	6PL6	30PL16
LTB19	29PL11	LTB43	10PL2	6PL9	30PL17
LTB20	29PL12	LTB44	10PL12	6PL10	30PL18
LTB21	29PL13	LTB45	10PL10	6PL11	30PL19
LTB22	29PL14	LTB46	10PL4	30PL1	29PL1
LTB23	6PL1	LTB47	10PL5	30PL2	29PL2
LTB24	6PL4	LTB48	10PL6	30PL3	29PL3

30PL4	29PL4
30PL5	29PL5
30PL6	29PL6
30PL7	29PL7
30PL8	29PL8
30PL9	29PL9
30PL10	29PL10
30PL11	29PL11
30PL12	29PL12
30PL13	29PL13
30PL14	29PL14

6.1.3 Capacitor Test

6.1.4 Connect Sencore LC103 to LTB61 (negative lead) and Ground eyelet (positive lead) and set for .047uF.

6.1.5 Verify C1 by pressing the “Capacitor Good/Bad” button.

6.1.6 Remove Sencore

6.1.7 Relay Test

6.1.8 Verify LTB53 - LTB54 = <2 Ohms

6.1.9 Verify LTB53 - LTB55 = Open

6.1.10 Apply 30VDC to 6PL22 with respect to 6PL17

6.1.11 Verify LTB53 - LTB54 = Open

6.1.12 Verify LTB53 - LTB55 = <2 Ohms

6.1.13 Remove 30VDC

6.1.14 Connect + from power supply to 29PL26 (this connection can remain for the rest of the test).

6.1.15 Connect – from power supply to 29PL19 (this connection will move as you fire each relay).

6.1.16 Verify 30PL21 – 30PL22 = Open

6.1.17 Apply power


6.1.18 Verify 30PL21 – 30PL22 = <2 Ohms

6.1.19 Verify 30PL22 – 30PL23 = Open

6.1.20 Remove power

LOU-GED-531X189LTBA REV. A	<div data-bbox="548 205 581 254" data-label="Image"></div> <div data-bbox="737 258 980 333" data-label="Text"> <p>GE Energy Parts & Repair Services Louisville, KY</p> </div>	Page 5 of 7
---------------------------------------	--	--------------------

- 6.1.21 Move – lead from power supply to 29PL20
- 6.1.22 Apply power
- 6.1.23 Verify 30PL22 – 30PL23 = <2 Ohms
- 6.1.24 Remove power
- 6.1.25 Move – lead from power supply to 29PL19
- 6.1.26 Set JP1 to pos. 2-3 and remove all other jumpers
- 6.1.27 Verify RPL1 – RPL3 = <2 Ohms
- 6.1.28 Apply Power
- 6.1.29 Verify RPL1 – RPL3 = Open
- 6.1.30 Set JP1 to pos.1-2
- 6.1.31 Verify RPL1 – RPL3 = <2 Ohms
- 6.1.32 Remove power
- 6.1.33 Verify RPL1 – RPL3 = Open
- 6.1.34 Move – lead from power supply to 29PL20
- 6.1.35 Remove JP1
- 6.1.36 Install JP2 and set to pos. 2-3
- 6.1.37 Verify RPL1 – RPL5 = <2 Ohms
- 6.1.38 Apply power
- 6.1.39 Verify RPL1 – RPL5 = Open
- 6.1.40 Set JP2 to pos. 1-2
- 6.1.41 Verify RPL1 – RPL5 = <2 Ohms
- 6.1.42 Remove power
- 6.1.43 Verify RPL1 – RPL5 = Open
- 6.1.44 Move – lead from power supply to 29PL21
- 6.1.45 Remove JP2
- 6.1.46 Install JP3 and set to pos. 2-3
- 6.1.47 Verify RPL1 – RPL7 = <2 Ohms
- 6.1.48 Apply power
- 6.1.49 Verify RPL1 – RPL7 = Open
- 6.1.50 Set JP3 to pos. 1-2
- 6.1.51 Verify RPL1 – RPL7 = <2 Ohms
- 6.1.52 Remove power
- 6.1.53 Verify RPL1 – RPL7 = Open
- 6.1.54 Move – lead from power supply to 29PL22

LOU-GED-531X189LTBA REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 6 of 7
---------------------------------------	--	--------------------

- 6.1.55** Remove JP3
- 6.1.56** Install JP4 and set to pos. 2-3
- 6.1.57** Verify RPL1 – RPL9 = <2 Ohms
- 6.1.58** Apply power
- 6.1.59** Verify RPL1 – RPL9 = Open
- 6.1.60** Set JP4 to pos. 1-2
- 6.1.61** Verify RPL1 – RPL9 = <2 Ohms
- 6.1.62** Remove power
- 6.1.63** Verify RPL1 – RPL9 = Open
- 6.1.64** Move – lead from power supply to 29PL23
- 6.1.65** Remove JP4
- 6.1.66** Install JP5 and set to pos. 2-3
- 6.1.67** Verify RPL1 – RPL11 = <2 Ohms
- 6.1.68** Apply power
- 6.1.69** Verify RPL1 – RPL11 = Open
- 6.1.70** Set JP5 to pos. 1-2
- 6.1.71** Verify RPL1 – RPL11 = <2 Ohms
- 6.1.72** Remove power
- 6.1.73** Verify RPL1 – RPL11 = Open
- 6.1.74** Move – lead from power supply to 29PL24
- 6.1.75** Remove JP5
- 6.1.76** Install JP6 and set to pos. 2-3
- 6.1.77** Verify RPL1 – RPL13 = <2 Ohms
- 6.1.78** Apply power
- 6.1.79** Verify RPL1 – RPL13 = Open
- 6.1.80** Set JP6 to pos. 1-2
- 6.1.81** Verify RPL1 – RPL13 = <2 Ohms
- 6.1.82** Remove power
- 6.1.83** Verify RPL1 – RPL13 = Open
- 6.1.84** Move – lead from power supply to 29PL25
- 6.1.85** Remove JP6
- 6.1.86** Install JP7 and set to pos. 2-3
- 6.1.87** Verify RPL1 – RPL15 = <2 Ohms
- 6.1.88** Apply power

<p>LOU-GED-531X189LTBA REV. A</p>	<p>g</p> <p>GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i></p>	<p>Page 7 of 7</p>
--	--	---------------------------

6.1.89 Verify RPL1 – RPL15 = Open

6.1.90 Set JP7 to pos. 1-2

6.1.91 Verify RPL1 – RPL15 = <2 Ohms

6.1.92 Remove power

6.1.93 Verify RPL1 – RPL15 = Open

6.1.94 Reinstall All Jumpers

6.2 *TEST COMPLETE*****

7. Notes

7.1 None at this time.

8. Attachments

8.1 None at this time.