TITLE

CONT ON SHEET 2

SH NO.1

P5K-AL-0179

INTERCEPT VALVE AMPLIFIER CIRCUIT BOARD TEST

CONT ON SHEET 2

+

SH NO.

FIRST MADE FOR Philadelphis Electric - 170X463

GENERAL DESCRIPTION

REVISIO


This board sums the speed error signal, the load reference signal, the valve opening bias signal, the valve closing bias signal (during chest/shell warming) to produce a d-c signal at the output for the intercept valve position loops. Zero volts or less drives the valves to the closed position; +5 volts call for the valves to go wide open. A biasing network limits the output to +5 volts if a higher voltage is called for, and drives the output negative (via contact KT101) opening on an emergency trip. The transistor circuit is used only for current amplification - the base to emitter drop may be neglected.

The intercept valves will be biased full open (+5 volts output) during starting up and loading by -5 volts at TP6.

If an overspeed occurs, the resulting speed error will act to cancel the bias voltages and load reference signal. The intercept valves have a regulation of 2%, therefore, the speed error resulting from a 2% overspeed will cancel 5 volts at the output. A 100% load with 5% control valve regulation and a load reference of -5 volts, will start to close the valve at 5% overspeed, and will be fully closed at 107% of rated speed. The overspeed required to start the valves closing is due to the fact that more than 5 volts must be cancelled at the output.

During chest/shell warming a (+) 5.50 VDC input valve closing bias will_assure that intercept valves remain closed.

The gain seen by the speed error input (equal to 5 in the steady state) increases to 2.5 during a transient change through the Resistor - capacitor input path.



ET-2273-

273-

273-273-

273-PRINTS

D.Mone Jan. 17, 1973 JAN 1 8 1973

Steam Turbine

APPROVALS

DIV OR

P3K-AL-0179

sh no 2

Schenectady, N.Y. CONT ON SHEET LOCATION

1051 10

PRINTS

D.Mone Jan. 17, 1973

Steam Turbine

OIV OR DEPT.

P3K-AL-0179

Schenectady, N.Y. LOCATION CONT ON SHEET 4 SH NO 3

Schenectady, N.Y.

FF-808-WA (1-72) PRINTED IN U.S.A.

LOCATION CONT ON SHEET 5

D.Mone Jan. 17, 1973

APPROVALS

Steam Turbine

Schenectady, N.Y.

DIV OR

P3K-AL-0179

LOCATION CONT ON SHEET - SH NO 5

FF-803-WA (1-72) PRINTED IN U.S.A. CODE

PRINT

Data Sheet

Job #								
Serial #					Burn-in Start			
Date								
Data Sheet for118D1517G003					Burn-in Stop			
Test ProcedureP3K-AL-0179					Technician			
Test						Pot Values		
Procedure	.	Lower	Pre-Burn	Post Burn	1		If applicable	
Step	Nominal	Limit	in Results	in Results	Upper Limit	CW	CCW	Pass/Fail
7	0V					-	-	
11*	-9.8VDC	-8.8V			-10.8V	-	-	
13*	-5.0VDC	-4.75V			-5.25V	-	-	
R5	-	-	<u>-</u>	-	-			
								-
						_		
					1			
					-			
					<u> </u>			
Comments:	"*" = Tolerar	ces tighten :	x 10 for Brunswick	<				