g		GE Energy		Functional T	esting Spe	ecification
	Parts & Repai Louisville, KY	ir Services '		LOU-GED	-IS200TDBT	H6Axx
		Test Proc	edure for	а		
DOCU	MENT REVISION STATUS:	Determined by the last entry in t	he "REV" a	nd "DATE" column		
REV.		DESCRIPTION		SI	GNATURE	REV. DATE
Α	Initial release			Da	ın Waddy	11/3/2017
В						
С						
Hard co PROPR MAY N	© COPYRIGHT GENERAL ELECTRIC COMPANY Hard copies are uncontrolled and are for reference only. PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.					
D. Wa	ARED BY addy	REVIEWED BY	REVIEWE	D BY	L. Groves	PROVAL
DATE 11/3/2	2017	DATE	DATE		DATE 11/3/2017	

	g	
LOU-	GE Energy	Page 2 of 8
REV. A	Parts & Repair Services	
	Louisville, KY	

1. SCOPE

1.1 This is a functional testing procedure for a Card.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
 - **3.1.1** Check board's electronic folder for more information

4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
 - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- **4.2** Equipment Inspection
 - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
 - 4.2.1.1 Wires broken, cracked, or loosely connected
 - 4.2.1.2 Terminal strips / connectors broken or cracked
 - 4.2.1.3 Components visually damaged
 - **4.2.1.4** Capacitors bloated or leaking
 - 4.2.1.5 Solder joints damaged or cold
 - 4.2.1.6 Circuit board burned or de-laminated
 - 4.2.1.7 Printed wire runs / Traces burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		Tenma Dual output supply

	g	
LOU-	GE Energy	Page 3 of 8
REV. A	Parts & Repair Services	
	Louisville, KY	

6. <u>Testing Procedure</u>

6.1 Initial Testing

- **6.1.1** Begin testing by inspecting the card for shorted MOV's, damaged parts, or any other visible defects.
- **6.1.2** Verify continuity at the following points illustrated below in **Table 1**.

From	То
JE1-1	TB2-1
JE1-1	TB2-3
JE1-1	TB2-5
JE1-1	TB2-7
JE1-1	TB2-9
JE1-1	TB2-11
JE1-1	TB2-13
JE1-1	TB2-15
JE1-1	TB2-17
JE1-1	TB2-19
JE1-1	TB2-21
JE1-1	TB2-23
JE1-1	TB2-25
JE1-1	TB2-27
JE1-1	TB2-29
JE1-1	TB2-31
JE1-1	TB2-33
JE1-1	TB2-35
JE1-1	TB2-37
JE1-1	TB2-39
JE1-1	TB2-41
JE1-1	TB2-43
JE1-1	TB2-45
JE1-1	TB2-47

Table 1

	g	
LOU-	GE Energy	Page 4 of 8
REV. A	Parts & Repair Services Louisville, KY	

6.1.3 Perform resistance checks using the following points listed below in **Table 2**.

From	То	Output
JE1-3	JT1-1	492k ohm
JE1-3	JT1-3	492k ohm
JE1-3	JT1-4	492k ohm
JE1-3	JT1-5	492k ohm
JE1-3	JT1-6	492k ohm
JE1-3	JT1-7	492k ohm
JE1-3	JT1-8	492k ohm
JE1-3	JT1-9	492k ohm
JE1-3	JT1-10	492k ohm
JE1-3	JT1-11	492k ohm
JE1-3	JT1-12	492k ohm
JE1-3	JT1-13	492k ohm
JE1-3	JT1-14	492k ohm
JE1-3	JT1-15	492k ohm
JE1-3	JT1-16	492k ohm
JE1-3	JT1-17	492k ohm
JE1-3	JT1-18	492k ohm
JE1-3	JT1-19	492k ohm
JE1-3	JT1-24	492k ohm
JE1-3	JT1-25	492k ohm
JE1-3	JT1-26	492k ohm
JE1-3	JT1-27	Open
JE1-3	JT1-28	Short
JE1-3	JT1-29	455k ohm
JE1-3	JT1-30	455k ohm
JE1-3	JT1-31	455k ohm
JE1-3	JS1-1	492k ohm
JE1-3	JS1-3	492k ohm
JE1-3	JS1-4	492k ohm

g GE Energy Parts & Repair Services Louisville, KY LOU-Page 5 of 8 REV. A

From	То	Output
JE1-3	JS1-5	492k ohm
JE1-3	JS1-6	492k ohm
JE1-3	JS1-7	492k ohm
JE1-3	JS1-8	492k ohm
JE1-3	JS1-9	492k ohm
JE1-3	JS1-10	492k ohm
JE1-3	JS1-11	492k ohm
JE1-3	JS1-12	492k ohm
JE1-3	JS1-13	492k ohm
JE1-3	JS1-14	492k ohm
JE1-3	JS1-15	492k ohm
JE1-3	JS1-16	492k ohm
JE1-3	JS1-17	492k ohm
JE1-3	JS1-18	492k ohm
JE1-3	JS1-19	492k ohm
JE1-3	JS1-24	492k ohm
JE1-3	JS1-25	492k ohm
JE1-3	JS1-26	492k ohm
JE1-3	JS1-27	Open
JE1-3	JS1-28	Short
JE1-3	JS1-29	455k ohm
JE1-3	JS1-30	455k ohm
JE1-3	JS1-31	455k ohm
JE1-3	JT1-1	492k ohm
JE1-3	JT1-3	492k ohm
JE1-3	JT1-4	492k ohm
JE1-3	JT1-5	492k ohm
JE1-3	JT1-6	492k ohm
JE1-3	JT1-7	492k ohm
JE1-3	JT1-8	492k ohm
JE1-3	JT1-9	492k ohm

LOUREV. A

GE Energy
Parts & Repair Services
Louisville, KY

Page 6 of 8

From	То	Output
JE1-3	JT1-10	492k ohm
JE1-3	JT1-11	492k ohm
JE1-3	JT1-12	492k ohm
JE1-3	JT1-13	492k ohm
JE1-3	JT1-14	492k ohm
JE1-3	JT1-15	492k ohm
JE1-3	JT1-16	492k ohm
JE1-3	JT1-17	492k ohm
JE1-3	JT1-18	492k ohm
JE1-3	JT1-19	492k ohm
JE1-3	JT1-24	492k ohm
JE1-3	JT1-25	492k ohm
JE1-3	JT1-26	492k ohm
JE1-3	JT1-27	Open
JE1-3	JT1-28	Short
JE1-3	JT1-29	455k ohm
JE1-3	JT1-30	455k ohm
JE1-3	JT1-31	455k ohm
JE1-3	TB2 -2	50k ohm
JE1-3	TB2 -4	50k ohm
JE1-3	TB2 -6	50k ohm
JE1-3	TB2 -8	50k ohm
JE1-3	TB2 -10	50k ohm
JE1-3	TB2 -12	50k ohm
JE1-3	TB2 -14	50k ohm
JE1-3	TB2 -16	50k ohm
JE1-3	TB2 -18	50k ohm
JE1-3	TB2 -20	50k ohm
JE1-3	TB2 -22	50k ohm
JE1-3	TB2 -24	50k ohm
JE1-3	TB2 -26	50k ohm

	g	
LOU-	GE Energy	Page 7 of 8
REV. A	Parts & Repair Services	
	Louisville, KY	

From	То	Output
JE1-3	TB2 -28	50k ohm
JE1-3	TB2 -30	50k ohm
JE1-3	TB2 -32	50k ohm
JE1-3	TB2 -34	50k ohm
JE1-3	TB2 -36	50k ohm
JE1-3	TB2 -38	50k ohm
JE1-3	TB2 -40	50k ohm
JE1-3	TB2 -42	50k ohm
JE1-3	TB2 -44	50k ohm
JE1-3	TB2 -46	50k ohm
JE1-3	TB2 -48	50k ohm

Table 2

6.2 TMR testing

- **6.2.1** Connect positive 28V DC to pin JW2-Z2 using one output of the Tenma power supply.
- **6.2.2** Connect the COM from that supply to pin JW2-Z4.
- **6.2.3** Apply power to the card at this time.
- 6.2.4 Verify "TMR" relay functionality. Connect an ohm meter between TB1-1 (K1NC1) and TB1-2 (K1COM1) which should read as a short on the ohm meter. Energize K1 by grounding two of the three inputs JR1-32, JS1-32, and JT1-32. Verify that the ohm meter transitions to read as an open when the relay is energized. While leaving the meter lead connected to TB1-2 (K1COM1), move the other meter lead from TB1-1 (K1NC1) to TB1-3 (K1NO1) which should read as a short until the relay is de-energized and TB1-3 (K1NO1) should return to its "normally open" state. Repeat these steps on the remaining relays using Table 3, listed below.

	g	
LOU-	GE Energy	Page 8 of 8
REV. A	Parts & Repair Services	
	Louisville, KY	

Relay	KxNC	KxCOM	KxNo	Inputs
K1	TB1-1	TB1-2	TB1-3	JR1-32, JS1-32, JT1-32
K2	TB1-5	TB1-6	TB1-7	JR1-33, JS1-33, JT1-33
K3	TB1-9	TB1-10	TB1-11	JR1-34, JS1-34, JT1-34
K4	TB1-13	TB1-14	TB1-15	JR1-35, JS1-35, JT1-35
K5	TB1-17	TB1-18	TB1-19	JR1-36, JS1-36, JT1-36
K6	TB1-21	TB1-22	TB1-23	JR1-37, JS1-37, JT1-37
K7	TB1-25	TB1-26	TB1-27	JR1-38, JS1-38, JT1-38
K8	TB1-29	TB1-30	TB1-31	JR1-39, JS1-39, JT1-39
K9	TB1-33	TB1-34	TB1-35	JR1-40, JS1-40, JT1-40
K10	TB1-37	TB1-38	TB1-39	JR1-41, JS1-41, JT1-41
K11	TB1-41	TB1-42	TB1-43	JR1-42, JS1-42, JT1-42
K12	TB1-45	TB1-46	TB1-47	JR1-43, JS1-43, JT1-43

Table 3

- 6.2.5 Read and verify the ID chip.
- 6.2.6 Post Testing Burn-in Required ____ Yes _X__ No
- 6.3 ***TEST COMPLETE ***
- 7. Notes
 - **7.1** None at this time?
- 8. Attachments
 - **8.1** None at this time?