g	GE Energy		Functional 7	Testing Spec	cification
	Parts & Repai Louisville, KY		LOU-GI	ED-DS200RTB/	AG5
	Test Procedure for	or DS200RTBA cards tested	d on the Bench-Geneva do	es not work on	G5
DOCUM	MENT REVISION STATUS:	Determined by the last entry in the DESCRIPTION		IGNATURE	REV. DATE
A	Initial release	2-20		S. Cash	7-18-2014
В					
С					
© COPYRIGHT GENERAL ELECTRIC COMPANY					
Hard copies are uncontrolled and are for reference only.  PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.					
PREPA	RED BY	REVIEWED BY	REVIEWED BY	QUALITY APPR	ROVAL
S. Ca	sh	DATE	DATE	Charlie Wad	le
7/21/2	2014	DATE	DATE	<b>DATE</b> 7/21/2014	

GE Energy Part & Repair Services

Page 2 of 5

### LOU-GED-DS200RTBAG5 REV. A

#### Functional test procedure for DS200RTBAG5xxx cards tested on the Bench

Louisville, KY

#### 1. SCOPE

**1.1** This is a functional testing procedure for DS200RTBAG5xxx boards.

g

## 2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

## 3. APPLICABLE DOCUMENTS

- **3.1** The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.
  - **3.1.1** Check the board's electronic folder for more information.

# 4. **ENGINEERING REQUIREMENTS**

- 4.1 Equipment Cleaning
  - **4.1.1** Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.
- 4.2 Equipment Inspection
  - **4.2.1** Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:
    - 4.2.1.1 Wires broken or cracked
    - 4.2.1.2 Terminal strips / connectors broken or cracked
    - **4.2.1.3** Loose wires
    - 4.2.1.4 Components visually damaged
    - 4.2.1.5 Capacitors leaking
    - 4.2.1.6 Solder joints damaged or cold
    - 4.2.1.7 Circuit board burned or de-laminated
    - 4.2.1.8 Printed wire runs burned or damaged

# 5. EQUIPMENT REQUIRED

**5.1** The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1	Fluke	Fluke 85 or equivalent
1	Power Supply	24 VDC

LOU-GED-DS200RTBAG5 REV. A

**GE Energy** Part & Repair Services Louisville, KY

Page 3 of 5

# 6. Testing Process

- 6.1 Setup
  - **6.1.1** Setup power supply to 24 VDC.
  - **6.1.2** Set all Jumpers to 1-2 position
- 6.2 Test procedure
  - **6.2.1** Make continuity checks per the following table.

g

СРН	CP2PL-1	<1 ohm
CPN	CP2PL-2	<1 ohm
RTB-50	OPTPL-1	<1 ohm
RTB-51	OPTPL-2	<1 ohm
RPL-1	OPTPL-2	<1 ohm
RTB-50	JP9-3	<1 ohm
JP1-2	RTB-1	<1 ohm
JP1-3	RPL-3	<1 ohm
JP2-2	RTB-8	<1 ohm
JP2-3	RPL-7	<1 ohm
JP3-2	RTB-15	<1 ohm
JP3-3	RPL-7	<1 ohm
JP4-2	RTB-22	<1 ohm
JP4-3	RPL-9	<1 ohm
JP5-2	RTB-29	<1 ohm
JP5-3	RPL-11	<1 ohm
JP6-2	RTB-36	<1 ohm
JP6-3	RPL-13	<1 ohm
JP7-2	RTB-43	<1 ohm
JP7-3	RPL-15	<1 ohm

LOU-GED-DS200RTBAG5
REV. A

GE Energy
Part & Repair Services
Louisville, KY

Page 4 of 5

**6.2.2** Check relay operations per the following tables. On the Normally Open relays check continuity both engaged and not engaged several times.

Normally Closed Contacts				
Relay	From	То	Reading	
K20	RTB-4	RTB-3	<1 ohm	
K20	RTB-7	RTB-6	<1 ohm	
K21	RTB-11	RTB-10	<1 ohm	
K21	RTB-14	RTB-13	<1 ohm	
K22	RTB-18	RTB-17	<1 ohm	
K22	RTB-21	RTB-20	<1 ohm	
K23	RTB-25	RTB-24	<1 ohm	
K23	RTB-28	RTB-27	<1 ohm	
K24	RTB-32	RTB-31	<1 ohm	
K24	RTB-35	RTB-34	<1 ohm	
K25	RTB-39	RTB-38	<1 ohm	
K25	RTB-42	RTB-41	<1 ohm	
K26	RTB-46	RTB-45	<1 ohm	
K26	RTB-49	RTB-48	<1 ohm	

Normally Open Relay Contact Operation Testing					
Relay	Relay Power		Measure		
Number	24 VDC	Common	From	То	Reading
K20	RTB-1	RTB-50	RTB-2	RTB-3	open\<1 ohm
K20	RTB-1	RTB-50	RTB-5	RTB-6	open\<1 ohm
K21	RTB-8	RTB-50	RTB-9	RTB-10	open\<1 ohm
K21	RTB-8	RTB-50	RTB-12	RTB-13	open\<1 ohm
K22	RTB-15	RTB-50	RTB-16	RTB-17	open\<1 ohm
K22	RTB-15	RTB-50	RTB-19	RTB-20	open\<1 ohm
K23	RTB-22	RTB-50	RTB-23	RTB-24	open\<1 ohm
K23	RTB-22	RTB-50	RTB-26	RTB-27	open\<1 ohm
K24	RTB-29	RTB-50	RTB-30	RTB-31	open\<1 ohm
K24	RTB-29	RTB-50	RTB-33	RTB-34	open\<1 ohm
K25	RTB-36	RTB-50	RTB-37	RTB-38	open\<1 ohm
K25	RTB-36	RTB-50	RTB-40	RTB-41	open\<1 ohm
K26	RTB-43	RTB-50	RTB-44	RTB-45	open\<1 ohm
K26	RTB-43	RTB-50	RTB-47	RTB-48	open\<1 ohm

LOU-GED-DS200RTBAG5
REV. A

GE Energy
Part & Repair Services
Louis ville, KY

Page 5 of 5

## **6.3** \*\*\*TEST COMPLETE \*\*\*

# 7. Notes

**7.1** This is an unpopulated G2 board but the Geneva test will fail many steps if used. The G5 test on Geneva does not work at all.