

REV NO. 0A	TITLE	CONT ON SHEET 6	SH NO. 5
P3K-AL-0467-A01	TEST INSTRUCTIONS FOR THROTTLE PRESSURE LIMITER (PROP)		
CONT ON SHEET 6	SH NO. 5	WITH MOTOR SET 1L1-P002 (ASSEMBLY DRAWING 118D1323 G1)	
FIRST MADE FOR EHC MARK II (LOAD CONTROL UNIT)			

REVISIONS




FIGURE 1

- NOTE: 1. Resistor R2
1W, 1%
2. Adjust VR1 for 11 VDC at TP1, prior to connection to board 1L1-P002

MADE BY J. Placer	SEP 26 1977	APPROVALS	Steam Turbine	DIV OR DEPT.	P3K-AL-0467-A01
ISSUED	SEP 26 1977		Schenectady, N.Y.	LOCATION	CONT ON SHEET 6 SH NO. 5

9.1.0 SCOPE

This document establishes the performance requirement and recommended test for the 6.9KV Power Electronics Gating Module identified as:

DS5220PEG

This specification will check the output tolerances based on a known input.

9.2.0 Test Equipment and Documentation

9.2.1 Standard Equipment Required

The following instrumentation is needed:

- (a) 2 channel oscilloscope ≥ 100 MHZ bandwidth.
- (b) 0-2 Amp AC ammeter.
- (c) A signal generator capable of delivering a pulse train consisting of square pulses of variable width and 22.22 KHZ frequency. The pulse train period shall be 16.67 MS.

9.2.2 Special Equipment Required

- (a) AC Source:

This module is designed to operate with a voltage stabilizing transformer input. It is preferred that such a source (rated 250 VA or greater) be used to test this module.

If a standard transformer is used, it should not droop more than 2%.

$$\left[\text{Droop} = \left(\frac{V_{NL} - V_{FL}}{V_{NL}} \right) (100\%) \right]$$

The transformer must have an output of 240V, 60HZ with center tap.

9.3.0 Pin Connections

- (a) AC Power:

L1 to AC1

L2 to AC2

Center tap to TBI-1

Ground all four terminals of TBI

REV. 1	REV. 4	REV. 7	PRINTS TO DL119	ENGINEER <i>[Signature]</i>	GENERAL ELECTRIC SALEM, VA. U.S.A.	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J. W. Hylton				CONT. ON SH. 9AB SH. NO. 9AA

9.3.0 Pin Connections (continued)

(b) Ribbon Header (JA):

Gate input signal to JA1
Gate input common to JA4
Overvoltage input signal to JA10
Overvoltage common to JA8
JA8 and JA10 should be shorted together and to COM when not in use.

(c) Gate Output:

Connect gate pulse transformer loads to Plug JE. Positive gate current will flow out of JE-2 and return thru JE-1. Do not ground the load circuit externally.

(d) Overvoltage Relay Contacts:

Connect ohmmeter to JD1 and JD2. Polarity is unimportant.

9.4.0 Setup and Initial Loading

(a) Connect as shown on the test elem. (Fig. 1)

```
*****
*                                     *
*      CAUTION !!                   *
*                                     *
*****
```

C1 is charged to 170 volts DC upon application of power. When power is removed, the cap requires two minutes to discharge to 50 volts and approximately ten minutes to discharge completely. The danger area encompasses the entire module including the HPTP card. Before handling, make sure that C1 is discharged. C1 may be discharged in \approx two seconds by shorting with a 500 Ω resistor.

REV. 1	REV. 4	REV. 7	PRINTS TO DL119	ENGINEER <i>[Signature]</i>	GENERAL ELECTRIC SALEM, VA, U.S.A.	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J. W. Hylton				CONT. ON SH. 9AC SH. NO. 9AB

9.5.0

9.5.1 Gate Command Signal




Fig. 9-2 Input Pulse Train




Fig. 9-3 Input Pulse

REV. 1	REV. 4	REV. 7	PRINTS TO DL119	ENGINEER <i>[Signature]</i>	GENERAL ELECTRIC	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J.W. Hylton			SALEM, VA. U.S.A.	CONT. ON SH. 9AD SH. NO. 9AC

9.5.2




Fig. 9-4 Normal Gate Input and Output

REV. 1	REV. 4	REV. 7	PRINTS TO DL119	ENGINEER <i>[Signature]</i>	GENERAL ELECTRIC SALEM, VA. U.S.A.	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J. W. Hylton				CONT. ON SH. 9AE SH. NO. 9AD

9.5.3 Overvoltage Command Signal




Fig. 9-5 OV Input




Fig. 9-6 OV I/O

REV. 1	REV. 4	REV. 7	PRINTS TO DL119 6403	ENGINEER JWH	GENERAL ELECTRIC SALEM, VA. U.S.A.	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J. W. Hylton				CONT. ON SH. 9AF SH. NO. 9AE

9.6.0 Test Procedure

9.6.1 Preliminary Inspection

The element shall be inspected prior to application of power to verify that it is assembled according to assembly drawing.

9.6.2 Initial Checks

- (a) Remove fuses FU1 and FU2
- (b) Apply AC input power
- (c) AC input current should be \leq 0.2A
- (d) All LED's should be off
- (e) Voltage regulator levels:

All voltages referenced to COM (TPS)


Regulator	TP	Limits	
		From	To
P15	4	+14.9V	+15.1V
N15	6	-14.6V	-15.4V
PR10	7	+9.97V	+10.03V

- (f) O.V. Alarm Relay (K1) Contacts, JD1-JD2 should be open
- (g) Remove AC power
- (h) Replace FU1 and FU2
- (i) Apply AC input power
- (j) AC input current should be \leq 0.2A
- (k) LED's:

OV Fire (CR50) - off
 Fire (CR51) - off
 IMOK (CR52) - On

- (l) OV Relay, K1

JD1-JD2 should be less than 1 Ω .

REV. 1	REV. 4	REV. 7	PRINTS TO DL119	ENGINEER <i>[Signature]</i>	 GENERAL ELECTRIC SALEM, VA. U.S.A.	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J. W. Hylton				CONT. ON SH. 9AG SH. NO. 9AF

9.6.4 Output Gate Check


- (a) Apply input gate command signal pulse train as shown in Figures 2 and 3.
- (b) Output pulse (I_{gate}) as measured with current probe shall be outside the shaded area shown in Figure 4.
- (c) LED's:
 - OV Fire (CR50) - off
 - Fire (CR51) - on
 - IMOK (CR52) - on
- (d) There shall be no current glitches of $\geq 4\text{MA}$ between pulse trains.
- (e) Remove input gate command signal.

9.6.5 Overvoltage Gate Check

- (a) Apply the overvoltage command signal as specified in paragraph 9.3.0 (B) and Figure 5.
- (b) Output (I_{gate}) shall be as shown in Figure 6.
- (c) LED's:
 - "OV Fire" (CR50) - on
 - "Fire", (CR51) - off
 - IMOK (CR52) - on
- (d) Remove the overvoltage command signal (CR50) "OV Fire" shall remain on.
- (e) Press pushbutton SW1 (reset). CR50 shall go off and remain off.

END OF TEST

REV. 1	REV. 4	REV. 7	PRINTS TO DL11	ENGINEER <i>[Signature]</i>	GENERAL ELECTRIC SALEM, VA. U.S.A.	POWER ELECTRONICS GATING MODULE
REV. 2	REV. 5	ISSUED 3-27-84				DS5220PEG
REV. 3	REV. 6	MADE BY J. W. Hylton				CONT. ON SH. 9AH SH. NO. 9AG



R1-R6 - 68A7002P101 (100 2 watt)
 CR1-CR6 - 68A7228P1 (1A, 400V, fast rec)
 T1-T6 - 228B6709 Gate pulse transformer, 250VA
 T7 - voltage stabilizing transformer, 250VA
 or greater
 R1-R6 - 15Ω±0.1 (non inductive) @ 6 watts

Note: This can be a parallel string of 2W
 resistors trimmed to 15Ω(hot) or a
 single 15Ω non-inductive stick. Check
 hot resistance by measuring volts and
 amps while dissipating 6 watts.
 (This is normal 120° conduction)

REV. 1	REV. 4	REV. 7	PRINTS TO	ENGINEER	GENERAL ELECTRIC	POWER ELECTRONICS
REV. 2	REV. 5	ISSUED	DL119			GATING MODULE
REV. 3	REV. 6	MADE BY	3-27-84			DS5220PEG
			J. W. Hylton		SALEM, VA. U.S.A.	CONT. ON SH. FL SH. NO. 9AH