



GE Energy

Functional Testing Specification

Parts & Repair Services
Louisville, KY

LOU-GED-DS3800NATD

Test Procedure for a DS3800NATD

DOCUMENT REVISION STATUS: Determined by the last entry in the "REV" and "DATE" column

REV.	DESCRIPTION	SIGNATURE	REV. DATE
A	Initial release	Steve Pharris	5/2/2011
B			
C			

© COPYRIGHT GENERAL ELECTRIC COMPANY

Hard copies are uncontrolled and are for reference only.

PROPRIETARY INFORMATION – THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF GENERAL ELECTRIC COMPANY AND MAY NOT BE USED OR DISCLOSED TO OTHERS, EXCEPT WITH THE WRITTEN PERMISSION OF GENERAL ELECTRIC COMPANY.

PREPARED BY Steve Pharris	REVIEWED BY	REVIEWED BY	QUALITY APPROVAL <i>Charlie Wade</i>
DATE 5/2/2011	DATE	DATE	DATE 6/17/2011

LOU-GED-DS3800NATD REV. A	g GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 2 of 8
------------------------------	--	-------------

1. SCOPE

1.1 This is a functional testing procedure for a DS3800NATD.

2. STANDARDS OF QUALITY

2.1 Refer to the current revision of the IPC-A-610 standard for workmanship standards.

3. APPLICABLE DOCUMENTS

3.1 The following document(s) shall form part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue shall apply.

3.1.1 Check board's electronic folder for more information

4. ENGINEERING REQUIREMENTS

4.1 Equipment Cleaning

4.1.1 Equipment should be clean and free of debris prior to applying power unless performing an initial check. Refer to site specific SRA's for cleaning guidelines.

4.2 Equipment Inspection

4.2.1 Equipment should be visually inspected for any defects prior to applying power. This inspection should include the following as a minimum:

4.2.1.1 Wires - broken, cracked, or loosely connected

4.2.1.2 Terminal strips / connectors - broken or cracked

4.2.1.3 Components - visually damaged

4.2.1.4 Capacitors - bloated or leaking

4.2.1.5 Solder joints - damaged or cold

4.2.1.6 Circuit board - burned or de-laminated

4.2.1.7 Printed wire runs / Traces - burned or damaged

5. EQUIPMENT REQUIRED

5.1 The following equipment is required to perform the process requirements. Equipment may be substituted provided that all accuracy's and test ratios are equivalent or better.

Qty	Reference #	Description
1		Fluke 87 DMM (or Equivalent)
1		Tenma Dual Power Supply
1		O-Scope
1		Function Generator

<p>LOU-GED-DS3800NATD REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 3 of 8</p>
---	--	---------------------------

6. Modifications/Upgrades

6.1 None.


7. Testing Process

7.1 Setup

- 7.1.1 Set dual power supply for + and – 15VDC.
- 7.1.2 Connect +15VDC to JB1
- 7.1.3 Connect -15VDC to JB3
- 7.1.4 Connect common from power supplies to JB2
- 7.1.5 Set function generator for 3Vpk-pk sine wave @ 1Khz
- 7.1.6 Resistance readings should be within +/- 5%

7.2 Testing Procedure

- 7.2.1 Apply Power.
- 7.2.2 Connect function generator to JB5 with respect to TP10 and apply signal.
- 7.2.3 Verify the following points = 8.2Vpk-pk @ 1Khz sine wave
 - TP17
 - JG1
 - JG3
 - JG5
 - JG7
 - JG9
 - JG10
- 7.2.4 Disconnect function generator
- 7.2.5 Remove power from card
- 7.2.6 Verify the following points are shorted (< than 1 ohm resistance)
 - JE3-JB5
 - JE3-TP8
 - JB1-TP11
 - TP16-TP9
 - TP9-JE1
 - JE1-JB9
 - TP15-JF1
 - JA20-TP3
 - TP3-TP18

LOU-GED-DS3800NATD REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 4 of 8
--------------------------------------	--	--------------------


TP18-JH1
 TP18-JH3
 TP18-JH5
 TP18-JH7
 TP18-JH9
 TP18-JH10
 JA19-TP4
 JA1-TP14
 JC12-TP1
 TP1-JF12
 JC7-TP6
 TP6-JD19
 TP6-JD20
 TP6-JD22
 TP6-JD24
 TP6-JD28
 TP6-JD30
 TP6-JD34
 TP6-JD32
 TP6-JD26
 TP6-JD18
 TP6-JD10
 TP6-JD2
 TP6-JD4
 TP6-JD6
 TP6-JD8
 TP6-JD12
 TP6-JD13
 TP6-JD14
 JJ4-JJ5
 JJ5-TP19
 JJ2-TP21
 JJ8-JJ9
 JJ9-TP22

LOU-GED-DS3800NATD REV. A	<div data-bbox="548 205 581 254" data-label="Image"></div> <div data-bbox="737 258 980 333" data-label="Text"> <p>GE Energy Parts & Repair Services Louisville, KY</p> </div>	Page 5 of 8
--------------------------------------	--	--------------------

JJ6-TP23
 TP24-JK29
 TP25-JK31
 JK30-TP10
 TP10-JK32
 TP12-JC11
 JC14-TP2
 TP2-JC9
 TP2-JK24
 TP2-JK22
 TP2-JK20
 TP2-JK18
 TP2-JK16
 TP2-JK14
 TP2-JK12
 TP2-JK10
 TP2-JK8
 TP2-JK6
 TP2-JK4
 TP2-JK2
 JK1-TP20
 TP5-JD11

- 7.2.7** Connect com from DMM (Set for Diode) to JC14 and other lead to JC16
- 7.2.8** Verify proper diode voltage drop
- 7.2.9** Connect com from DMM (Set for Diode) to JC12 and other lead to JC18
- 7.2.10** Verify proper diode voltage drop
- 7.2.11** Connect DMM (Set for Ohms) from JC5 to JC7
- 7.2.12** Verify resistance is 575 Ohms
- 7.2.13** Push PB1 and verify meter reads short.
- 7.2.14** Verify when button is released meter again reads 575 Ohms
- 7.2.15** Connect DMM from JC11 to JC9
- 7.2.16** Verify resistance is 575 Ohms
- 7.2.17** Push PB2 and verify meter reads short.
- 7.2.18** Verify when button is released meter again reads 575 Ohms

LOU-GED-DS3800NATD REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 6 of 8
--------------------------------------	--	--------------------

LOU-GED-DS3800NATD REV. A	 GE Energy <i>Parts & Repair Services</i> <i>Louisville, KY</i>	Page 7 of 8
--------------------------------------	--	--------------------

7.2.19 Verify the following resistance measurements between the specified points. Resistance readings should be within +/- 5%

JF15-JF16=475 Ohms

JF17-JF18=475

JF19-JF20=475

JF21-JF22=475

JF23-JF24=475

JF25-JF26=475

JA12-JA18=1.21K

JA14-JA16=1.21K

TP3-JA3=20

TP3-JA7=40

TP3-JA9=40

TP3-JA5=60

TP3-JA11=60

TP3-JA1=60

TP3-TP4=100

JC18-JF10=475

JF8-JF14=1K

JF14-JF12=110

JF12-TP5=175

TP5-JD7=100

TP5-JD5=175

TP5-JD3=245

TP5-TP13=300

TP5-JD1=300

TP13-JD9=100

TP13-JD17=175

TP13-JD25=245

TP13-JD31=300

JD31-JD33=100

JD33-JD29=100

JD29-JD27=100

<p>LOU-GED-DS3800NATD REV. A</p>	<p>g</p> <p>GE Energy Parts & Repair Services Louisville, KY</p>	<p>Page 8 of 8</p>
---	--	---------------------------

JD27-JD23=100
 JD23-JD21=100
 JD21-TP6=100
 JB10-JK29=4.75K
 JK29-TP10=200
 TP10-TP25=100
 JJ1-JJ4=10
 JJ4-JJ2=10
 JJ2-JJ3=500
 JJ10-JJ9=10
 JJ9-JJ6=10
 JJ6-JJ7=500
 JC16-TP20=453
 JK1-JK3=56.2
 JK3-TP12=56.2
 TP12-JK5=14
 JK3-JK5=56.8
 JK5-JK7=56.2
 JK7-JK9=56.2
 JK9-JK11=56.2
 JK11-JK13=56.2
 JK13-JK15=56.2
 JK15-JK17=56.2
 JK17-JK19=56.2
 JK19-JK21=56.2
 JK21-JK23=56.2
 JK23-JK24=56.2

7.2.20 Verify the following resistance measurements between the specified points. Resistance readings should be within +/- 5%.

7.3 *TEST COMPLETE*****

8. Notes

8.1 None at this time.

9. Attachments

9.1 None at this time.