GENERAL (%) ELECTRIC

P3K -AL-0404-A01

, - 0	***TANK		_
REV (A)	TITLE	CONT ON SHEET	2 вн. но. 1
se superior and a construction of the superior and the su	TEST INSTRUCTIONS FOR PLANT COMMUNICAT	LIONS	
P3K-AL-0404-A01	ANALOG (LOAD SET MOTOR POSITION INDICA	ATOR)	
CONT ON SHEET 2 SH NO. 1	FIRST MADE FOR FOR EHC MARK II (PLANT CO	OMMUNICATIONS	S)
And the second section of the second section of the second section of the second section secti			REVISIONS

I. SCOPE

~}~

This instruction outlines the specification for testing the Plant Communication Analog board IPCl-C001.

CIRCUIT BOARD 117D7374 -- LOAD SET MOTOR POSITION INDICATOR

II. CIRCUIT DESCRIPTION

The plant communications (PC) load set motor position indicator is designed to incorporate the following features:

- 1. Provides a means to convey to the customer the EHC load set motor position signal.
- 2. Analog signal processing done in a manner that provides protection to the EHC circuits that provide the signal, in the event that the output is abused, even seriously abused, by the customers equipment.
- 3. The isolation is provided by having a second RVDT on the load set motor drive unit. This RVDT is excited by a local oscillator on the 117D7374 board which is powered by the separate ± 15 VDC power supply. The same oscillator and power supply operate the necessary demodulator on the 117D7374 board to convert the AC signal to DC and amplify it.
- 4. No isolation circuits are required because the whole circuit is electrically isolated from the EHC control circuits.
- 5. The oscillator has adjustment pots for SHAPE CONTROL (VR50) and AMPLITUDE CONTROL (VR51). This amplitude control is for oscillator output not DC load set position output. The latter level is set by the output gain (VR1).

To provide the isolation, a separate power supply is required furnishing plus and minus $15\ \text{VDC}$ power.

A zero balance pot is provided on the output IC op amp.

III. CIRCUIT SPECIFICATIONS

- A. Power Supply Requirements
 - 1. Power Supply 1: +15.0 ± 0.1 VDC (Pins 21 & 25)
 - 2. Power Supply 2: -15.0 ± 0.1 VDC (Pins 20 & 25)

ACTIVE

273-71 273-138

273-2

273-12

273-221 273-227

PRINTS TO

MAPE BY CACLE SEP 21 1977

Steam Turbine Schenectady, N.Y.

DIV OR P 3K-AL-

P3K-AL-0404-A01

4-

+

CONT ON SHEET 3

P3K-AL-0404-A01

TITLE

REVISIONS

CONT ON SHEET

TEST INSTRUCTIONS FOR PLANT COMMUNICATIONS ANALOG (LOAD SET MOTOR POSITION INDICATOR)

FIRST MADE FOR FOR EHC MARK II (PLANT COMMUNICATIONS)

CIRCUIT SPECIFICATIONS (continued)

- Operating Signal Levels
 - 1. Oscillator Output (TP1 to TP5)
 - Voltage: 6.0 VRMS a.
 - Frequency: 3050 + 150 HZ
 - 2. Board Output (TP7 to TP5)
 - a. Voltage: -5 to +7 VDC for -250 to +350 rotational travel of the RVDT or -100° to $+140^{\circ}$ rotational travel of the motor drive manual shaft.
- C. Output Loads
 - The oscillator is loaded by the demodulator circuit including the RVDT.
 - The board output (pins 10 and 23): 2K Ohms.
- D. Continuity
 - Continuity exists between pins 23 and 25.

REQUIRED TESTS AND SETTINGS IV.

3 KHZ Oscillator Α.

> All tests, except that for temperature sensitivity, are to be done with the oscillator normally loaded with the transformer, and RVDT, and the demodulator.

Initial Starting

Adjust VR50 to mid range and observe TP1 with a scope (2 volt/div. amplitude, 50 usec/div. sweep). If necessary readjust for a non-distorted sine wave.

- 2. Distortion
 - FET (2N3822) Distortion

APPROVALS

Adjusting VR50 too far CW will cause the output TP1 to distort. Check distortion by centering the signal on both the amplitude and sweep coordinates as shown in Figure 1. Distortion occurs when the absolute value of T1 - T2 is greater than 10 usec and can be eliminated by backing down on VR50 (TP6).

SEP 21 1977 SEP 22 1977

Steam Turbine

DIV OR _ DEPT.

P3K-AL-0404-A01

Schenectady, N.Y.

LOCATION CONT ON SHEET

FF-BOS-WA (4-73) PROTECTION U.S.A.

+

CODE IDENT NO

PRINTS TO

GENERAL (%) ELECTRIC P3K-AL-0404-A01 CONT ON SHEET 4 SH NO. TEST INSTRUCTIONS FOR PLANT COMMUNICATIONS ANALOG (LOAD SET MOTOR POSITION INDICATOR) EHC MARK II (PLANT COMMUNICATIONS) FIRST MADE FOR REVISIONS REQUIRED TESTS AND SETTINGS (continued) 3 KHZ Oscillator (continued) (continued) (continued) Distorted Undistorted V_{gate} distorted > Vgate undistorted -T2 → 50 usec/dix sweep .FIG. 1 FET DISTORTION | T1 - T2 > 10 µsec Saturation Distortion Saturation will occur when $V_{\mbox{peak}}$ of TP1 is greater than the supply voltage (15V). It is eliminated by decreasing 3. V_{gate} (TP6) Setting Adjust VR50 so that the oscillator runs at the upper limit of linearity (absolute value of T/1 - T2 approaches 10 usec), i.e.: Set ygate to that its magnitude is approximately 10 mv below the Operation around this point give maximum distortion level. temperature and load change stability. A sampling of 25/FET/s has shown the upper limit of V gate to be between -2.6 and -1.0. TPG DE MISS. 4/73/2/pe

4. Amplitude Setting

VR51.

Adjust VR51 for $V_{TP1} = 6.000 \pm .010$ RMS.

APPROVALS

Frequency

P3K-AL-0404-A01

a.

CONT ON SHEET

IV.

SH NO.

3000 < f < 3400 Hz

SIP 22 Bir

Steam Turbine

Schenectady, N.Y.

DIV OR

P3K-AL-0404-A01

LOCATION CONT ON SHEET

CODE IDENT NO

PRINTS TO

+

REVISIONS

		L DIC IIII O	10-7 2101
REV DI	TITLE	CONT ON SHEET	5 sti NO. 4
are an expected by finding from the control of the state of the control of the co	TEST INSTRUCTIONS FOR PLANT COMMUNICA		
P3K-AL-0404-A01	ANALOG (LOAD SET MOTOR POSITION INDIC	*	• .
CONT ON SHEET 5 SH NO. 4	FIRST MADE FOR ENG MARK II (PLANT COM	MIONI GALIONS,	

REQUIRED TESTS AND SETTINGS (continued)

- 3 KHZ Oscillator (continued)
 - 6. Regeneration

4-

The oscillator must restart in all of the following situations:

- Simultaneously interrupt the +15 VDC and the -15 VDC power. Reconnect.
- Interrupt the +15 VDC power. Reconnect.
- Interrupt the -15 VDC power. Reconnect.
- Withdraw and reinsert the Load Set Motor Position Indicator board.
- Temperature Stability

This test may be conducted with the oscillator unloaded.

 ${f gate}$ set as in step 3 at ambient temperature, the absolute magnitude of the voltage at TP1 must not vary more than + .060V RMS as the temperature ranges between ambient and the r.

A small change in V_{gate} may be necessary to meet this spect the change at TP1 exceeds + .060, decrease the V_{gate} If the at TP1 exceeds - .060, increase V_{gate}.

8. Load Variance

No angular change in the RVDT between + 350 should cause the voltage at TP1 to vary more than + .015V RMS.

9. Envelop Modulation.

Envelop modulation should not exceed .015V peak to peak.

В.	0utr	out Setting	Note	, RVDT	Is Genred	4:1 (100° Shi Displace	vit D; sdA cenent concatt	- X2 / XV
A	1.	Adjust VR1 s	o that the	e output	(pin 10 a	and TP7) i	s <u>+</u> 5.0 VDC f	or
(k)		4 250 dienla	coment of	the RIM	I from ze	ara ar +	1000 dienlace	mant of

the motor drive manual shaft from zero.

Confirm that the output is linear within + 1%.

APPROVALS

CONNECT TPB To Com. Then Adjust UR52 FOR OVDC +.005 V at TP7 (Renove TPE To Com

Jumpea)	PRINTS T

27706	LUR	SEP	2	1.	197
'SSUEO	SEP 2	2 19	77		

Steam Turbine Schenectady, N.Y.

DIV OR ... DEM. P3K-AL-0404-A01

LOCATION CONT ON SHEET

SH NO. CODE FOENT NO

FF-803-WA (4-73) PRINTED IN U.S.A.

+

P3K-AL-0404-A01

CONT ON SHEET

P3K-AL-0404-A01

--

+

CONT ON SHEET

TEST INSTRUCTIONS FOR PLANT COMMUNICATIONS ANALOG (LOAD SET MOTOR POSITION INDICATOR) FIRST MADE FOR EHC MARK II (PLANT COMMUNICATIONS)

REVISIONS

REQUIRED TESTS AND SETTINGS (continued)

5

TITLE

C. RVDT Connections

RVDT		TERMINAL	PIN OR BOARD	
R1	Red	21	35	
R2	Black	22	34	
S 1	Yellow	23	18	
S2	Blue	24	. 19	

CLR SEP 21 1977 SEP 22 1977

Steam Turbine

DIV OR ... DEFT.

P3K-AL-0404-A01

LOCATION CONT ON SHEET

SH NO.

CODE IDENT NO

PRINTS TO

FF-803-WA (8-74) PRINTED IN U.S.A.

+

APPROVALS

Schenectady, N.Y.

FF-803-WA (4-73) FRINTED IN U.S.A.

+

CODE IDENT NO.

P3K-AL-0404-A01

DIV OR

LOCATION CONT ON SHEET

Steam Turbine

Schenectady, N.Y.

PRINTS TO